

THE CITY OF NEW YORK  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF WATER POLLUTION CONTROL

BOROUGH OF \_\_\_\_\_

CERTIFICATE OF INSPECTION  
NEW SEWER HOUSE CONNECTION

The following described sewer house connection has been laid from  
the property line to the existing sewer at premises:

N.B.# 1945/31 BLOCK 2070 LOT 18

UNDER PERMIT NO. 4401 ISSUED 3 17 80

PREMISES 43 CROFT PL  
(HOUSE NUMBER AND STREET)

LOCATED S SIDE, 259 FEET E OF Leh Ave

OWNER Lehman Estates Inc.

PLUMBER John A. Boccia

SIZE AND TYPE OF PIPE LAID 6" C.I.

CONN. TO (SIZE, TYPE) 10" SAN SEWER LOCATED IN  
(STREET/AVENUE) CROFT PL

I HEREBY CERTIFY THAT I MADE THE INSPECTION OF THE SEWER HOUSE  
CONNECTION DESCRIBED ABOVE AND THAT ALL WORK DONE UNDER THIS  
PERMIT HAS BEEN PROPERLY COMPLETED IN ACCORDANCE WITH EXISTING  
ORDINANCES AND RULES AND REGULATIONS.

DATE: 12-22-78 NAME (PRINT) B. P. ...

SIGNED [Signature]  
INSPECTOR-DIVISION OF SEWER CONSTRUCTION

NOTED [Signature]  
BOROUGH ENGINEER

PENALTY FOR FALSIFICATION:  
FALSIFICATION OF ANY STATEMENT MADE HEREIN IS AN OFFENSE PUNISHABLE BY A FINE  
OR IMPRISONMENT OR BOTH (N.Y.C. ADMINISTRATIVE CODE, SECTION 1151-9.0)

Copies to: \_\_\_\_\_ Borough Superintendent, Department of Buildings  
\_\_\_\_\_ Borough Office, Bureau of Water Register  
\_\_\_\_\_ Sewer Regulation and Control Section  
File original in Borough Construction Office

NOTE: The sewer to which the house connection is made is   
is not  connected to a private sewer treatment plant.  
Form No. WPC-15 Rev. 3 (6-77) [Yellow]

40	CRAFT PL.	2070	18
HOUSE NUMBER	STREET NAME	BLOCK	LOT

1. Was connection extended from existing curb connection?  YES  NO
2. Was the connection placed on earth, stone or crushed rock, concrete cradle, concrete encasement, or reinforced concrete encasement? (Circle)
3. Was connection made to existing spur or riser or cut in? (Circle)
4. If connection was "cut in", was saddle or dutchman used? (Circle, if yes)

5. Length, size and material of new connection \_\_\_\_\_

6. Depth of connection at curb line is \_\_\_\_\_ feet.

7. All work was exposed and inspected.


DATE: 01/24/78 SIGNED: [Signature]  
INSPECTOR-DIVISION OF SEWER CONSTRUCTION