



2021 - 2024

**COMISIÓN DE AGUA POTABLE Y ALCANTARILLADO
DEL MUNICIPIO DE IGUALA**

**PLANTA TRATADORA DE
AGUAS RESIDUALES**

**FLUJO
TOTALIZADO**

CAPAMI -PTAR

DICIEMBRE 2023

FECHA: 01-12-2023

FLUJO TOTALIZADO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			108.6		23	109.86
1:00			108.1		23	109.86
2:00			105.4		23	109.86
3:00			102.8		23	109.86
4:00			100.5		23	109.86
5:00			100.3		23	109.86
6:00			103.9		23	109.86
7:00			105.2		23	109.86
8:00			110.4		24	117.05
9:00			112.7		24	117.05
10:00			116.5		24	117.05
11:00			113.9		24	117.05
12:00			115.2		24	117.05
13:00			114.7		24	117.05
14:00			112.9		24	117.05
15:00			117.4		24	117.05
16:00			120.2		25	128.4
17:00			121.6		25	128.4
18:00			122.8		25	128.4
19:00			120.3		25	128.4
20:00			126.1		25	128.4
21:00			127.4		26	131.88
22:00			125.8		25	128.4
23:00			128.2		26	131.88

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

Edgar
1ER TURNO

Edgar
2DO TURNO

Edgar
3ER TURNO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			128.0		26	131.88
1:00			129.3		26	131.88
2:00			129.8		26	131.88
3:00			130.4		26	131.88
4:00			131.1		26	131.88
5:00			129.5		26	131.88
6:00			127.2		26	131.88
7:00			128.9		26	131.88
8:00			126.1		25	128.4
9:00			126.2		25	128.4
10:00			125.8		25	128.4
11:00			125.6		25	128.4
12:00			125.3		25	128.4
13:00			124.8		25	128.4
14:00			124.6		25	128.4
15:00			127.3		25	128.4
16:00			123.9		25	128.4
17:00			123.7		25	128.4
18:00			123.5		25	128.4
19:00			123.3		+25	128.4
20:00			122.9		24	117.05
21:00			122.7		24	117.05
22:00			122.5		24	117.05
23:00			122.3		24	117.05

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

1ER TURNO

2DO TURNO

3ER TURNO

CAPAMI

PLANTA DE TRATAMIENTO DE AGUAS RESIDUALES "IGUALA, GRO."

FECHA: 3/ Diciembre 2023

FLUJO TOTALIZADO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			123.8		25	128.4
1:00			123.6		25	128.4
2:00			123.3		25	128.4
3:00			124.9		25	128.4
4:00			124.7		25	128.4
5:00			124.5		25	128.4
6:00			125.8		25	128.4
7:00			125.4		25	128.4
8:00			126.6		25	128.4
9:00			127.9		25	128.4
10:00			127.0		25	128.4
11:00			127.3		25	128.4
12:00			130.5		26	131.88
13:00			132.8		26	131.88
14:00			132.6		26	131.88
15:00			130.4		26	131.88
16:00			134.7		26	131.88
17:00			135.2		26	131.88
18:00			134.0		26	131.88
19:00			133.8		25	128.4
20:00			129.5		25	128.4
21:00			128.9		25	128.4
22:00			128.1		23	109.86
23:00			125.3		23	109.86

PROMEDIO
DIARIO (ps)
CAUDAL TOTAL
(m³)

1ER TURNO

2DO TURNO

3ER TURNO

FECHA: 4-12-2023

FLUJO TOTALIZADO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			115.0		24	117.05
1:00			113.3		24	117.05
2:00			113.9		24	117.05
3:00			110.7		24	117.05
4:00			110.2		24	117.05
5:00			112.6		24	117.05
6:00			114.8		25	128.4
7:00			118.1		25	128.4
8:00			120.6		25	128.4
9:00			126.1		25	128.4
10:00			129.5		26	131.88
11:00			130.7		26	131.88
12:00			134.3		26	131.88
13:00			137.2		26	131.88
14:00			131.9		26	131.88
15:00			135.4		27	139.51
16:00			138.2		27	139.51
17:00			133.6		27	139.51
18:00			134.1		26	131.88
19:00			137.5		27	139.51
20:00			120.8		25	128.4
21:00			119.0		25	128.4
22:00			119.9		25	128.4
23:00			125.6		25	128.4

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

Edgar
1ER TURNO

Edgar
2DO TURNO

Edgar
3ER TURNO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			96.5		22	102.82
1:00			98.1		22	102.82
2:00			94.3		22	102.82
3:00			92.7		22	102.82
4:00			110.4		24	117.05
5:00			115.7		24	117.05
6:00			118.3		24	117.05
7:00			120.6		24	117.05
8:00			113.2		25	128.4
9:00			113.1		25	128.4
10:00			123.4		25	128.4
11:00			113.6		25	128.4
12:00			113.8		25	128.4
13:00			113.0		25	128.4
14:00			113.6		25	128.4
15:00			112.4		25	128.4
16:00			113.5		25	128.4
17:00			113.3		24	117.05
18:00			114.9		24	117.05
19:00			114.7		24	117.05
20:00			114.5		24	117.05
21:00			114.3		24	117.05
22:00			115.9		24	117.05
23:00			115.7		24	117.05

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

1ER TURNO

2DO TURNO

3ER TURNO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			115.5		24	117.05
1:00			115.3		24	117.05
2:00			116.9		24	117.05
3:00			116.7		24	117.05
4:00			116.5		24	117.05
5:00			116.3		24	117.05
6:00			117.9		25	117.05
7:00			117.5		25	117.05
8:00			121.8		25	128.4
9:00			123.3		25	128.4
10:00			123.0		25	128.4
11:00			126.7		25	128.4
12:00			125.4		25	128.4
13:00			127.7		25	128.4
14:00			128.1		25	128.4
15:00			128.3		25	128.4
16:00			129.5		25	128.4
17:00			129.2		25	128.4
18:00			129.6		25	128.4
19:00			126.1		25	128.4
20:00			126.4		25	128.4
21:00			120.8		24	117.05
22:00			120.1		24	117.05
23:00			118.4		24	117.05

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

1ER TURNO

2DO TURNO

3ER TURNO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			109.5		23	109.86
1:00			107.0		23	109.86
2:00			107.3		23	109.86
3:00			103.7		22	102.82
4:00			100.1		22	102.82
5:00			100.8		22	102.82
6:00			104.6		23	109.86
7:00			106.4		23	109.86
8:00			95.2		22	102.82
9:00			98.6		22	102.82
10:00			95.1		22	102.82
11:00			99.4		22	102.82
12:00			100.3		23	109.86
13:00			115.1		24	117.05
14:00			117.8		24	117.05
15:00			112.2		24	117.05
16:00			119.9		24	117.05
17:00			121.3		25	128.4
18:00			124.5		25	128.4
19:00			126.8		25	128.4
20:00			128.1		26	131.88
21:00			129.6		26	131.88
22:00			131.3		26	131.88
23:00			132.8		26	131.88

PROMEDIO
DIARIO (ps)
CAUDAL TOTAL
(m³)

Edgar
1ER TURNO

Edgar
2DO TURNO

Edgar
3ER TURNO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			112.4		24	117.05
1:00			110.5		24	117.05
2:00			105.8		24	117.05
3:00			114.1		24	117.05
4:00			116.2		24	117.05
5:00			121.8		25	128.4
6:00			120.5		25	128.4
7:00			122.9		25	128.4
8:00			124.2		25	128.4
9:00			124.0		25	128.4
10:00			125.2		25	128.4
11:00			125.4		25	128.4
12:00			125.6		25	128.4
13:00			125.3		25	128.4
14:00			124.9		25	128.4
15:00			124.7		25	128.4
16:00			124.5		25	128.4
17:00			124.3		25	128.4
18:00			123.4		25	128.4
19:00			123.7		25	128.4
20:00			123.5		25	128.4
21:00			123.3		24	117.05
22:00			123.0		24	117.05
23:00			122.9		24	117.05

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

1ER TURNO

2DO TURNO

3ER TURNO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			122.7		24	117.05
1:00			122.5		24	117.05
2:00			122.3		24	117.05
3:00			121.9		24	117.05
4:00			121.7		24	117.05
5:00			121.5		24	117.05
6:00			121.3		24	117.05
7:00			120.9		22	117.05
8:00			119.3		24	117.05
9:00			121.6		24	117.05
10:00			122.0		25	128.4
11:00			122.9		25	128.4
12:00			124.1		25	128.4
13:00			126.4		25	128.4
14:00			126.8		25	128.4
15:00			128.5		25	128.4
16:00			129.2		25	128.4
17:00			129.3		25	128.4
18:00			129.0		25	128.4
19:00			127.2		25	128.4
20:00			125.1		25	128.4
21:00			125.9		25	128.4
22:00			125.4		25	128.4
23:00			121.1		24	117.05

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

1ER TURNO

2DO TURNO

3ER TURNO

CAPAMI**PLANTA DE TRATAMIENTO DE AGUAS RESIDUALES "IGUALA, GRO."**FECHA: 10-12-2023

FLUJO TOTALIZADO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			108.1		23	109.86
1:00			108.6		23	109.86
2:00			105.3		23	109.86
3:00			103.5		22	102.82
4:00			100.8		22	102.82
5:00			101.0		22	102.82
6:00			104.2		22	102.82
7:00			106.4		23	109.86
8:00			89.3		20	91.4
9:00			89.7		20	91.4
10:00			90.1		20	91.4
11:00			90.9		20	91.4
12:00			92.5		21	95.93
13:00			94.8		21	95.93
14:00			91.1		21	95.93
15:00			96.4		21	95.93
16:00			97.3		22	102.82
17:00			97.7		22	102.82
18:00			97.5		22	102.82
19:00			98.1		22	102.82
20:00			99.9		22	102.82
21:00			100.3		22	102.82
22:00			110.4		24	117.05
23:00			115.8		24	117.05

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

Edgar
1ER TURNO

Edgar
2DO TURNO

Edgar
3ER TURNO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			112.8		24	117.05
1:00			114.1		24	117.05
2:00			116.9		24	117.05
3:00			115.7		24	117.05
4:00			121.6		25	128.4
5:00			124.3		25	128.4
6:00			126.4		25	128.4
7:00			127.2		25	128.4
8:00			126.9		25	128.4
9:00			126.6		25	128.4
10:00			126.3		25	128.4
11:00			125.9		25	128.4
12:00			125.7		25	128.4
13:00			125.3		25	128.4
14:00			124.9		25	128.4
15:00			124.7		25	128.4
16:00			124.5		25	128.4
17:00			124.3		25	128.4
18:00			123.9		25	128.4
19:00			123.7		25	128.4
20:00			123.5		25	128.4
21:00			123.3		25	128.4
22:00			122.9		24	117.05
23:00			122.7		24	117.05

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

1ER TURNO

2DO TURNO

3ER TURNO

CAPAMI
1971 - 2024

PLANTA DE TRATAMIENTO DE AGUAS RESIDUALES "IGUALA, GRO."

FECHA: 12-12-2023

FLUJO TOTALIZADO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			122.5		25	128.4
1:00			122.3		25	128.4
2:00			121.9		25	128.4
3:00			121.7		25	128.4
4:00			121.5		24	117.05
5:00			121.3		24	117.05
6:00			120.9		24	117.05
7:00			120.7		24	117.05
8:00			123.4		25	128.4
9:00			125.0		25	128.4
10:00			125.6		25	128.4
11:00			127.9		25	128.4
12:00			127.1		26	131.88
13:00			127.3		26	131.88
14:00			128.7		26	131.88
15:00			128.5		26	131.88
16:00			129.6		26	131.88
17:00			129.1		26	131.88
18:00			129.8		26	131.88
19:00			128.2		26	131.88
20:00			130.4		26	131.88
21:00			130.0		26	131.88
22:00			125.9		25	128.4
23:00			125.3		25	128.4

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

1ER TURNO

2DO TURNO

3ER TURNO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			115.8		24	117.05
1:00			115.2		24	117.05
2:00			113.4		23	109.86
3:00			110.1		23	109.86
4:00			108.6		23	109.86
5:00			108.3		23	109.86
6:00			109.5		23	109.86
7:00			113.2		24	117.05
8:00			116.4		24	117.05
9:00			112.1		24	117.05
10:00			119.5		25	128.4
11:00			120.2		25	128.4
12:00			124.6		25	128.4
13:00			121.0		25	128.4
14:00			122.8		25	128.4
15:00			121.4		25	128.4
16:00			126.1		25	128.4
17:00			119.9		25	128.4
18:00			120.7		25	128.4
19:00			126.2		25	128.4
20:00			128.4		26	131.88
21:00			125.1		26	131.88
22:00			120.8		25	128.4
23:00			129.3		26	131.88

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

Edgar
1ER TURNO

Edgar
2DO TURNO

Edgar
3ER TURNO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			92.4		21	95.93
1:00			96.7		22	102.82
2:00			99.3		22	102.82
3:00			100.8		22	102.82
4:00			110.2		24	117.05
5:00			114.5		24	117.05
6:00			116.1		24	117.05
7:00			119.9		24	117.05
8:00			120.5		23	109.86
9:00			120.3		23	109.86
10:00			119.9		24	117.05
11:00			119.7		24	117.05
12:00			119.5		24	117.05
13:00			119.3		24	117.05
14:00			118.9		24	117.05
15:00			118.7		24	117.05
16:00			118.5		24	117.05
17:00			118.3		24	117.05
18:00			117.9		24	117.05
19:00			117.7		24	117.05
20:00			117.5		24	117.05
21:00			117.3		24	117.05
22:00			117.1		24	117.05
23:00			116.9		24	117.05

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

1ER TURNO

2DO TURNO

3ER TURNO

CAPAMI
1921-2321

PLANTA DE TRATAMIENTO DE AGUAS RESIDUALES "IGUALA, GRO."

FECHA: 15/10 Diciembre / 2023

FLUJO TOTALIZADO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			116.7		24	117.05
1:00			116.5		24	117.05
2:00			116.3		24	117.05
3:00			115.9		24	117.05
4:00			115.7		24	117.05
5:00			115.5		24	117.05
6:00			115.3		24	117.05
7:00			114.6		24	117.05
8:00			115.5		24	117.05
9:00			118.3		24	117.05
10:00			118.8		25	128.4
11:00			123.2		25	128.4
12:00			128.1		25	128.4
13:00			127.9		26	131.88
14:00			129.0		26	131.88
15:00			129.7		26	131.88
16:00			129.4		26	131.88
17:00			129.6		26	131.88
18:00			130.3		26	131.88
19:00			132.5		26	131.88
20:00			131.8		26	131.88
21:00			130.6		26	131.88
22:00			127.2		25	128.4
23:00			126.0		25	128.4

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

1ER TURNO

2DO TURNO

3ER TURNO

FECHA: 16-12-2023

FLUJO TOTALIZADO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			108.3		23	109.86
1:00			105.6		23	109.86
2:00			103.0		22	102.82
3:00			103.9		22	102.82
4:00			100.7		22	102.82
5:00			100.5		22	102.82
6:00			102.8		22	102.82
7:00			107.2		23	109.86
8:00			99.4		22	102.82
9:00			99.7		22	102.82
10:00			103.3		22	102.82
11:00			101.6		22	102.82
12:00			105.9		22	102.82
13:00			104.5		22	102.82
14:00			107.7		22	102.82
15:00			108.6		22	102.82
16:00			105.5		22	102.82
17:00			104.0		22	102.82
18:00			101.3		22	102.82
19:00			109.1		22	102.82
20:00			99.8		21	95.93
21:00			99.4		21	95.93
22:00			98.2		21	95.93
23:00			99.3		21	95.93

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

1ER TURNO

2DO TURNO

3ER TURNO

CAPAMI
1071-2311

PLANTA DE TRATAMIENTO DE AGUAS RESIDUALES "IGUALA, GRÓ."

FECHA: 17/12/2023

FLUJO TOTALIZADO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			98.5		21	95.93
1:00			98.4		21	95.93
2:00			96.9		21	95.93
3:00			97.8		21	95.93
4:00			97.8		21	95.93
5:00			97.5		21	95.93
6:00			96.7		21	95.93
7:00			96.9		21	95.93
8:00			109.3		23	109.86
9:00			108.7		23	109.86
10:00			108.5		23	109.86
11:00			108.3		23	109.86
12:00			107.9		23	109.86
13:00			107.7		23	109.86
14:00			107.5		23	109.86
15:00			107.3		23	109.86
16:00			106.9		23	109.86
17:00			106.6		23	109.86
18:00			106.3		23	109.86
19:00			105.9		23	109.86
20:00			105.7		23	109.86
21:00			105.5		23	109.86
22:00			105.3		23	109.86
23:00			104.9		23	109.86

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

1ER TURNO

2DO TURNO

3ER TURNO

FECHA: 18/Diciembre/2023

FLUJO TOTALIZADO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			110.2		23	109.86
1:00			110.4		23	109.86
2:00			110.6		23	109.86
3:00			110.8		23	109.86
4:00			111.4		23	109.86
5:00			111.6		23	109.86
6:00			111.8		23	109.86
7:00			112.3		24	117.05
8:00			113.8		23	109.86
9:00			115.2		23	109.86
10:00			115.5		23	109.86
11:00			114.0		23	109.86
12:00			116.3		24	117.05
13:00			117.6		24	117.05
14:00			119.4		24	117.05
15:00			119.7		24	117.05
16:00			119.0		24	117.05
17:00			118.9		24	117.05
18:00			117.7		24	117.05
19:00			117.2		24	117.05
20:00			116.0		24	117.05
21:00			114.2		23	109.86
22:00			112.4		23	109.86
23:00			110.6		23	109.86

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

1ER TURNO

2DO TURNO

3ER TURNO

FECHA: 19-12-2023

FLUJO TOTALIZADO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			101.4		22	102.82
1:00			100.7		22	102.82
2:00			99.0		22	102.82
3:00			99.3		22	102.82
4:00			99.8		22	102.82
5:00			103.2		23	109.86
6:00			105.4		23	109.86
7:00			105.3		23	109.86
8:00			110.4		24	117.05
9:00			112.4		24	117.05
10:00			118.2		24	117.05
11:00			111.5		24	128.4
12:00			117.3		25	128.4
13:00			120.1		25	128.4
14:00			120.6		25	128.4
15:00			120.9		25	128.4
16:00			121.2		25	128.4
17:00			124.4		25	128.4
18:00			126.1		26	131.88
19:00			128.8		26	131.88
20:00			130.4		26	131.88
21:00			130.7		26	131.88
22:00			131.2		26	131.88
23:00			132.5		26	131.88

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

Edgar
1ER TURNO

Edgar
2DO TURNO

Edgar
3ER TURNO

FECHA: 20/Diciembre/2023

FLUJO TOTALIZADO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			93.1		21	95.93
1:00			94.6		21	95.93
2:00			92.9		21	95.93
3:00			95.7		22	102.82
4:00			100.3		22	102.82
5:00			105.1		22	102.82
6:00			110.5		24	117.05
7:00			112.9		24	117.05
8:00			113.2		24	117.05
9:00			113.4		24	117.05
10:00			113.6		24	117.05
11:00			113.8		24	117.05
12:00			114.2		24	117.05
13:00			114.6		24	117.05
14:00			114.8		24	117.05
15:00			115.2		24	117.05
16:00			115.9		24	117.05
17:00			115.6		24	117.05
18:00			115.8		24	117.05
19:00			116.2		24	117.05
20:00			116.9		24	117.05
21:00			116.6		24	117.05
22:00			116.8		24	117.05
23:00			117.2		24	117.05

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

1ER TURNO

2DO TURNO

3ER TURNO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			117.4		24	117.05
1:00			117.6		24	117.05
2:00			117.8		24	117.05
3:00			118.2		24	117.05
4:00			118.4		24	117.05
5:00			118.6		24	117.05
6:00			118.8		25	128.4
7:00			119.4		25	128.4
8:00			117.7		24	117.05
9:00			117.3		24	117.05
10:00			119.0		24	117.05
11:00			119.9		24	117.05
12:00			119.5		24	117.05
13:00			123.7		25	128.4
14:00			126.4		25	128.4
15:00			128.6		25	128.4
16:00			128.2		25	128.4
17:00			129.1		25	128.4
18:00			129.6		25	128.4
19:00			127.0		25	128.4
20:00			108.3		23	109.86
21:00			108.5		23	109.86
22:00			105.1		23	109.86
23:00			103.4		23	109.86

PROMEDIO
DIARIO (ps)
CAUDAL TOTAL
(m³)

1ER TURNO

2DO TURNO

3ER TURNO

FECHA: 22-12-2023

FLUJO TOTALIZADO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			103.4		22	102.82
1:00			100.8		22	102.82
2:00			100.1		21	95.93
3:00			95.3		21	95.93
4:00			93.5		21	95.93
5:00			93.0		21	95.93
6:00			95.9		21	95.93
7:00			100.7		22	102.82
8:00			110.2		25	128.4
9:00			112.5		25	128.4
10:00			109.6		25	128.4
11:00			113.9		25	128.4
12:00			115.4		25	128.4
13:00			111.8		24	117.05
14:00			116.3		24	117.05
15:00			119.9		24	117.05
16:00			122.5		25	128.4
17:00			124.1		25	128.4
18:00			126.6		25	128.4
19:00			129.9		26	128.4
20:00			130.0		26	131.88
21:00			131.7		26	131.88
22:00			133.4		27	139.51
23:00			135.5		27	139.51

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

Edgar
1ER TURNO

Edgar
2DO TURNO

Edgar
3ER TURNO

CAPAMI

2011-2024

PLANTA DE TRATAMIENTO DE AGUAS RESIDUALES "IGUALA, GRO."

FECHA: 23/ Diciembre/2023

FLUJO TOTALIZADO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			92.3		21	95.93
1:00			93.9		21	95.93
2:00			94.6		21	95.93
3:00			97.1		22	102.82
4:00			99.9		22	102.82
5:00			110.3		24	117.05
6:00			115.8		24	117.05
7:00			118.4		24	117.05
8:00			118.6		24	117.05
9:00			118.8		24	117.05
10:00			118.7		24	117.05
11:00			119.3		24	117.05
12:00			119.6		24	117.05
13:00			119.9		24	117.05
14:00			120.2		24	117.05
15:00			120.4		24	117.05
16:00			120.7		24	117.05
17:00			120.6		24	117.05
18:00			120.9		24	117.05
19:00			121.2		24	117.05
20:00			121.4		24	117.05
21:00			121.6		24	117.05
22:00			121.8		24	117.05
23:00			122.2		24	117.05

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

1ER TURNO

2DO TURNO

3ER TURNO

CAPAMI**PLANTA DE TRATAMIENTO DE AGUAS RESIDUALES "IGUALA, GRO."**FECHA: 29/ Diciembre/ 2023 FLUJO TOTALIZADO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			122.1		24	117.05
1:00			121.9		24	117.05
2:00			121.6		24	117.05
3:00			121.9		24	117.05
4:00			121.2		24	117.05
5:00			120.9		24	117.05
6:00			120.6		24	117.05
7:00			120.4		24	117.05
8:00			124.6		25	128.4
9:00			126.3		25	128.4
10:00			128.1		25	128.4
11:00			129.5		25	128.4
12:00			131.0		26	131.88
13:00			133.2		26	131.88
14:00			133.4		26	131.88
15:00			135.8		26	131.88
16:00			133.2		26	131.88
17:00			131.7		26	131.88
18:00			130.4		26	131.88
19:00			130.6		26	131.88
20:00			128.2		25	128.4
21:00			129.8		25	128.4
22:00			128.0		25	128.4
23:00			126.2		25	128.4

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

1ER TURNO

2DO TURNO

3ER TURNO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			108.5		23	109.86
1:00			109.3		23	109.86
2:00			105.0		23	109.86
3:00			105.8		23	109.86
4:00			103.1		23	109.86
5:00			103.4		23	109.86
6:00			100.7		23	109.86
7:00			102.9		23	109.86
8:00			107.2		24	117.05
9:00			110.6		24	117.05
10:00			112.8		24	117.05
11:00			115.3		24	117.05
12:00			117.0		24	117.05
13:00			118.3		25	128.4
14:00			119.6		25	128.4
15:00			120.1		25	128.4
16:00			116.0		25	128.4
17:00			112.4		25	128.4
18:00			121.7		25	128.4
19:00			125.2		25	128.4
20:00			128.1		26	131.88
21:00			126.5		26	131.88
22:00			129.3		26	131.88
23:00			130.6		26	131.88

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

Edgar
1ER TURNO

Edgar
2DO TURNO

Edgar
3ER TURNO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			91.5		21	95.93
1:00			93.6		21	95.93
2:00			95.2		22	102.82
3:00			98.1		22	107.82
4:00			99.3		22	102.82
5:00			100.8		23	109.86
6:00			110.4		23	109.86
7:00			112.9		24	117.05
8:00			112.7		24	117.05
9:00			112.5		24	117.05
10:00			112.3		24	117.05
11:00			113.9		24	117.05
12:00			113.7		24	117.05
13:00			113.5		24	117.05
14:00			113.3		24	117.05
15:00			114.9		24	117.05
16:00			114.7		24	117.05
17:00			114.5		24	117.05
18:00			114.3		24	117.05
19:00			115.9		24	117.05
20:00			118.7		24	117.05
21:00			115.5		24	117.05
22:00			115.3		24	117.05
23:00			116.9		24	117.05

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

1ER TURNO

2DO TURNO

3ER TURNO

CAPAMI**PLANTA DE TRATAMIENTO DE AGUAS RESIDUALES "IGUALA, GRO."**FECHA: 27/Diciembre/2023

FLUJO TOTALIZADO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			116.7		24	117.05
1:00			116.5		24	117.05
2:00			116.3		24	117.05
3:00			117.9		24	117.05
4:00			117.7		24	117.05
5:00			117.5		24	117.05
6:00			117.3		24	117.05
7:00			118.9		24	117.05
8:00			116.6		24	117.05
9:00			117.4		24	117.05
10:00			117.0		24	117.05
11:00			119.5		24	117.05
12:00			124.3		25	128.4
13:00			126.7		25	128.4
14:00			128.4		25	128.4
15:00			128.8		25	128.4
16:00			129.0		25	128.4
17:00			129.9		25	128.4
18:00			128.1		25	128.4
19:00			128.4		25	128.4
20:00			122.2		24	117.05
21:00			120.5		24	117.05
22:00			118.8		24	117.05
23:00			116.1		24	117.05

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

1ER TURNO

2DO TURNO

3ER TURNO

FECHA: 28-12-2023

FLUJO TOTALIZADO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			108.5		23	109.86
1:00			105.8		23	109.86
2:00			103.0		23	109.86
3:00			100.3		22	102.82
4:00			100.4		22	102.82
5:00			98.7		22	102.82
6:00			99.2		22	102.82
7:00			101.6		22	102.82
8:00			98.2		22	102.82
9:00			98.5		22	102.82
10:00			97.7		22	102.82
11:00			110		22	102.82
12:00			111.8		25	128.4
13:00			114.1		25	128.4
14:00			114.6		25	128.4
15:00			116.1		25	128.4
16:00			117.3		25	128.4
17:00			118.8		25	128.4
18:00			118.4		25	128.4
19:00			119.1		25	128.4
20:00			120.2		25	128.4
21:00			120.8		25	128.4
22:00			128.0		25	128.4
23:00			124.1		25	128.4

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

Edgar
1ER TURNO

Edgar
2DO TURNO

Edgar
3ER TURNO



PLANTA DE TRATAMIENTO DE AGUAS RESIDUALES "IGUALA, GRO."

FECHA: 29 / Diciembre / 2023

FLUJO TOTALIZADO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			91.4		21	95.93
1:00			92.5		21	95.93
2:00			91.8		21	95.93
3:00			92.9		21	95.93
4:00			93.5		21	95.93
5:00			94.1		21	95.93
6:00			94.7		21	95.93
7:00			95.2		21	95.93
8:00			106.8		23	109.86
9:00			106.4		23	109.86
10:00			106.2		23	109.86
11:00			105.8		23	109.86
12:00			105.6		23	109.86
13:00			105.4		23	109.86
14:00			105.2		23	109.86
15:00			104.6		22	102.82
16:00			104.3		22	102.82
17:00			102.6		22	102.82
18:00			102.4		22	102.82
19:00			102.2		22	102.82
20:00			101.9		22	102.82
21:00			101.6		22	102.82
22:00			101.4		22	102.82
23:00			101.2		22	102.82

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

1ER TURNO

2DO TURNO

3ER TURNO



PLANTA DE TRATAMIENTO DE AGUAS RESIDUALES "IGUALA, GRO."

FECHA: 30/ Diciembre/ 2023 FLUJO TOTALIZADO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			101.6		22	102.82
1:00			101.8		22	102.82
2:00			102.9		22	102.82
3:00			102.6		22	102.82
4:00			102.4		22	102.82
5:00			102.8		22	102.82
6:00			103.3		22	102.82
7:00			103.6		22	102.82
8:00			105.2		23	109.86
9:00			108.9		23	109.86
10:00			109.4		23	109.86
11:00			109.0		23	109.86
12:00			109.7		23	109.86
13:00			115.5		24	117.05
14:00			117.8		24	117.05
15:00			119.1		24	117.05
16:00			118.6		24	117.05
17:00			119.3		24	117.05
18:00			117.0		24	117.05
19:00			119.9		24	117.05
20:00			115.4		24	117.05
21:00			108.7		23	109.86
22:00			109.2		23	109.86
23:00			107.3		23	109.86

PROMEDIO DIARIO (lps)
CAUDAL TOTAL (m³)

1ER TURNO

2DO TURNO

3ER TURNO

CAPAMI

PLANTA DE TRATAMIENTO DE AGUAS RESIDUALES "IGUALA, GRO."

FECHA: 31-12-2023

FLUJO TOTALIZADO

HORA	MEDIDOR DE FLUJO DE INFLUENTE		MEDIDOR DE FLUJO DE EFLUENTE		PARSHALL	
	lts/seg	m3x100	lts/seg	m3x100	ALTURA	FLUJO
					cm	l/seg
0:00			106.4		23	109.86
1:00			104.8		22	102.82
2:00			101.1		22	102.82
3:00			98.7		22	102.82
4:00			94.2		22	102.82
5:00			96.5		22	102.82
6:00			98.9		22	102.82
7:00			100.1		22	102.82
8:00			110.9		24	117.05
9:00			112.3		24	117.05
10:00			112.7		24	117.05
11:00			114.1		24	117.05
12:00			115.3		24	117.05
13:00			116.7		24	117.05
14:00			116.2		24	117.05
15:00			117.5		25	128.4
16:00			118.4		25	128.4
17:00			118.8		25	128.4
18:00			119.5		25	128.4
19:00			120.7		25	128.4
20:00			121.2		25	128.4
21:00			121.8		25	128.4
22:00			122.4		25	128.4
23:00			122.9		25	128.4

PROMEDIO
DIARIO (lps)
CAUDAL TOTAL
(m³)

Edgar
1ER TURNO

Edgar
2DO TURNO

Edgar
3ER TURNO