


East Lake Tarpon Special Fire Control District

	<i>SOP 906 Fuel (revised)</i>	
	Implementation Date: 11/2000	Revision Date(s): 8/06/2010
		Reviewed Date(s):
	Forms or Attachments: None	

A. STATION 57 DIESEL TANK

The fuel maintained at Station 57 is for the stand-by generator only. The tank shall be measured each Monday by the following method:

1. Tank checked and inches recorded on the Department weekly inspection form.

B. FUELING VEHICLES AT COUNTY SITE:

Vehicles will be refueled at a County site when below 3/4 of a tank. These facilities have 24 hour access. New county fuel system will record vehicles and amounts.

NOTE: When filling cans etc. use 5 gallon fuel key (red).

For vehicles using diesel, follow instructions above.

ASSET NUMBERS FOR EAST LAKE TARPON SPECIAL FIRE CONTROL DISTRICT

PRIMARY VEHICLES	CO. ID	DESCRIPTION	FUEL
05240	524	1961 AM. LA FRANCE	DIESEL
05250	S57	2002 E-ONE/SAULSBURY	DIESEL
05260	E57	2003 E-ONE/SAULSBURY	DIESEL
05280	E58	2003 E-ONE/SAULSBURY	DIESEL
05290	E56	2009 E-ONE/SAULSBURY	DIESEL
05400	EL 500	2003 FORD EXPLORER	UNLEADED
05410	EL100	2009 Chevy Impala	UNLEADED
05420	EL400	2007 FORD TAURUS	UNLEADED
05430	DC	2008 F250	UNLEADED
05470	Reserve	1999 FORD EXPEDITION	UNLEADED
05480	W58	2005 AMERICAN LA FRANCE	DIESEL
05490	B58	2006 FORD F550	UNLEADED

	DESCRIPTION	FUEL
1330426	MISC. FUEL CANS	UNLEADED