

West Virginia Department of Health & Human Resources

Berkeley County Health Department



GENERAL SANITATION INSPECTION REPORT

Establishment Information		
Facility Name Orchard View Intermediate	Facility Type School	
Licensee Name Berkeley Co. Board of Education	Facility Telephone # 304 263-4143	
Facility Address 1455 Delmar Orchard Rd Martinsburg, WV	Licensee Address ,	
Inspection Information		
Inspection Type Routine	Inspection Date 06/16/2017	Total Time Spent 1.52

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 6 Repeated # 0</p> <p><i>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose.</i> OBSERVATION: Back ramp needs repaired</p> <p><i>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose.</i> OBSERVATION: POD door needs repaired very hard to open</p> <p><i>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose.</i> OBSERVATION: Water fountain in the 5th grade wing needs repaired or replaced, being held together by duct tape.</p> <p><i>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose.</i> OBSERVATION: Multiple ceiling tiles need replaced, showing water damage</p> <p><i>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose.</i> OBSERVATION: Forth grade boy's bathroom urinal leaking water</p> <p><i>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose.</i> OBSERVATION: Faucet leaks in 404,420, mant rooms floors waxed and could not be checked</p>

Inspection Outcome

Comments
Make sure hot water is turned back on before students arrive back to school. Off due to cost saving methods.

Disclaimer

Person in Charge

Onfile

Sanitarian

Glenn GCO Ondick