

LAPLAWD

SUNDANCE FARRADAY SUB DISTRICT No. 1 WATER DISTRIBUTION SYSTEM PROJECT

Adendum No. 1

Amendment No. 1 of the SUNDANCE FARRADAY SUB DISTRICT No. 1 WATER DISTRIBUTION SYSTEM PROJECT is hereby issued as below:

1. All references to Project Duration shall be changed from "120 days" to "240 days".
2. In the Bid Schedule, or in any other contract document citing, reference to 2"Ø "DR18 C-900" pipe is now changed to 2"Ø "Schedule 40 Solvent Weld" pipe.
3. Reference contact information on Page 3 of the Contract Documents shall be changed from "brett@durangowater.com" to "dave@durangowater.com".
4. Combination [air release/ vacuum relief] Valves specified as model A.R.I. D-050/52 or D-60/65 may be substituted with A.R.I. model D-40.
5. Castings Inc. Model IMH15024FPAL - Frost Free 24" Aluminum Inverted Manhole Ring and Cover, with H-20 load-rating, may be used.

David Henry, PE

Harris Water Engineering, for LAPLAWD

Date