


East Lake Tarpon Special Fire Control District

	<i>SOP 910 Three Month Vehicle Maintenance</i>	
	Implementation Date: 11/2000	Revision Date(s): 7/02/2009
		Reviewed Date(s):
	Forms or Attachments: None	

All appliances shall be cleaned during monthly cleaning.

1. Gated Wyes and Siamese shall be inspected for corrosion and ease of operation. They shall be cleaned as necessary.
2. All Gated Steamer intakes shall be checked for ease of operation. If needed, lubricate them for proper operation using a dry silicone lubricant.

NOTE: Remove and lube threads