

**LAFAYETTE COUNTY BUILDING DEPARTMENT
120 WEST MAIN STREET
MAYO, FLORIDA 32066**

PERMITTING A CAMPER SERVICE

NON FLOOD ZONE PERMIT REQUIREMENTS:

1. **MUST MEET ZONING REQUIREMENTS**
2. **SEPTIC TANK MUST BE INSTALLED & APPROVED BY HEALTH DEPARTMENT BEFORE POWER RELEASED**
3. **MAXIMUM 60 AMP SERVICE ALLOWED**
4. **POLE MUST MEET NATIONAL ELECTRIC CODE AND LOCAL POWER COMPANY SPECIFICATIONS**
5. **OUTLET INSTALLED FOR CAMPER POWER**
6. **CAMPER MUST MEET FEMA REGULATIONS:**
 - A. **BE ON THE SITE FEWER THAN 180 CONSECUTIVE DAYS**
 - B. **BE FULLY LICENSED AND READY FOR HIGHWAY USE**
 - I. **ON IT'S WHEELS OR JACKING SYSTEM**
 - II. **ATTACHED TO THE SITE BY QUICK DISCONNECT TYPE UTILITIES AND SECURITY DEVICES**
 - III. **HAS NO PERMANENTLY ATTACHED ADDITIONS**

FLOOD ZONE PERMIT REQUIREMENTS:

1. **MUST MEET ZONING REQUIREMENTS**
2. **SEPTIC TANK MUST BE INSTALLED & APPROVED BY HEALTH DEPARTMENT BEFORE POWER RELEASED**
3. **MAXIMUM 60 AMP SERVICE ALLOWED**
4. **POLE MUST MEET NATIONAL ELECTRIC CODE AND LOCAL POWER COMPANY SPECIFICATIONS**
5. **OUTLET INSTALLED FOR CAMPER POWER**
6. **CAMPER MUST MEET FEMA REGULATIONS:**
 - A. **BE ON THE SITE FEWER THAN 180 CONSECUTIVE DAYS**
 - B. **BE FULLY LICENSED AND READY FOR HIGHWAY USE**
 - I. **ON IT'S WHEELS OR JACKING SYSTEM**
 - II. **ATTACHED TO THE SITE BY QUICK DISCONNECT TYPE UTILITIES AND SECURITY DEVICES**
 - III. **HAS NO PERMANENTLY ATTACHED ADDITIONS**
7. **THE 100-YEAR FLOODPLAIN MUST BE ESTABLISHED BEFORE PERMITTING AND METER BASE-PANEL BOX MUST BE INSTALLED ONE (1) FOOT ABOVE THE 100-YEAR FLOODPLAIN AS ESTABLISHED AT PERMITTING. A CERTIFICATE OF ELEVATION BY A SURVEYOR OR ENGINEER LICENSED BY THE STATE OF FLORIDA THAT CERTIFIES THAT THE SERVICE MEETS FEMA AND LAFAYETTE COUNTY REGULATIONS WILL BE REQUIRED BEFORE RELEASING POWER TO THE POWER COMPANY.**
8. **ALL ELECTRICAL INSTALLED BELOW THE BASE FLOOD ELEVATION WILL REQUIRE GROUND FAULT PROTECTION OUT OF THE FLOOD ZONE.**
9. **THE CENTER OF THE METER BASE IS REQUIRED TO SET AT 66 INCHES ABOVE THE STANDING SURFACE. IF ELEVATED ABOVE THIS (5ft 6inches) THEN A PLATFORM 3' X 3' WILL BE REQUIRED WITH ACCESS STAIRS PER CHAPTER 10 OF THE FLORIDA BUIILDING CODE.**