

**West Virginia Department of Health &
Human Resources
Berkeley County Health Department**

No image found with name:
Berkeley.png. Image files
needed to be generated.

GENERAL SANITATION INSPECTION REPORT

| <i>Establishment Information</i> | | |
|---|--------------------------------------|--------------------------|
| Facility Name Eagle School Intermediate | Facility Type School | |
| Licensee Name Berkeley Co. Board of Education | Facility Telephone # 304 263-0422 | |
| Facility Address 730 Eagle School Rd Martinsburg , WV | Licensee Address , | |
| <i>Inspection Information</i> | | |
| Inspection Type Routine | Inspection Date 05/31/2019 | Total Time Spent 3.25 |

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

| <i>Observed Violations</i> |
|--|
| <p>Total # 5 Repeated # 0</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose. OBSERVATION: Leaking faucets in rooms 515,518,517,521,522,125,402,401,405,421</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose. OBSERVATION: No hot water observed in the gym side bathrooms</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose. OBSERVATION: Stained ceiling tiles 301,504</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose. OBSERVATION: Water sensors need repaired in several bathroom faucets</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose. OBSERVATION: Fifth grade water fountains needs repaired</p> |

| <i>Inspection Outcome</i> |
|----------------------------------|
| |

| <i>Comments</i> |
|------------------------|
| |

Disclaimer

Person in Charge
On file

Sanitarian
Glenn GCO Ondick