

WWTP Report

July - August 2017

- No out of service or major maintenance necessary since last report
- Plant is averaging 70,000 gallons per day
- One sludge hauls at 5362 gallons and two hauls at 6000 per haul
- The flow chart malfunctioned and was reporting very high flow rates. Biometrics had the flow meter recalibrated and it was discovered that the transducer had fallen off or came loose.
- No odor complaints were reported
- Consideration is being given to covering the head works bar screen area to prevent rainwater from entering the disposal container.