

WWTP Report

March 21, 2017

- No out of service or major maintenance necessary since last report
- Plant is averaging 90,000 gallons per day
- Five sludge hauls at 6,000 gallons per haul
- Plant operator has been made aware of several odor complaints. He is requesting times and dates if possible from those who are complaining. Operator continues to experiment with the newly installed timer and flow rate of material from oxidation ditch. Recently, the flow of mixed liquor has made difference in the frequency of odor complaints
- New locks have been ordered to secure all test wells with one common key
- Test wells have been cleared of vegetation
- Lift station generator receptacles for emergency power need to be replaced. There is a question as to whom is responsible for supplying the generator in such an emergency. This issue needs to be resolved before ordering the receptacles so we know we are purchasing the correct ones. The audible alarms at the lift stations are not functional. The plan was to replace them at the time the receptacles were replaced. The plant operator is concerned that the audible alarms are not working and feels they need to be replaced asap as this is a requirement to alert someone that the lift stations are not functioning