



NONAERIAL COMMON FIREWORKS SALES / STORAGE APPLICATION

This information sheet will provide you with information on the steps you need to complete to sell permitted **NONAERIAL COMMON FIREWORKS** within the Middleton Rural Fire District and Star Fire Protection District.

If you are operating a stand within the city limits of Middleton or Star additional applications are required by each city. It is the responsibly of the Owner/Operator make contact with the city and complete all required applications prior to the deadline below.

Agency	Application Deadline	Codes
Middleton Rural Fire District (208) 585-6650 www.middletonfire.org	May 24, 2021 by 5:00 pm	Idaho Code Title 39 Chapter 26 International Fire Code 2018
City of Middleton (208) 585-3133 www.middleton.id.gov	May 24, 2021 by 5:00 pm	1-15-14: Fireworks Permit
Star Fire Protection District (208) 286-7772 www.starfirerescue.org	May 24, 2021 by 5:00 pm	Idaho Code Title 39 Chapter 26 International Fire Code 2018
City of Star (208) 286-7247 www.staridaho.org	May 24, 2021 by 5:00 pm	Chapter 6 – Fireworks

Fees must be paid in the form of check or money order in the amount of **\$50.00** payable to the Fire District having jurisdiction. The fee includes permit and initial inspection.

Inspection scheduling shall be coordinated through the Fire Code Official (208) 585-6650. Inspections may be performed Monday through Friday between 8am and 5pm.

All Temporary Firework Stands are subject to the approval of the Fire Code Official once they are set up. Stands must meet all of the criteria listed on the Inspection Form before a permit will be issued. The Fire Code Official will present the Owner/Operator with copies of the inspection and permits from the city in which the stand is operating.

All Permit must be posted conspicuously inside the stand during all hours of operation.

Compliance inspections may be performed at random times and without notice. Fire Code Official may or may not be in uniform and may or may not be utilizing an official vehicle. Stands found to be not in compliance will have their permit revoked on scene by the Inspector. Stands with revoked permits must immediately cease operations and sales. The Fire Code Official or his/her designee may re-issue the permit, at their discretion; after all unsatisfactory items are resolved.

No temporary fireworks stand used during the summer sales period shall be erected before June 15. The premises on which such temporary fireworks stand is erected shall be cleared of any and all temporary fireworks stands and debris not later than twelve o'clock (12:00) noon on July 12. No temporary fireworks stand used during the winter sales period shall be erected before December 15. The premises on which such temporary fireworks stand is erected shall be cleared of any and all temporary fireworks stands and debris not later than twelve o'clock (12:00) noon on January 8.

Nonaerial common fireworks, special fireworks, and fireworks may be sold at retail and used beginning at twelve o'clock (12:00) midnight June 23 an ending at twelve o'clock (12:00) midnight July 5, and beginning at twelve o'clock (12:00) midnight December 26 and ending at twelve o'clock (1200) midnight January 1 each year. The use of fireworks must also comply with the city noise ordinances.



NONAERIAL COMMON FIREWORKS SALES / STORAGE APPLICATION

Operator's Name:		Date of Birth:	
Address:		City:	Zip:
Phone/Mobile:		Email Address:	
Supplier:		Local Rep:	
Address:		City:	Zip:
Phone/Mobile:		Email Address:	
LOCATION			
Location:			
After-hours Storage Location:			
EMPLOYEE LIST			
Name:		Age:	Phone:
Name:		Age:	Phone:
Name:		Age:	Phone:
Name:		Age:	Phone:
Name:		Age:	Phone:
ADDITIONAL INFORMATION REQUIRED			
<input type="checkbox"/>	Bond and Certificate: Attach the bond or valid certificate of public liability and property-causality insurance providing coverage up to One Hundred Thousand Dollars (\$100,000) for personal injury and property damage proving coverage at each location.		
<input type="checkbox"/>	Site Map: Attach a detailed site map.		
<input type="checkbox"/>	Product List: Attach a products list to ensure compliance.		
<input type="checkbox"/>	Property Utilization: Attach a written letter of consent form the owner(s) of the property where the temporary tent will be set.		
<input type="checkbox"/>	Fee: Permit/Inspection Fee \$50.00		
APPLICATION ACKNOWLEDGMENT			
I verify that the above information supplied is true and correct and agree to follow the rules and regulations set forth by Fire District.			
Applicant Signature:		Date:	
FOR OFFICE USE ONLY			
Application & Plans Received: (Date/ By)		Reviewed by Fire Code Official	Authority Having Jurisdiction
Permit Fee \$ _____ <input type="checkbox"/> Paid Ck# _____		Notes:	
<input type="checkbox"/> Bond or Certificate of Insurance <input type="checkbox"/> Site Map <input type="checkbox"/> List of products from supplier	<input type="checkbox"/> Property Utilization <input type="checkbox"/> Information requested verified <input type="checkbox"/> Other: _____	Meets the following: <input type="checkbox"/> Idaho Code <input type="checkbox"/> NFPA <input type="checkbox"/> County/City Code	
This application form also serves as a Permit which shall be valid for twelve (12) months from the date of issuance and is nontransferable. This permit for is for the "Retail Sale of Non-Aerial Common Fireworks" herein issued shall be displayed in public view at the location listed above.		<input type="checkbox"/> Approved <input type="checkbox"/> Denied	
Fire Code Official:		Date:	Permit #



NONAERIAL COMMON FIREWORKS SALES / STORAGE APPLICATION

INSPECTION FOR THE SALE OF NON-AERIAL COMMON FIREWORKS & STORAGE

All fireworks sales and storage shall meet the requirements outlined below:

Location:		AHJ:	
Owner:		Operator:	
<input type="checkbox"/> Initial Inspection	<input type="checkbox"/> Follow-Up Inspection	<input type="checkbox"/> Other:	
Requirements for temporary fireworks sales stand:			
<input type="checkbox"/>	Must be at least 25 ft away from any other building or structure and from any generator or other internal combustion power sources and/or their fuels.		
<input type="checkbox"/>	The stand must be at least <i>25 feet</i> away from any other building or structure.		
<input type="checkbox"/>	The stand must be at least <i>100 feet</i> away from any fuel storage/dispensing station.		
<input type="checkbox"/>	No temporary fireworks stand shall have a floor area in excess of seven hundred (700) square feet.		
<input type="checkbox"/>	Stand must meet the 2018 International Fire Code requirements for temporary and permanent tents and membrane structures. (International Fire Code, Chapter 31, Section 3104 and all subsections)		
<input type="checkbox"/>	Any and all temporary fireworks stands shall have exit doors at least thirty inches (30") wide at both ends of the temporary fireworks stand and one additional door for each thirty-two feet (32') of rear wall in excess of thirty-two feet (32'). All doors shall open outward from the temporary fireworks stand and all doorways shall be kept clear and operational at all times. No operator shall cause or allow any exit from a temporary fireworks stand to be obstructed, unopenable, inaccessible, or malfunctioning.		
<input type="checkbox"/>	Each stand/tent shall be provided with a minimum of one (1) type 2A10BC rated fire extinguisher, and one (1) 2A water type fire extinguisher in good working order and with a current inspection tag in place dated within the last calendar year. Extinguishers must be hung three to four feet above the floor. Extinguishers must be readily visible and accessible at all times.		
<input type="checkbox"/>	At least one sign reading, "Fireworks - No Smoking Within 25 Feet" in letters at least four inches (4") high on a contrasting background shall be posted on each and every <u>exterior</u> wall and/or side of any and all temporary fireworks stands. Such signs shall be maintained in a legible condition at all times.		
<input type="checkbox"/>	At least one sign reading, "Fireworks - No Smoking Within 25 Feet" in letters at least two inches (2") high on a contrasting background shall be posted on each and every <u>interior</u> wall and/or side of any and all temporary fireworks stands. Such signs shall be maintained in a legible condition at all times.		
<input type="checkbox"/>	There shall be at least one supervisor twenty-one (21) years of age or older, during business hours. No person under sixteen (16) years of age shall work at or be in the non-public areas of the stand.		
<input type="checkbox"/>	No operator shall sell fireworks to any person who is under the age of sixteen (16) years unless such person is accompanied by a parent or legal guardian. The burden of verifying the age of purchasers of fireworks shall be borne by the operator.		
<input type="checkbox"/>	The stand <u>must</u> be attended during business hours. No person shall sleep at any time in any temporary fireworks stand.		
<input type="checkbox"/>	Waste receptacles or garbage cans in any temporary fireworks stand shall be noncombustible and shall have a securely fitting lid.		
<input type="checkbox"/>	Any and all temporary fireworks stands shall comply with all applicable provisions of this code, including, but not limited to, the unified development code, the building code, the fire code, and the electrical code. The operator shall obtain any and all required permits. No open flame-heating device may be used in a temporary fireworks stand/tent at any time.		



NONAERIAL COMMON FIREWORKS SALES / STORAGE APPLICATION

<input type="checkbox"/>	There shall be NO short-term storage within 25' of fireworks stand/tent. The storage container must be less than 320 square feet and be located at least 25' from any building or structure. Must have a 2A fire extinguisher located within 48" of the door and be at a height of three to four feet.
<input type="checkbox"/>	At least one sign reading, "No Fireworks To Be Discharged Within 100 Feet" in letters at least four inches (4") high on a contrasting background shall be posted on each and every exterior wall or side of any and all temporary fireworks stands. Such signs shall be maintained in a legible condition at all times.
<input type="checkbox"/>	Prior to erecting any temporary fireworks stand, and throughout the applicable sales period, the ground underlying such temporary fireworks stand and all ground within a thirty-foot (30') perimeter thereof shall be cleared and maintained clear of any and all weeds, combustible vegetation or material, and/or debris. No operator shall permit the accumulation of rubbish or trash in or around any temporary fireworks stand. No operator shall permit a fire nuisance or hazard to exist in or around any temporary fireworks stand.
<input type="checkbox"/>	All stands shall be 25' from any generator or internal combustion engine and vehicle parking.
<input type="checkbox"/>	All permits are required to be posted in the stand at all times.
<input type="checkbox"/>	Allowed to be erected (2) two temporary signs not to exceed 32 square feet each. The posting of these signs shall not obscure vehicles line of sight.
<input type="checkbox"/>	One additional sign may be erected and affixed to the stand. Sign not to exceed 32 square feet.
<input type="checkbox"/>	Any and all temporary fireworks stands shall be emptied of all fireworks when not open for business. This provision shall not apply where the operation is not open for business and the temporary fireworks stand is used as a short term storage facility
NOTES:	
<input type="checkbox"/>	The Temporary Stand listed in this document has passed the Fire & Life Safety Inspection for compliance. The Fire Code Officials signature signs off on the inspection and recommends to the City/County/State that permits and/or licenses be issued.
<input type="checkbox"/>	The Temporary Stand listed in this document has NOT passed the Fire & Life Safety Inspection for compliance. The Fire Code Officials signature recommends to the City/County/State that permits and/or licenses NOT be issued until all documented violations are corrected.
Fire Code Official: _____ Date of Inspection: _____	