INTEGRAL TWO-STAGE REGULATORS

EXCEID-FIO Quick Reference Guide

MEC

Innovation Made Simple

Free tech support call: 269 789 6700

LOAD BTU/HR.	DISTANCE maximum distance from regulator outlet to furthest appliance	PIPE TO APPLIANCE	MEC REGULATOR	MEC PIGTAILS
100,000	10 feet	1/2" CTS Iron Pipe or copper tubing @ 11" water column regulator set pressure		POL X POL Length Part. No. 3/8" tube OD 12" ME1680-12 1/4" tube OD 12" ME1664-12 3/8" tube OD 6" ME1680-06
	35 feet	5/8" copper tubing @ 11" water column regulator set pressure		3/8 (due OD 0 ME1080-00
	100 feet	3/4" IPS Iron pipe @ 11" water column regulator set pressure	MEGR-1232-HBF F. POL X 1/2" MEGR-1232-HFF F. POL X 3/4" MEGR-1232-BBF 1/4" X 1/2"	· ·
200,000	10 Feet	5/8" copper tubing @ 11" water column regulator set pressure		POL X POL Length Part. No. 3/8" tube OD 12" ME1680-12 1/4" tube OD 12" ME1664-12 3/8" tube OD 6" ME1680-06
	50 Feet	3/4" IPS Iron pipe @ 11" water column regulator set pressure	MEGR-1232-HBF F. POL X 1/2" MEGR-1232-HFF F. POL X 3/4" MEGR-1232-BBF 1/4" X 1/2"	100
300,000	30 Feet	3/4" IPS Iron pipe @ 11" water column regulator set pressure	MEGR-1232-HFF F. POL X 3/4" MEGR-1632-HCF F. POL X 1/2" MEGR-1632-BCF 1/4" X 1/2"	POL X POL Length Part. No. 3/8" tube OD 12" ME1680-12 1/4" tube OD 12" ME1664-12 3/8" tube OD 6" ME1680-06
	70 Feet	1" IPS Iron pipe @ 11" water column regulator set pressure		
400,000	20 Feet	3/4" IPS Iron pipe @ 11" water column regulator set pressure	MEGR-1232-HFF F. POL X 3/4" MEGR-1632-JFF F. POL X 3/4" MEGR-1632-CFF 1/4" X 3/4"	POL X POL Length Part. No. 3/8" tube OD 12" ME1680-12 1/4" tube OD 12" ME1664-12 3/8" tube OD 6" ME1680-06
	60 Feet	1" IPS Iron pipe @ 11" water column regulator set pressure		

Instructions:

- Determine the total gas demand for the system by adding up the
 BTU/hr input from the appliance nameplaces and adding demand as
 appropriate for future appliances.
- appropriate for future appliances.

 2. For second stage or integral twin stage piping.
- A Measure length of ping required from outlet of regulator to the appliance furthest away. No other length is necessary to do the sizing.

 B. Make a simple sketch of the pining as shown.

 C. Determine the capacity to be handled by each section of piping. For
- C. Determine the capacity to be handled by each section of piping. For example, the capacity of the line between a and b must handle the total demand of appliances A, B, and C; the capacity of the line from c to d must handle only appliance B, etc.
- must handle only appliance B, etc.

 D. Using one of the above Tables, select proper size of tubing or pipe for each section of piping, using values in BTU/lir for the length determined from step #2-A. If exact length is not on chart, use next longer length. Do not use any other length for this purpose! Simply select the size that shows at least as much capacity as needed for each origing regrit.
- piping section.

 3. For piping between first and second stage regulators
- A For a simple system with only one second stage regulator, merely measure length of piping required between outlet of first stage regulator and inlet of second stage regulator. Select piping or tubing required from one of the Tables.
- B. For systems with multiple second stage regulators, measure length of piping required to reach the second stage regulator that is furthest away. Make a simple sketch, and size each leg of piping using Table 1, 2, or 3 using values shown in column corresponding to the length as measured above, same as when handling second stage piping.

