



SECURITY FIRE PROTECTION DISTRICT

FLOW TEST REQUIREMENT

Flow test must be done before any building material is brought on site

- Provide ***“ON SITE” FIRE FLOW TESTS RESULTS*** – The District will verify these calculations. Any and all fire flow tests must be witnessed by the District. We will not accept a fire flow calculation if a representative of the District has not witnessed the testing. Contact us at 719-392-3271 to schedule a representative to witness flow tests, allow a minimum of 72 hours notice for any appointment. **ATTENTION: Fire flow tests older than one year will not be utilized. ATTENTION: FEES ASSOCIATED WITH OBTAINING FIRE FLOW TESTS ARE THE RESPONSIBILITY OF THE GENERAL CONTRACTORS AND/OR SITE DEVELOPERS.**

Remember, 1,500 gallons per minute (GPM) @ 20 pounds per square inch (PSI) are the MINIMUM flows and pressures the District allows for both residential and commercial sites.

As a part of the final inspection for occupancy, “ON SITE” FIRE FLOWS may be required to insure compliance with International Fire Code (IFC) fire flow requirements.

- ***RESIDENTIAL WATER PLAN SUBMITTALS:*** All water plan submittals shall have the gross square footage of the homes clearly indicated on plan submittals. The “ON SITE” fire flows will be utilized to determine the MAXIMUM SIZE of the residential structures that will be permitted at any given site. On the submitted plans, the maximum size homes are to be indicated, and the fire flows shall be adequate to allow the size of homes being proposed. These plans will be kept on file for our future review, and no home larger than those approved will be permitted to be constructed. Utilizing Appendix B & C of the IFC.