

*****ADDENDUM #1*****
PARK DIRECTIVE
FIRE POLICY FOR ALL OPEN FIRES
PRINCE ALBERT NATIONAL PARK OF CANADA

5. Additional Information Required and Conditions for the Issuance of a Fire Permit When Appliance is Located on a DECK:

- a. Fuel burning appliances located on exterior wood decks will conform to the following guidelines:
- deck will be covered with a durable noncombustible pad under the appliance with a minimum of 450 mm (18 in) clearance on all sides;
 - pad will be a minimum of 50 mm (2 in) thick;
 - appliances shall have a minimum clearance of 1.8 m (6 ft) from any combustible material, ie: deck railings, combustible siding and propane fuelled appliances.

Prince Albert National Park of Canada reserves the right to revoke or temporarily suspend this permit should the outlined conditions previously met are altered after issuance of the fire permit for public safety reasons, ie. Fire ban issued by the Superintendent.

Date the 14 Day of JUNE, 2004



Rod Blair
Superintendent