

SMOKE DETECTOR AND CARBON MONOXIDE DETECTOR PLACEMENT INFORMATION

Smoke Alarms shall be installed in the following locations:

- In each sleeping room.
- Outside each sleeping area in the immediate vicinity of the bedrooms.
- On each additional story of the dwelling, including basements but not including crawl spaces and uninhabitable attics

For more information on smoke alarms go to:

www.fire.ca.gov/communications/communications_firesafety_smokealarms

Carbon Monoxide Alarms shall be installed in the following locations:

- Outside of each separate dwelling unit sleeping area in the immediate vicinity of the bedroom(s).
- On every level of a dwelling unit including basements.
- Where a fuel-burning appliance is located within a bedroom or its attached bathroom, a carbon monoxide alarm shall be installed within the bedroom.

For more information on carbon monoxide alarms go to:

www.fire.ca.gov/communications/communications_firesafety_carbonmonoxide