



# Lathrop-Manteca Fire Protection District

800 East 'J' Street, Lathrop, California 95330  
• (209) 941-5100 • Fax (209) 941-5115 • [www.lmfire.org](http://www.lmfire.org) •

## LARGE FAMILY DAYCARE CHECKLIST

*14 or fewer children, less than 24 hours per day, including children under age 10*

- Address posted and visible from the street.
- Smoke detectors in every bedroom, and all common use areas.
- Fire extinguisher (serviced within last year) shall be mounted where readily available.
- Fire alarm with sounding device.
- Exits (2) required.
- Locks on exit doors (no knowledge).
- Solid Core, self-closing door on garage.
- Garage – One hour separation required.
- Emergency numbers posted near telephone.
- Evacuation plan posted at both exits.
- Fire drill monthly record kept on file for inspector to view.
- Gas heaters/furnaces – protected.
- Fireplaces, wood stoves, open faced heaters – shall be screened.
- Storage of flammables – shall be stored in garage/outside location.
- Fire department permit posted.
- Assistant for children.
- 5' or fence around swimming pools.
- Side gates must have single operation hardware, no locks while children are under care
- Additional corrections may be required at time of inspection
- Provide / request Community Care Licensing 850 Form (if applicable)