



# PITMAN FIRE DEPARTMENT

BUREAU OF FIRE SAFETY

## APPLICATION FOR SELF CERTIFICATION OF SMOKE ALARMS, CARBON MONOXIDE ALARM AND FIRE EXTINGUISHER COMPLIANCE DURING A NATIONAL EMERGENCY

Dwelling Location: Block: \_\_\_\_\_ Lot: \_\_\_\_\_  
(not mailing address)  
Street: \_\_\_\_\_  
Municipality: \_\_\_\_\_ County: \_\_\_\_\_

\*NOTE: ALL BOXES MUST BE CHECKD IN ORDER FOR CERTIFICATION TO BE VALID

- Smoke detector on each level of the dwelling, including basements, excluding attic or crawl space; and
- Smoke detector and carbon monoxide alarm outside each separate sleeping area; and within 10 feet of bedrooms
- All smoke detectors are in working order.  Carbon monoxide alarm(s) in working order
- Fire extinguisher is the correct size, is properly mounted, and is located within 10 feet of the kitchen

This is a \_\_\_\_\_ story dwelling  with  without a basement.

An inspection shall be conducted by the owner or an authorized representative of the owner. The smoke detectors required above shall be located in accordance with NFIPA 74; the carbon monoxide alarm(s) installed per NFPA-720. The detectors are not required to be interconnected. Battery powered detectors and alarms are acceptable. Note: AC powered and/or interconnected alarms and smoke detectors installed in homes constructed after January, 1977 shall be maintained in working order. The fire extinguisher is installed per P.L. 2005, c.71 (N.J.S.A. 52:27D-198.1 et seq). See diagrams on the back of this application for further information regarding installation.

Please mail certificate to: \_\_\_\_\_ Phone #: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
Fax #: \_\_\_\_\_  
\_\_\_\_\_  
Zip: \_\_\_\_\_

Contact person: \_\_\_\_\_ Phone #: \_\_\_\_\_ Closing Date: \_\_\_\_\_

I do hereby certify that the foregoing statements made by me are true. I am aware that if any of the foregoing statements made by me are willfully false, I will be subject to penalty.

Sworn and subscribed to before me this \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_\_.

*Not Needed*

Notary Signature

Applicant Signature

Printed Name

**Uniform Fire Code of New Jersey Certification Criteria  
One & Two Family Homes**

<b>Homes Built Prior to 1977</b>	<b>Homes Built After 1977</b>	<b>Newer Homes – 1990’s and newer</b>
<p align="center"><b>Smoke Alarms</b></p> <ul style="list-style-type: none"> <li>• 10 Year Sealed Battery Type</li> <li>• One on each floor level</li> <li>• Within 10’ of bedrooms</li> </ul>	<p align="center"><b>Smoke Alarms</b></p> <ul style="list-style-type: none"> <li>• Hardwired Electric</li> <li>• Interconnected</li> <li>• One on each floor level</li> <li>• Within 10’ of bedrooms</li> </ul>	<p align="center"><b>Smoke Alarms</b></p> <ul style="list-style-type: none"> <li>• Hardwired Electric</li> <li>• Battery Backup</li> <li>• Interconnected</li> <li>• One on each floor level</li> <li>• In each bedroom</li> </ul>
<p align="center"><b>Carbon Monoxide Alarms</b></p> <ul style="list-style-type: none"> <li>• Within 10’ of sleeping areas</li> </ul>	<p align="center"><b>Carbon Monoxide Alarms</b></p> <ul style="list-style-type: none"> <li>• Within 10’ of sleeping areas</li> </ul>	<p align="center"><b>Carbon Monoxide Alarms</b></p> <ul style="list-style-type: none"> <li>• Within 10’ of sleeping areas</li> </ul>
<p align="center"><b>Fire Extinguisher</b></p> <ul style="list-style-type: none"> <li>• 2A:10B:C Type</li> <li>• Mounted using manufacturer hanger or brackets</li> <li>• Visible and easily accessible location within 10’ of kitchen</li> <li>• Inspected and tagged within the last year OR must have store receipt for purchase within the last 12 months.</li> </ul>	<p align="center"><b>Fire Extinguisher</b></p> <ul style="list-style-type: none"> <li>• 2A:10B:C Type</li> <li>• Mounted using manufacturer hanger or brackets</li> <li>• Visible and easily accessible location within 10’ of kitchen</li> <li>• Inspected and tagged within the last year OR must have store receipt for purchase within the last 12 months.</li> </ul>	<p align="center"><b>Fire Extinguisher</b></p> <ul style="list-style-type: none"> <li>• 2A:10B:C Type</li> <li>• Mounted using manufacturer hanger or brackets</li> <li>• Visible and easily accessible location within 10’ of kitchen</li> <li>• Inspected and tagged within the last year OR must have store receipt for purchase within the last 12 months.</li> </ul>



## RECALL 14-275

DATE: 09/11/2014

Kidde hard-wired smoke and combination smoke/carbon monoxide (CO) alarms

### HAZARD:

The alarms could fail to alert consumers of a fire or a CO incident following a power outage.

### DESCRIPTION:

This recall involves Kidde residential smoke alarm model i12010S with manufacture dates between December 18, 2013 and May 13, 2014, combination smoke/CO alarm i12010SCO with manufacture dates between December 30, 2013 and May 13, 2014, and combination smoke/CO alarm model KN-COSM-IBA with manufacture date between October 22, 2013 and May 13, 2014. They are hard-wired into a home's electric power. The i12010S and i12010SCO come with sealed 10 year batteries inside. The KN-COSM-IBA model has a compartment on the front for installation of replaceable AA backup batteries. The alarms are white, round and measure about 5 to 6 inches in diameter. Kidde is engraved on the front of the alarm. Kidde, the model number and manufacture dates are printed on a label on the back of the alarm. "Always On" is also engraved on the front of alarms with sealed 10-year batteries.

### MODELS:

Smoke # **i12010S** mfg between: 12/18/2013 and 5/13/2014

Combination Smoke/CO # **i12010SCO** mfg between: 12/30/2013 and 5/13/2014

Combination Smoke/CO # **KN-COSM-IBA** mfg between: 10/22/2013 and 5/13/2014



# RECALL 17-031

DATE: 11/10/2016

Kidde NightHawk combination smoke/carbon monoxide (CO) alarms

## HAZARD:

The alarm can fail to continue to chirp when it reaches its seven-year end of life if the batteries are replaced, leading consumers to believe it is still working. This poses a risk of consumers not being alerted to a fire or CO incident in their home.

## DESCRIPTION:

This recall involves Kidde NightHawk talking combo smoke/CO alarm with model number KN-COSM-IB and manufacture dates between June 1, 2004 and December 31, 2010. The alarms are hard-wired into a home's electric power. The unit has a compartment on the back for the installation of a replaceable 9V backup battery. The alarm is white, round and measures about 5 to 6 inches in diameter. "Kidde" is engraved on the front of the alarm. "Kidde," the model number and manufacture dates are printed on a label on the back on the alarm.

## MODELS:

NightHawk talking Smoke/CO # KN-COSM-IB mfg between 7/1/2004 and 12/31/201

