

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**  
**Monitoring Reporting Requirements Not Met For**  
**Paw Paw Route 19 PSD    WV3302518**

Our water system violated drinking water monitoring requirements. Even though these were not emergencies, you, as our customers, have a right to know what happened and what we did to correct the situation.

*We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During periods listed in the table below, we did not monitor or test as required and therefore cannot be sure of the quality of our drinking water during that time.*

**What should I do?** At this time, there is nothing you need to do.

The table below lists the monitoring we did not conduct, other violations, and the associated compliance period.

Monitoring Violation	Year-Fed Report #	Monitoring Frequency	Compliance Period
27 – MONITORING (DBP), ROUTINE MAJOR, HAA5 Failure To Monitor For Haloacetic Acids (HAA5's)	2023    12398	Quarterly	3QT 2022
27 – MONITORING (DBP), ROUTINE MAJOR, TTHM Failure To Monitor For Trihalomethanes (TTHM's)	2023    12377	Quarterly	3QT 2022

What Happened? What is being done? (Describe corrective action).

A miscommunication occurred between the Chief Operator during the 3rd quarter of 2022 and the Operator-In-Training at that time. Each thought the other one was performing the quarterly water sample to test for HAA5/TTHM for that quarter. This oversight was not discovered until after the end of the month for that quarterly reporting period, therefore a violation was received for non-submission. The board addressed the problem with the staff involved and made a plan that clearly identified who would be responsible for performing these tests in the future per schedule required. The issue has now been resolved and all sample/tests have been performed per schedule and met the current EPA quality guidelines.

For more information, please contact: Office Staff at 304-278-8029 (T,W,Th 9am-2pm)  
(Contact Name) (Phone Number)  
or: Paw Paw Rt. 19 PSD, P.O. Box 2035, Westover, WV 26502  
(Mailing Address)

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail*

Date Prepared: August 24, 2023

Date Distributed: 9/20/2023 (website)  
9/20/2023 (bulletin board @  
Arnettville Community Center,  
4120 Fairmont Road)  
9/26/2023 (customer billcard note)