

Cyanide - heavy metals - Plating Company - Covina, CA

Analyte	EPA Method	Detection Limit	Raw Water mg/l	Post EC Filtered mg/l	% Removal
Total Cyanide	335.2	0.02	742	91	88%
Free Cyanide	335.1	0.02	723	0.02	99+%
Cadmium	200.7	0.02	95	0.04	99+%
Chromium	200.7	0.02	3.18	0.26	92%
Nickel*	200.7	0.02	327	216	34%
Zinc	200.7	0.02	125	0.07	99+%

*Chelated nickle will need other pre-treatment

