



Home Office - 1717 East Erwin Street

Tyler, Texas 75702-6398

Office: (903) 595-4421 Lab: (903) 595-6402 Fax: (903) 595-6113

Area Offices

210 Beech Street	Texarkana, AR 71854	(870) 772-0013
707 West Cotton St.	Longview, TX 75604	(903) 758-0402
2000E Randol Mill Rd. Ste 613	Arlington, TX 76011	(817) 962-0048
8403 Cross Park Dr. Ste D-3	Austin, TX 78754	(512)-519-9312

Acct ID: WESTHENLY

Proj. No.: C7229169

Date Sampled: 10/31/2017

Report Date: 11/01/2017

Sampled By: Sutherland, Tyler

Project: West Henly Materials

By Order Of: Jason Wheeler

Location:

Order Number:

Client: West Henly Materials

Contractor:

REPORT: **Earthwork Observation**

LAB NO: 2104

Test Method: See Below

TEST RESULTS

Report No: 2104

Page 1 of 2

S e e a t t a c h e d r e p o r t f o r d e t a i l s .

Respectfully Submitted,
ETTL Engineers & Consultants, Inc.

Chris Taylor, SET



Austin - 8403 Crosspark Drive Ste 3D · Austin, Texas 78754

Ph. 512-519-9312

Corporate - 1717 E. Erwin Street · Tyler, Texas 75702

Ph. 903-595-4421

Project NO: C7229-169
 Client: West Henly Materials
 Date: 10/31/2017
 Report NO: 2104
 Project Name: West Henly Materials Stockpile Testing
 Description: Manufactured 1" Pipe Bedding
 Source: West Henly Materials
 Test Method as applicable: ASTM C117, C136, D1140

Location: 1" Pipe Bedding Stockpile

Aggregate Gradation

Sieve Size	Individual Weight Retained	Percent Retained	Percent Passing
1 1/4"	0	0.0%	100.0%
1"	973.3	10.1%	89.9%
7/8"	2013.7	31.1%	68.9%
3/4"	5925.7	71.9%	28.1%
1/2"	2297.8	95.9%	4.1%
#4	87.7	96.8%	3.2%
#8	9.2	96.9%	3.1%

Chris Taylor S.E.T

THIS REPORT APPLIES ONLY TO THE STANDARDS OR PROCEDURES INDICATED AND TO THE SAMPLE(S) TESTED AND/OR OBSERVED AND ARE NOT NECESSARILY INDICATIVE OF THE QUALITIES OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS OR PROCEDURES, NOR DO THEY REPRESENT AN ONGOING QUALITY ASSURANCE PROGRAM UNLESS SO NOTED. THESE REPORTS ARE FOR THE EXCLUSIVE USE OF THE ADDRESSED CLIENT AND ARE NOT TO BE REPRODUCED WITHOUT WRITTEN PERMISSION.

Tyler * Austin * Longview * Texarkana * Arlington