

From: Marj.Garbini@pepcoholdings.com [mailto:Marj.Garbini@pepcoholdings.com]
Sent: Monday, June 10, 2013 12:56 PM
To: Helm, M. Gary
Subject: EIPC Gas-Electric System Interface Study Scope of Work

Gary,

Some concerns I have that I don't see addressed in this document...

The gen size cut-off in 4.1 will exclude many black start units. I am concerned that in a system restoration/ black out scenario we are overly dependent on natural gas as a black start unit fuel.

Is there some regulation that requires the generation owners and operators to release details of their gas supply contracts for this study?

Marjorie Garbini
Senior Supervising Engineer
OP&A, System Operations
PHI - NCRO
OP&A, Electric System Operations
office 302-454-4078
cell 302-530-6281
email marj.garbini@pepcoholdings.com

----- Forwarded by Marjorie Garbini/CP/PEP on 06/10/2013 10:54 AM -----

From: Janell Fabiano <fabial@pjm.com>
To: PJM-MRC@LISTSERV.PJM.COM,
Date: 06/10/2013 10:42 AM
Subject: [PJM-MRC]
Sent by: Markets and Reliability Committee <PJM-MRC@LISTSERV.PJM.COM>