

## 10-9-15 Missouri Wastewater Lagoon Effluent

110V/2.5 A

██████ MO

mg/l

	<b>Phosphorous -</b>	<b>Raw</b>	<b>EC-60 sec</b>	<b>EC-30 sec</b>	<b>EC-15sec</b>
Al Blades		1.65	0.02	0.02	0.06
Fe Blades		1.65	0.04	0.06	0.05
<b>Al</b>	<b>Fecal -</b>	200/100ml		<10/100ml	
<b>Al</b>	<b>Ecoli -</b>	100/100ml		<10/100ml	

	<b>60 sec</b>	<b>Raw</b>	<b>EC treated pre-filter</b>	<b>EC post 11 micron filter</b>
<b>Al</b>	<b>NTU</b>	91.1 ntu	8.78 ntu	2.36

Split Chamber 100 V/15 A

██████ MO

Ammonia Reduction (Struvite Formation)

<b>Al</b>	<b>Ammonia</b>	<b>Raw</b>	<b>60 sec</b>
		23.6 mg/l	ND <0.06 mg/l