

THE CITY OF NEW YORK  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF SEWERS

BOROUGH OF S-I

CERTIFICATE OF INSPECTION - NEW SEWER HOUSE CONNECTION

The below described sewer house connection has been laid from the property line to the existing sewer at premises:

N.B.# 152083 Block 2070 Lot 65

Under Permit Number 21442 Issued 5/18, 1984

Premises 35 ETON PL.  
house number and street

Located \_\_\_\_\_ side, \_\_\_\_\_ feet \_\_\_\_\_ of \_\_\_\_\_

Owner 893 CONST CORP.

Plumber ANTHONY B. BOCKVILLE

Size and type of pipe laid 6" C.I.

Connected to 10" SAN Sewer laid in  
size, type  
ETON PL.  
street/avenue

I hereby certify that I made the inspection of the Sewer House Connection described above and that all work done under this permit has been properly completed in accordance with existing ordinances, rules and regulations.

name B. PAPPASO  
Inspector-Division of Sewer Construction

signed B. Pappas date: 5/23/84

noted Paul A. Kumbarger date: 6/5/84  
Acting Engineer In Charge


PENALTY FOR FALSIFICATION:

Falsification of any statement made herein is an offense punishable by a fine or imprisonment or both (N. Y. C. Administrative Code, Section 1151-9.0)

copies to: \_\_\_\_\_ Borough Superintendent, Department of Buildings  
\_\_\_\_\_ Borough Office, Bureau of Water Register  
\_\_\_\_\_ Sewer Regulation and Control Section  
File original in Borough Office, Sewer Regulation & Control

35	St. M. St.	2070	65
house number	street name	block	lot

1. Was connection extended from curb connection?  yes,  no
2. Was the connection placed on earth, stone or crushed rock, concrete cradle, concrete encasement or reinforced concrete encasement? (circle one)
3. Was connection made to existing spur or riser or cut in? (circle one)
4. If connection was "cut in", was saddle or dutchman used? (if so, circle)
5. Length, size and material of new connection 30' 6" cut.
6. Depth of connection at curb line is 4 feet.
7. All work was exposed and inspected.



date 5/23/61 signed R. F. [Signature]  
 Inspector-Division of Sewer Construction