



P.O. Box 954 Cullowhee, NC 28723  
 2675 Skyland Drive Sylva, NC 28779  
 Phone (828) 586-5588 (800) 213-4035  
 FAX (828) 586-0800  
 E-mail environmentalinc@aol.com

## Certificate of Analysis

Client Name: Tater Knob POA  
 Address: P.O Box 354  
 Glenville, NC 28736

Collection Date: 6/5/2024  
 Date Received: 6/5/2024

### RESULTS

**Sample Identification:** Tater Knob POA (North Tank) – XS1224 (grab)

Parameters	Result	MDL	Units	Date Analyzed	Method	Foot-notes
Residual Chlorine	0.4	0.2	mg/L	6/5/2024	SM 4500 Cl G	*
Total Coliform	Absent	-----	Present/Absent	6/5/2024	Colitag	
Fecal Coliform	Absent	-----	Present/Absent	6/5/2024	Colitag	

\* Analysis performed beyond recommended 15-minute hold time.

Anthony Tirona  
 Anthony Tirona, Laboratory Supervisor

6/6/24  
 Date



P.O. Box 954 Cullowhee, NC 28723  
 2675 Skyland Drive Sylva, NC 28779  
 Phone (828) 586-5588  
 Fax (828) 586-0800

Client: Tater Knob POA  
 Address: P.O Box 354  
 Glenville, NC 28736  
 Phone: (407) 619-8255  
 Other: [StevePR00@gmail.com](mailto:StevePR00@gmail.com)

Well Water Scan

Tater Knob POA (North Tank) - XS1224 (grab)

Contaminant	Results	Acceptable Range	Comments
total coliform	negative	negative	bacteria naturally present in the environment
E.coli	negative	negative	bacteria from fecal matter
residual chlorine	0.4	0.2-2.0	minimum chlorine residual recommended for disinfection

Collection Date & Time: 6/5/2024 @ 9:40 a.m. By: Steve Price