

# Laboratory Report

ORELAP Accreditation Number: OR 100014

Amy Clouse

Grandma's Place - Clark Family Center

2740 SE Powell Blvd

Portland OR 97202



Lab ID	Collection Date / Time	Sample Location	Sample Type	Lead (ppb)
BC13042	9/14/2018 5:30:00 AM	Infant	Initial First-draw	1.09
BC13043	9/14/2018 5:30:00 AM	Mobile Infant	Initial First-draw	2.19
BC13044	9/14/2018 5:30:00 AM	Wob	Initial First-draw	3.88
BC13045	9/14/2018 5:30:00 AM	Young Pre	Initial First-draw	0.56
BC13046	9/14/2018 5:30:00 AM	Pre K	Initial First-draw	0.74
BC13047	9/14/2018 5:30:00 AM	Kitchen Food Prep	Initial First-draw	2.98

ppb = parts per billion

Sample Types:

First-draw = Sample collected after an 8 to 18 hour stagnation period

Flowing = Sample collected after running water for 30 seconds



Amanda Fritz, Commissioner  
Michael Stuhr, P.E., Administrator



1120 SW 5<sup>th</sup> Avenue  
Portland, Oregon 97204-1926  
Information: 503-823-7404  
[www.portlandoregon.gov/water](http://www.portlandoregon.gov/water)

Dear childcare provider:

Attached you will find the results for the lead-in-water samples that you collected at your childcare facility. These samples were analyzed at the Portland Water Bureau Laboratory - an ORELAP accredited lab for the analysis of lead in water.

The sample kit sent to you follows the Environmental Protection Agencies guidance document *3Ts for the Reduction of Lead in Drinking Water Schools (2016)* and meets the testing requirements of the Oregon Department of Education Early Learning Division.

Please be aware that the Early Learning Division requires that providers immediately stop using any fixture for consumption that tests at or above 15 parts per billion (ppb) and that an alternative water source be provided. Childcare providers that have fixtures that test at or above 15.0 ppb are then required to work with the Division to develop and implement a response plan within sixty days of receiving these results.

Regardless of the level of lead in water, the Early Learning Division requires childcare providers to share these results with all parents and guardians within **one business day** and submit these results to the Office of Childcare within **10 days**.

Please contact the Early Learning Division at 503-947-5908 or [ELD.lead@state.or.us](mailto:ELD.lead@state.or.us) with any question regarding childcare lead testing requirements. More information can also be found at [www.oregonearlylearning.com/lead-poisoning-prevention](http://www.oregonearlylearning.com/lead-poisoning-prevention).

Sincerely,

The Portland Water Bureau,

Facilities Water Quality Team

Please contact us for translation or interpretation, or for accommodations for people with disabilities.

Más información · Дополнительная информация · Thêm thông tin · 欲了解更多信息 · Mai multe informații · Macluumaad dheeri ah · Подробици · Tichikin Poraus · अधिक सूचना  
[www.portlandoregon.gov/water/access](http://www.portlandoregon.gov/water/access) 503.823.1870 / TTY 503.823.6868