

College View Community Association

Water Quality Report - 2019

This year, as in the years past, your tap water met all US Environmental Protection Agency and Illinois Environmental Protection Agency drinking water health standards. Our system safeguards its groundwater & well water supply and we are pleased to report that the community had **No Violations** of any contaminant level or of any other water quality standard in the previous year. This report summarizes the quality of water that we provided last year, including details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. College View Community Association provides you with this information because informed residents and neighbors are our best allies.

If you have any questions about this report or concerns about your water system please contact Carl Groth, President of College View Community Association at 1-815-838-9025. If you would like to learn more, you are welcome to attend any of our regularly scheduled meetings at the Miller Field House in College View Park on the third Tuesday of every month at 6:30 pm.

The College View subdivision is in Lockport Township, in the county of Will, state of Illinois, located one half mile from Rt. 53, north of Airport Road, and is supplied with water by community wells owned and operated by the College View Community Association, a not for profit organization. The water system consists of four shallow wells, three storage tanks, 9000 feet of water main, valves, and other related and necessary equipment needed for treatment, all located within our community. This system provides an adequate supply of water for the 190 homes in the community. In accordance with IEPA regulations, daily water samples are taken and measured for proper content of chlorine and fluoride. The association is responsible for maintenance of water mains and lines up to, but **Not** including the buffalo box, service line, and shut-off valve. **It is the responsibility of the homeowner to provide a service line shut-off valve that is operational and above ground level, so that in case of an emergency it may be turned off for repairs.**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, persons with HIV/AIDS, or other immune system disorders, some elderly, and infants can be particularly at risk for infections. These people should seek advice about drinking water from their healthcare providers. US EPA/CDC guidelines on appropriate means to lessen the risk of infections by cryptosporidium, and other microbiological contaminants are available from the US EPA Safe Drinking Water Hotline @ 1-800-426-4791.

If present, elevated levels of lead can cause serious health issues, especially for pregnant woman and children. Lead in drinking water is primarily from materials in components in home plumbing. We cannot control the materials used in your home plumbing. **There are no lead water mains or service lines in our community.** When your water has been unused for several hours you can minimize the potential for lead exposure by flushing your tap for a couple of minutes before using it for drinking or cooking. If you are concerned about lead in your water you may wish to have it tested. For more information, you can call the US

EPA Safe Drinking Water Hotline @ 1-800-426-4791 or on-line internet @ <http://www.epa.gov/safewater/lead>.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and its potential health effects can be obtained by calling the US EPA Safe Drinking Water Hotline @ 1-800-426-4791.

The sources of drinking water (both tap water and bottled water), include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it can dissolve naturally occurring minerals and radioactive materials, and can pick up substances resulting from the presence of animals or from human activities. Possible contaminants consist of:

- Microbiological contaminants - such as viruses and bacteria, which may come from sewerage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants- such as salts and metals, which can be naturally occurring or can result from urban storm water runoff, industrial or domestic waste water discharges, oil or gas production, mining, or farming.
- Pesticides/Herbicides- which may come from a variety of sources such as agricultural, urban storm water runoff, and residential uses.
- Organic contaminants- including synthetic volatile organic chemicals which are by-products of industrial processes and petroleum production, they can also come from gas stations, urban storm water runoff and septic systems.
- Radioactive contaminants- which may be naturally occurring or be the result of oil and gas production or mining activities.

In order to ensure that tap water is safe to drink, the US EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits in bottled water, which must provide the same protection for public health. In addition to the informational section of the water quality report, we have included for your review several tables. The tables will give you a better picture of contaminants that were tested but not detected. Note: There is no maximum contaminant level for sodium but monitoring is required for information to consumers and health agents.

Thank you,

Carl Groth

President, College View Community Association



## 2019 Regulated Contaminants Detected

### LEAD AND COPPER

#### Definitions:

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.  
**Action Level Goal (AGL):** The level of a contaminant in drinking water below which there is no known or expected risk to health. AGL's allow for a margin of safety.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90 <sup>th</sup> Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2019	1.3	1.3	0.16	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2019	0	15	1.4	0	ppb	N	Corrosion of household plumbing systems. Erosion of natural deposits.

### WATER QUALITY TEST RESULTS

The state requires monitoring of certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Therefore, some of this data may be more than one year old.

**Definitions:** The following tables contain scientific terms and measures, some of which may require explanation.

- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the Maximum Contaminant Level Goal as feasible using the best available treatment technology.
- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.
- **mg/l:** Milligrams per liter or parts per million (ppm) – or one ounce in 7,350 gallons of water.
- **ug/l:** Micrograms per liter or parts per billion (ppb) – or one ounce in 7,350,000 gallons of water.
- **Avg:** Regulatory compliance with some MCL's are based on running annual average of monthly samples.
- **Maximum Residual Disinfectant Level (MRDL):** The highest level of disinfectant allowed in drinking water.
- **Maximum Residual Disinfectant Level Goal (MRDLG):** The level of disinfectant in drinking water below which there is no known or expected risk to health. MRDLG's allow for a margin of safety.

## Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2019	0.4	0.4 – 0.4	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Total Trihalomethanes (TTHm)	2019	8	7.56 – 7.56	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Haloacetic Acids (HAA5)	2019	2	2.07 – 2.07	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	2018	1.4	1.4-1.4	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	2018	0.03	0.03-0.03	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2018	1.04	1.04 – 1.04	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Iron	2018	0.025	0.025 – 0.025		1.0	ppm	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.
Manganese	2018	6.7	6.7 – 6.7	150	150	ppb	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.
Nitrate (Measured as Nitrogen)	2019	0.42	0.06– 0.42	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks; sewage; Erosion of natural deposits.
Selenium	2018	2.1	0 – 2.1	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.
Sodium	2018	15	15 – 15			ppm	N	Erosion from naturally occurring deposits; Used in water softener regeneration
Zinc	2018	0.037	0.037 – 0.037	5	5	ppm	N	This contaminant is not currently regulated by USEPA. However, the state regulates. Naturally occurring discharge from metal.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	2018	0.99	0.99 – 0.99	0	5	pCi/L	N	Erosion of natural deposits
Gross Alpha excluding Radon and Uranium	2015	2.47	2.03 – 2.47	0	15	pCi/L	N	Erosion of natural deposits