



CHILD CARE CENTER INSPECTION REPORT

Establishment Information	
Facility Name Ms. Cindy's Daycare	Facility Type Family Day Care
Licensee Name Cindy Stonebraker	Facility Telephone # 304
Facility Address 330 Discovery Rd Martinsburg, WV	Licensee Address ,

Establishment Details	
Adult to Child Ratio	

Inspection Information		
Inspection Type Follow up	Inspection Date 02/03/2017	Total Time Spent 0.27

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
Total # 0
Repeated # 0

Corrected Hazards
The following hazard(s) have been corrected since the last inspection.
Total # 0

Inspection Outcome
Facility will be re-evaluated at the next routine inspection.

Comments
Re-inspection to assess if chlorinator is operating properly. Chlorine residual of 3.0-3.5ppm. Re-inspection fee of \$50 given for checking chlorinator.

Disclaimer

Person in Charge

Jeff Stonebraker

Sanitarian

Robert RAD Deener