

**West Virginia Department of Health &
Human Resources
Berkeley County Health Department**

No image found with name:
Berkeley.png. Image files
needed to be generated.

FOOD ESTABLISHMENT INSPECTION REPORT

Establishment Information		
Facility Name Hedgesville Middle School	Facility Type Food Service Establishment	
Licensee Name Berkeley Co. Board of Education	Facility Telephone # 304 754-3313	
Facility Address 334 School House Drive Hedgesville, WV	Licensee Address ,	
Inspection Information		
Inspection Type Routine	Inspection Date 11/28/2018	Total Time Spent 1.27

Equipment Temperatures	
Description	Temperature (Fahrenheit)
Walk in cooler	38
Victory cooler	40
Milk cooler 2-right	40
Juice cooler	40
Hot box 1 (beside silverware)	140
Metro	138
Hoshizaki refrig(grab-n-go)	38
milk center	40

Warewashing Info					
Machine Name	Sanitization Method	Thermo Label	PPM	Sanitizer Name	Sanitizer Type
bucketDishmachine	chemheat	160	300	Quatheat	

OPERATOR - Violations cited in this report shall be corrected within the time frames specified below, but within a period not to exceed 10 calendar days for critical items (§ 8-405.11) or 90 days for non-critical items (§ 8-406.11).

Observed Critical Violations
Total # 0
Repeated # 1

Observed Non-Critical Violations

Total # 5

Repeated # 1

4-501.11 - GOOD REPAIR, PROPER ADJUSTMENT, AND OPERATION

OBSERVATION: (CORRECTED DURING INSPECTION): Black roller cart needs replaced/repared (top cracked)

6-501.11 - PHYSICAL FACILITIES - GOOD REPAIR

OBSERVATION: Hole in ceiling above dishmachine needs repaired (tape not approved) Not easily cleanable.

6-501.11 - PHYSICAL FACILITIES - GOOD REPAIR

REPEAT OBSERVATION Cracked floor tiles needs replaced

6-501.12 - CLEANING, FREQUENCY AND RESTRICTIONS

OBSERVATION: (CORRECTED DURING INSPECTION): Vent above washing machine needs cleaned.

6-501.16 - DRYING MOPS


OBSERVATION: Mops need to air dry (clips broken)

Inspection Outcome

Comments

Disclaimer

Person in Charge



Crystal Markely

Sanitarian



Keith Allison