

West Virginia Department of Health & Human Resources

Berkeley County Health Department



Public Health
Prevent. Promote. Protect.

GENERAL SANITATION INSPECTION REPORT

Establishment Information		
Facility Name Hampton Inn-Foxcroft	Facility Type Motel/Hotel	
Licensee Name Winchester Hospitality Inc	Facility Telephone # 304	
Facility Address 975 Foxcroft Ave Martinsburg , WV	Licensee Address ,	
Inspection Information		
Inspection Type Routine	Inspection Date 02/23/2017	Total Time Spent 2.25

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 14 Repeated # 1</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose. OBSERVATION: Laundry-Leak at bleach dispenser into washer; stained ceiling tiles need replaced; floor needs cleaned beneath back shelving; old cardboard needs removed beneath freezer; bugs</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose. OBSERVATION: Mens lobby restroom-fan grid needs cleaned and fan very noisy</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose. OBSERVATION: Rm 405-ceiling damage in center of bathroom</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose. OBSERVATION: Rm 212-A/c unit very noisy; shower head cap needs secured to wall</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose. REPEAT OBSERVATION 4th floor-Ice machine needs cleaned inside (2nd floor ice machine not accessible)</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose. OBSERVATION: Rms 307 and 303-ceiling in shower needs completed</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose. OBSERVATION: Rm-503-toilet paper holder needs secured to wall</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and</p>

sanitary condition. Facilities and equipment shall be provided for this purpose.

OBSERVATION: Rm 402-Side of a/c unit needs cleaned from paint overspray

64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose.

OBSERVATION: Rm 407-Shower curtain needs washed and side of a/c unit cleaned from paint overspray

64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose.

OBSERVATION: Rm 303-toilet seat needs tightened; hair dryer missing; light bulb needed in floor lamp

64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose.

OBSERVATION: Rm 211-Shower curtain needs trimmed; shower head-masking tape?; floor tacky

64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose.

OBSERVATION: Rm 214-caulk needed by bathtub

64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose.

OBSERVATION: Rm 312-Shower faucet leaking at base when turned on

Room: Laundry

64-18-22.1 - Effective measures shall be used to minimize the presence of rodents, flies, cockroaches, and other insects and vermin on the premises

OBSERVATION: Bugs in laundry-back room(box elder?)-dead and live-in ceiling light cover also

Inspection Outcome

Comments

Rooms inspected: 503, 505, 507, 508, 402, 403, 407, 307, 312, 303, 211, 212, 214 5th floor linen storage, 4th floor vending, Laundry, Lobby restrooms

*Fire Safety inspection Feb. 2017--Pest Control 2nd Tuesday of the month

*1st floor being renovated and half of 2nd floor

Disclaimer

Person in Charge



Sanitarian



Amy ARE Edwards