



A P P R O V A L S ®

## Certificate of Suitability

**Certificate No.:** SAA161222

**Certificate Holder:** Global Connections Group Pty Ltd T/as  
Aquila Power  
3/385 Oxley Drive  
Runaway Bay QLD 4216  
Australia

**Class Description:** Non-Declared  
**Product Description:** Stand Alone Inverter  
**Brand Name:** AQUILAPOWERS  
**Model No.:** AP30  
**Markings:** Input: 750Vdc Max, 352-705Vdc, 94A Max  
Output: 230V~ 50Hz 30kVA  
ta:45°C, Class I

**Standard:** IEC 62109-1 Ed 1.0  
IEC 62109-2 Ed 1.0

**Conditions:** Nil

**Certification Mark:** SAA161222 or RCM

**Date First Registered:** 24 June 2016

**Date of Expiry:** 24 June 2021


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 24-06-16 161222/1



A P P R O V A L S ®

## Certificate of Suitability

\* Addendum \*

**Certificate No.:** SAA161222

**Date of Issue:** 24 June 2016

**Class Description:** Non-Declared

**Product Description:** Stand Alone Inverter

**Additional Models**

AP25

**Description**

Input: 750Vdc Max 352-705Vdc 79A Max  
Output: 230V~ 50Hz 25kVA

AP20

Input: 750Vdc Max 352-705Vdc 62A Max  
Output: 230V~ 50Hz 20kVA

A handwritten signature in black ink, appearing to be 'L. ...', positioned above a horizontal line.


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 24-06-16 161222/2