



Recreational Water Facility Inspection Report

Facility Berkeley Springs Inn, LLC Certified RWF Operator Andrew Omps  
Location 1776 Valley Rd, Berkeley Springs WV 25411

Telephone \_\_\_\_\_ Permit Holder Andrew Omps Permit Number RWF-33-05-01-17-65

Type Facility (check all that apply):  Swimming Pool  Wading Pool  Diving Pool  Bathing Beach  Spa/Hot Tub  Wave Pool  
 Hydrotherapy/Therapeutic Pool  Spray Pool  Water Slide  Lazy River  Other: \_\_\_\_\_

<p><b>1. Disinfection</b></p> <p>a. Continuous chemical feed equip. *</p> <p>b. No hand batch feeding except for super-chlorination or shocking.</p> <p>c. Materials, methods approved.</p> <p>d. Gas chlorination - separate chlorine room.</p> <p>e. Chlorine room ventilation, cylinder storage, cylinder scales.</p> <p>f. No undue safety hazard.</p> <p>g. Handled, stored, used per directions.</p> <p>h. Compatible with other chemicals.</p> <p>i. Does not impart toxic properties.</p> <p>j. Effective residual; easily, accurately tested.</p> <p>k. Free chlorine residual of 1 - 5 mg/l. Deep <u>1</u> Shallow <u>1</u> Other _____</p> <p>l. Bromine residual 2 - 5 mg/l. Deep _____ Shallow _____ Other _____</p> <p>m. Other disinfectants approved; EPA reg.; residual, easily measured.</p> <p>n. Cyanuric acid as stabilizer 10-100 mg/l.</p>	<p>g. If free chlorine residual <math>\leq 0.5</math> mg/l, cease operations until <math>\geq 1.0</math>.*</p> <p>h. If free bromine residual <math>\leq 1.0</math> mg/l, cease operations until <math>\geq 2.0</math>.*</p> <p><b>7. Supervision of Patrons</b></p> <p>a. Qualified operator available.*</p> <p>b. Operator authority to exclude patron(s), evacuate facility.</p> <p>c. No urination, defecation, spitting, spouting water, blowing nose in water.</p> <p>d. No open sores or infectious disease transmissible by water.</p> <p>e. Patrons and apparel visibly clean.</p> <p>f. Children not toilet trained wear tight-fitting, plastic underwear that prevents leakage.</p> <p>g. Exclude disruptive patrons and those under influence of drugs or alcohol.</p> <p>h. No animals except service animals.</p> <p>i. Food, drink, gum, tobacco in designated, controlled areas.</p> <p>j. Glass, unsafe materials excluded.</p> <p>k. Diving from deck only at <math>\geq 5</math> ft. depth</p> <p>l. Post rules, readily visible to patrons.</p> <p><b>8. Safety Requirements</b></p> <p>a. Shepherd's crook and reach pole.</p> <p>b. 1 rescue tube/lifeguard, accessible.</p> <p>c. Without lifeguards, 1 unit of life saving equipment available for patron use.</p> <p>d. Equipment in good repair.</p> <p>e. First aid kit, fully stocked, available.</p> <p>f. Lifeguard w/o open sores or infectious diseases transmissible by water.</p> <p>g. Each lifeguard access to personal protective equip. including resuscitation mask, gloves.</p> <p>h. Certified lifeguards, if required. No. per Table 64-16B. Certificates current: life guarding, CPR, first aid.</p> <p>i. Children not left unattended in wading pool by parents/adults.</p> <p>j. If no lifeguards, post sign "Warning: No lifeguard on duty. All persons under the age of 14 must be accompanied by an adult."</p> <p>k. OSHA bloodborne pathogen plan.</p> <p>l. Telephone within 100 ft.; nos. posted.</p> <p>m. Written emergency plan.</p> <p>n. Drain entrapment of patrons avoided.</p> <p>o. Single drains meet ANSI/NSPI-1 and ANSI/NSPI-2 by 7/01/2005.</p> <p>p. Spas: Emergency shut-off switch and audible alarm within 20 ft.</p> <p>q. Comply with 87 CSR 01 Fire Code.</p> <p>r. Patron load per ANSI/NSPI-1.</p>	<p><b>9. Routine Maintenance and Operation</b></p> <p>a. Decks, sidewalks, areas surrounding facilities and bathroom clean.</p> <p>b. Visible debris removed every 12 hrs. or as needed for visibility and safety.*</p> <p>c. No visible scum, floating matter, grease line.*</p> <p>d. Skimmers, overflow gutters, hair and lint catchers maintained.*</p> <p>e. Pumps, filters maintained.*</p> <p>f. Drain as needed to inspect, clean, repair.*</p> <p>g. Water treatment equip. operated 24hrs/day.*</p> <p>h. Ventilation for indoor RWF meets ANSI/ASHRAE Standard 62-1999.</p> <p><b>10. Bathhouses, Concessions, Etc.</b></p> <p>a. Toilets, lavatories, fountains, showers per 87 CSR 04 State Building Code.</p> <p>b. Bathhouses, clothing storage facil., toilets, showers, other facil. good repair, clean.</p> <p>c. Toilet tissue at each toilet.</p> <p>d. Hand cleanser, approved drying device at each lav. or group of adjacent lavs.</p> <p>e. Hot &amp; cold running water, or tempered water, mixing faucets.</p> <p>f. Concession stand in compliance with 64 CSR 17 Food Establishments.</p> <p><b>11. Compliance</b></p> <p>a. Permit posted.</p> <p>b. Except for bathing beaches, operator shall close RWF per Table 64-16A.</p> <p>c. If water clarity not in compliance, close only affected area.*</p> <p>d. At a bathing beach, operator shall close b. beach if an inadequate no. of lifeguards or lifesaving equip. is provided; or an accident occurs causing lifeguard to leave station.</p> <p>e. Written record of closure events.</p> <p><b>12. Design, Construction*</b></p> <p>a. In compliance with ANSI/NSPI-1 1991 and ANSI/NSPI-2 1999 Standards.</p> <p>b. Lifelines, depth markings provided.</p> <p>c. Rate of flow meter Main pool _____ gpm Wading pool _____ gpm</p> <p>d. Placard in filter room lists water volume, gpm needed for turnover rate.</p> <p>e. Gauges:- Main Pool _____ Wading Pool _____ Influent _____ Effluent _____ Vacuum _____</p> <p>f. Fencing, Lighting adequate.</p> <p>(* = not applicable to bathing beaches.)</p>
---	--	--

Remarks Chlorine, Alkalinity levels are low.  
Fax weekly pool test results to health department.  
Pool must be tested again before opening.

Violations must be corrected by Immediately. Inspected by Tim Zeigler