

**West Virginia Department of Health & Human
Resources
Berkeley County Health Department**



GENERAL SANITATION INSPECTION REPORT

<i>Establishment Information</i>		
Facility Name Relax Inn	Facility Type Motel/Hotel	
Licensee Name Relax Inn	Facility Telephone # 304 263-0831	
Facility Address 1022 Winchester Ave Martinsburg , WV	Licensee Address ,	
<i>Inspection Information</i>		
Inspection Type Routine	Inspection Date 03/09/2017	Total Time Spent 1.00

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

ObservedViolations

Total # 8

Repeated # 0

64-18-22.2 - The premises shall be kept in such condition as to prevent the harborage or feeding of insects, rodents, and other vermin.

OBSERVATION: Mouse droppings behind refrigerator in laundry room (need to clean and organize equipment in room)

Room: 109

64-18-10.2 - Cleaning and sanitizing shall be conducted at a frequency necessary to maintain an environment conducive to the general safety, health and comfort of the users.

OBSERVATION: Floor behind bed closest to bathroom needs cleaned

Room: 117

64-18-10.2 - Cleaning and sanitizing shall be conducted at a frequency necessary to maintain an environment conducive to the general safety, health and comfort of the users.

OBSERVATION: Air conditioner vent needs to be cleaned

64-18-10.2 - Cleaning and sanitizing shall be conducted at a frequency necessary to maintain an environment conducive to the general safety, health and comfort of the users.

OBSERVATION: Mold around bathtub in bathroom needs cleaned/removed

64-18-10.2 - Cleaning and sanitizing shall be conducted at a frequency necessary to maintain an environment conducive to the general safety, health and comfort of the users.

OBSERVATION: Inside of microwave needs cleaned

64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose.

OBSERVATION: Handsink in bathroom needs repaired (leaking)

Room: 118

64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose.

OBSERVATION: Ceiling vent in bathroom needs repaired (duct tape not approved) Holes in cabinet under sink need repaired

64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose.

OBSERVATION: Shower head leaking in shower (room 118)

Inspection Outcome

Comments

Disclaimer

Person in Charge

Sanitarian



Bharat Gandhi



Keith Allison