Symbio LABORATORIES



CERTIFICATE OF ANALYSIS				Proudly AUSTRALIAN
Certificate Number	B1024588 [R00]	Page	1/2	ABN: 82 079 645 015
Client	Cool Off	Registering Laboratory	Brisbane	
Contact	Derrick Addison	Contact	Customer Service Tear	m
Address	271 Jude Road Howlong NSW 2643	Address	52 Brandl Street, Eight Mile Plains, QLD 4113	
		Email	admin@symbiolabs.co	om.au
Telephone	02 6026 5466	Telephone	1300 703 166	
Order Number		Date Samples Received	04/05/2021	NATA
Job Description	Water	Date Analysis Commenced	04/05/2021	
Client Job Reference		Issue Date	14/05/2021	Accreditation No: 2455
No. of Samples Registered	1 Sampler: Customer	Receipt Temperature (°C)	5.0	Accredited for compliance with ISO/IEC 17025 - Testing
Priority	Normal	Storage Temperature (°C)	4	

This report supersedes any previous revision with this reference. This document must not be reproduced, except in full. If samples were provided by the customer, results apply only to the samples 'as received' and responsibility for representative sampling rests with the customer. Results are reported on as 'as is' basis unless otherwise indicated in the 'Report Comments' section. Measurement Uncertainty is available upon request. If the laboratory was authorised to conduct testing on samples received outside of the specified conditions, all test results may be impacted. Details of samples received outside of the specified conditions are mentioned in the sample description section of this test report.

Definitions

| <: Less Than | >: Greater Than | RP: Result Pending | ~: Estimated | MPN: Most Probable Number | CFU: Colony Forming Units | ---: Not Received/Not Requested | | ^ Subcontracted Analysis | NA:Not Applicable | [NT]:Not Tested | LOR:Limit of Reporting | TBA:To Be Advised | ND:Not Detected | * Test not covered by NATA scope of accreditation | # Result derived from a calculation and includes results equal to or greater than the LOR | IH: Inconsistent results possibly caused by sample homogeneity

Authorised By

Name	Position	Accreditation Category
Glen Rangott	Environmental Laboratory Manager, Brisbane	Environmental Chemistry

Sample Information - Client/Sampler Supplied

Sample ID	Sample Description	Sample Matrix
B1024588/1	Waste Water Sample#5728	Water - General

Analytical Results

Compound/Analyte	Method	LOR	Units	B1024588/1
Total Kjeldahl Nitrogen	EFF001 - Nitrogen (Total Kjeldahl) in Water/Effluent	1	mg/L	370
Nitrate (as N)	EFF004.1 - Nitrate-Nitrogen in Water/Effluent FIA	0.005	mg/L	0.022
Nitrite (as N)	EFF005.1 - Nitrite N in Water by FIA	0.005	mg/L	0.036
рН	EFF006 - pH in Water/Effluent		pH Unit	5.88
Electrical Conductivity	EFF007 - Electical Conductivity in Water	5	μS/cm	1360
Solids (Suspended)	EFF009 - Suspended Solids in Water	1	mg/L	3800
Solids (Dissolved)	EFF010 - Dissolved Solids in Water	1	mg/L	970
Chloride	ENV002 - Anions by IC	0.05	mg/L	80
Sulphate	ENV002 - Anions by IC	0.01	mg/L	12
Fluoride	EFF015 - Fluoride in Water	0.05	mg/L	0.07
Oil & Grease	EFF021 - Oil & Grease (Gravimetric) in Water	2	mg/L	1260
BOD (5day)	EFF023 - BOD in Water	2	mg/L	6000
Total Phosphorus	EFF029.1 - Total N & P in Water by FIA	0.01	mg/L	39
Turbidity	EFF061 - Turbidity in Water	0.1	NTU	680
Salinity (Total Soluble Salt)#	EFF041 - Salinity Calculation	2	mg/L	870
Magnesium (Dissolved)	EWI01 - Dissolved metals in Water by ICPOES	0.05	mg/L	4.2

Client Cool Off
Page 2/2

Certificate Number

B1024588 [R00]



Analytical Results

Compound/Analyte	Method	LOR	Units	B1024588/1
Calcium (Dissolved)	EWI01 - Dissolved metals in Water by ICPOES	0.1	mg/L	9.3
Alkalinity Total (CaCO3)	EFF031 - Alkalinity as CaCO3 in water	1	mg/L	360
Alkalinity Bicarb (CaCO3)	EFF031 - Alkalinity as CaCO3 in water	1	mg/L	360
Alkalinity Carbonate (CaCO3)	EFF031 - Alkalinity as CaCO3 in water	1	mg/L	<1
Alkalinity Hydroxide(CaCO3)	EFF031 - Alkalinity as CaCO3 in water	1	mg/L	<1
Residual Alkalinity	EFF031 - Alkalinity as CaCO3 in water	1	meq/L	3
Nitrogen (Total) #	EFF085 - Nitrogen (Total) in Water/Effluent	1	mg/L	370
Potassium (Total)	EWI02 - ICP-AES Acid Extractable (total metals) elements in water	0.2	mg/L	75
Calcium (Total)	EWI02 - ICP-AES Acid Extractable (total metals) elements in water	0.1	mg/L	12
Magnesium (Total)	EWI02 - ICP-AES Acid Extractable (total metals) elements in water	0.05	mg/L	4.7
Sodium (Total)	EWI02 - ICP-AES Acid Extractable (total metals) elements in water	1	mg/L	68
Boron (Total)	EWM02 - Total metals in water by ICPMS	0.005	mg/L	0.014

Analysis Location

All in-house analysis was completed by Symbio Laboratories - Brisbane.

Report Comments

Laboratory results for pH, chlorine or dissolved oxygen are for information purpose only - testing conducted outside recommended storage time of 0.25hr from sampling.