

EIPC
Target 2 - Input Data and Assumptions
Exhibit 3 - Peak and Average Electric Load by Zone

All values in MW

PPA	Zone	2018			2023		
		Summer Peak	Winter Peak	Annual Average	Summer Peak	Winter Peak	Annual Average
IESO	ON_E	2,916	3,064	1,844	2,988	3,129	1,890
	ON_C	10,611	9,024	6,484	11,086	9,443	6,846
	ON_W	7,858	6,762	5,061	8,049	6,937	5,207
	ON_N	2,026	2,690	1,879	2,179	2,859	2,028
ISO-NE	ISONE_Maine	2,251	2,095	1,465	2,146	2,022	1,456
	ISONE_BOSTN	6,219	4,521	3,363	6,722	5,070	3,621
	ISONE_CT	7,554	5,534	3,893	8,022	5,759	4,295
	ISONE_ROS	13,689	10,357	7,357	14,823	11,483	8,171
MISO	MISO_MN_ND	19,811	14,744	11,640	20,936	15,674	12,319
	MISO_WUMS	13,996	10,011	7,571	14,435	10,393	7,816
	MISO_IA	9,687	7,071	5,469	10,176	7,475	5,753
	MISO_IL	10,703	7,911	6,341	11,928	8,824	7,077
	MISO_MO	8,672	6,359	5,058	8,922	6,548	5,212
	MISO_IN	17,704	13,610	11,408	18,179	13,992	11,737
	MISO_MI	21,356	13,808	11,330	21,570	13,960	11,455
	ENTG_ARK	7,073	4,740	4,174	7,368	4,946	4,359
	MISO_SOUTH	26,517	17,724	15,591	27,732	18,555	16,330
NYISO	NY_A-E	10,092	8,818	6,572	10,286	8,953	6,608
	NY_Cap	2,501	2,084	1,368	2,595	2,154	1,396
	NY_GHI	4,485	3,239	2,224	4,659	3,340	2,265
	NY_NY	12,276	8,138	6,281	12,915	8,449	6,446
	NY_LI	5,756	3,876	2,697	6,152	4,149	2,892
PJM	PJM_PSEG_N	5,345	3,323	2,582	5,462	3,396	2,639
	PJM_PSEG	5,718	3,601	2,826	5,845	3,690	2,900
	PJM_EMAAC	23,720	15,945	11,627	24,715	16,630	12,129
	PJM_SWMAAC	15,281	11,436	7,688	15,848	11,848	7,943
	PJM_MAAC	14,609	13,324	9,611	15,346	14,008	10,163
	PJM_ATSI	9,181	7,096	5,647	9,377	7,265	5,797
	PJM_CLEV	4,770	3,598	2,784	4,870	3,646	2,795
	PJM_RTO	97,873	78,055	55,162	102,862	82,015	57,813
TVA	TVA_C	18,902	18,634	12,456	19,624	19,340	12,793
	TVA_NW	844	832	556	876	864	571
	TVA_NE	1,831	1,805	1,206	1,901	1,873	1,239
	TVA_S	7,704	7,594	5,076	7,998	7,882	5,214

Notes:

1. At the request of a PPA, this table aggregates load data inputs by Area into Zone values.
2. Peak loads in this table are coincident peaks by zone.