

Transfer	FCITC (MW)	Limiting PA	Limiting Facility
F to B	1110.6	WERE-SPP	532765 HOYT 7 345kV - 532766 JEC N 7 345kV 1
	2560.2	BREC-MISO	340618 5LIVING 161kV - 340621 5COLEEHV 161kV 1
	2595.7	BREC-MISO	340618 5LIVING 161kV - 340621 5COLEEHV 161kV 1
	4308.4	OPPD-SPP	645456 S3456 3 345kV - 645458 S3458 3 345kV 1
F to E	1281.8	WERE-SPP	532765 HOYT 7 345 532766 JEC N 7 345 1

D: Summary of Incremental Transfer Capabilities
Transfers from Subsystem F

Rating (MVA)	TDF (%)	LODF (%)	Cont.PA
896	0.04204	0.33379	WERE-SPP
223	0.03002	0.08668	AMIL-MISO
223	0.0301	-0.21665	BREC-MISO/TVA
956	0.05556	0.46848	OPPD-SPP
896	-0.03639	-0.33379	WERE-SPP

Contingency / Outaged Facility	Operating Guide
532766 JEC N 7 345kV - 532767 GEARY 7 345kV 1	
348493 7XENIA 345kV - 348827 7W MT VERNON 345kV 1	
340624 5BRTAP 161kV - 360043 5PARADISE FP 161kV 1	
645455 S3455 3 345kV - 645740 S3740 3 345kV 1	
532766 JEC N 7 345 532767 GEARY 7 345 1	