



Client: Ironwood Twp
Project: WSSN 3430
Date Received: 10/25/2017

WWA Job #: 72814
Sample Matrix: Drinking water
Date Reported: 10/26/2017

Sample Number | ID | Description | Date/Time Sampled

72814-001 | E2955 Lake Rd, Ironwood MI 49938 | Lake Rd Spring | 10/24/2017 2:45:00 PM

Test	Result	Flags	Units	Date/Time	Method	MDL	SQL	Analyst
Coliforms (dw)	Positive		per 100mL	10/25/2017 11:20	Modified Colitag	1	1	CA
E. coli	Negative		per 100mL	10/25/2017 11:20	Modified Colitag	1	1	CA

CERTIFICATION

I certify that the data contained in this Final Report has been generated and reviewed in accordance with approved methods and White Water Associates Standard Operating Procedures. Exceptions, if any, are discussed in the accompanying sample narrative. Release of this Final Report is authorized by White Water Associates management, as is verified by the following signature.

Approved By: Electronically signed by Bette J. Premo

NOTES

ND = not detected, MDL = method detection limit, SQL = method quantitation limit
 ppm = mg/L (liquid) or mg/kg (solid), ppb = ug/L (liquid) or ug/kg (solid)
 Negative = No coliform bacteria detected, Positive = Coliform bacteria detected
 B The analyte was found in the associated blank as well as in the sample.
 H Indicates analytical holding time exceedance.
 J The quantitation is an estimated value because the result is less than the sample quantitation limit but greater than the detection limit.
 M A matrix effect was present.
 V Insufficient sample volume received (100 ml is required by MDEQ).
 * RPD exceeds limits.

MI DEQ Certification Number: 9306