

WWTP Report

October 2017

- The average flow per day is approximately 96,000 gallons
- No sludge hauls were required in the last 30 days
- After a heavy rainfall, for several days flow went up to a high of 385,000 gallons. This would be a strong indicator that there are water intrusion problems in the collection system.
- No major operational problems other than the defective blowers. Blowers are in the process of being replaced.
- Plant operator changed oil on the large east rotor
- Cover for backup generator was ordered and has been installed. Still needs aluminum vented box to cover while on trailer. This would assure safe operation in heaving rain.
- Two MSOA board members and maintenance met with Biometrics management to discuss the need for a redundant clarifier. During the meeting there was discussion about adding a management contract in addition to the existing maintenance contract.