

## WWTP Report

December 2017

- The average flow per day is approximately 95,000 gallons.
- One sludge haul was required since last report.
- Blowers have been replaced. One at the surge tank and one in the oxidation ditch.
- Inspected all motor covers at the plant and researching replacements with stainless steel or a composite material to prevent corrosion. Working with Biometrics on this issue.
- Had meeting with FRWA representative, Tim Plymel, and Karen Hegarty. Mr. Plymel is making arrangements to demonstrate a smoke test.
- The generator trailer is nearing completion.
- Had discussion with Biometrics and Karen Hegarty about corrosion protection for the clarifier and other WWTP components.
- Repaired (2) yard lights that provide lighting for clarifier.