



Texas Department of State Health Services

PO BOX 149347
 AUSTIN, TEXAS 78714-9347
 1-888-963-7111
 www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
 1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Volatile Organic Compounds by GC/MS
 Analysis Report

JAN 27 2017

BCWCID #2

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
 CREAMER, JOHN
 PO BOX 708
 BASTROP, TX 78602-0708

Date Reported : 01/19/2017

Report ID#: 20170119125041AD63986

2

Lab Sample ID#: AD63986	Water Source :	Date Collected : 01/10/2017 08:53	Conc. Units : µg/L
Sample Priority : NORMAL	Entry Point(s) : EP002	Date Received : 01/11/2017	Method : EPA 524.2
TCEQ ID#(s) : 1704224		Date Analyzed : 01/12/2017	Analyst : JL
			Sample Cond. : Acceptable

Regulated Cmpds.[40 CFR 141.61(a)]	Result	Qualifier	Monitored Cmpds.[40 CFR 141.40(j)]	Result	Qualifier
Benzene ¹	<0.5		1,2,4-Trimethylbenzene	<1.0	
Carbon tetrachloride ¹	<0.5		1,2,3-Trichlorobenzene	<1.0	
Monochlorobenzene ¹	<0.5		n-Propylbenzene	<1.0	
o-Dichlorobenzene ¹	<0.5		n-Butylbenzene	<1.0	
para-Dichlorobenzene ¹	<0.5		Naphthalene	<1.0	
1,2-Dichloroethane ¹	<0.5		Hexachlorobutadiene	<1.0	
1,1-Dichloroethylene ¹	<0.5		1,3,5-Trimethylbenzene	<1.0	
cis-1,2-Dichloroethylene ¹	<0.5		4-Isopropyltoluene	<1.0	
trans-1,2-Dichloroethylene ¹	<0.5		Isopropylbenzene	<1.0	
1,2-Dichloropropane ¹	<0.5		t-Butylbenzene	<1.0	
Dichloromethane ¹	<0.5		s-Butylbenzene	<1.0	
Ethylbenzene ¹	<0.5		Trichlorofluoromethane	<2.0	
Styrene ¹	<0.5		Dichlorodifluoromethane	<2.0	
Tetrachloroethylene ¹	<0.5		Bromochloromethane	<1.0	
Toluene ¹	<0.5		Other Compounds	Result	Qualifier
1,2,4-Trichlorobenzene ¹	<0.5		Acetone	<10	
1,1,1-Trichloroethane ¹	<0.5		Acrylonitrile	<10	
1,1,2-Trichloroethane ¹	<0.5		2-Butanone (MEK)	<10	
Trichloroethylene ¹	<0.5		Carbon disulfide	<1.0	
Vinyl chloride ¹	<0.5		Ethyl methacrylate	<1.0	
Xylenes (total) ¹	<0.5		2-Hexanone	<1.0	
Monitored Cmpds.[40 CFR 141.40(e)]	Result	Qualifier	Iodomethane	<5.0	
Chloroform	2.9		Methyl methacrylate	<1.0	
Bromodichloromethane	8.0	} 62.9	4-Methyl-2-pentanone (MIBK)	<2.0	
Dibromochloromethane	23		Methyl-t-butyl ether (MTBE)	<0.5	
Bromoform	29		Tetrahydrofuran	<5.0	
Dibromomethane	<1.0		Comments:		
1,3-Dichlorobenzene	<1.0				
1,1-Dichloropropene	<1.0				
1,1-Dichloroethane	<1.0				
1,1,2,2-Tetrachloroethane	<1.0				
1,3-Dichloropropane	<1.0				
Chloromethane	<2.0				
Bromomethane	<2.0				
1,2,3-Trichloropropane	<1.0				
1,1,1,2-Tetrachloroethane	<1.0				
Chloroethane	<2.0				
2,2-Dichloropropane	<1.0				
2-Chlorotoluene	<1.0				
4-Chlorotoluene	<1.0				
Bromobenzene	<1.0				
cis-1,3-Dichloropropene	<1.0				
trans-1,3-Dichloropropene	<1.0				

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(!) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead KFREE on 01/18/2017



Texas Department of State Health Services

PO BOX 149347
 AUSTIN, TEXAS 78714-9347
 1-888-963-7111
 www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
 1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Volatile Organic Compounds by GC/MS
 Analysis Report

PRINTED

JAN 27 2017

BCWCID #2

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
 CREAMER, JOHN
 PO BOX 708
 BASTROP, TX 78602-0708

Date Reported : 01/19/2017
 Report ID# : 20170119125041AD63978

Lab Sample ID# : AD63978	Water Source :	Date Collected : 01/10/2017 08:18	Conc. Units : µg/L
Sample Priority : NORMAL	Entry Point(s) : EP001	Date Received : 01/11/2017	Method : EPA 524.2
TCEQ ID#(s) : 1700558		Date Analyzed : 01/12/2017	Analyst : JL
			Sample Cond. : Acceptable

Regulated Cmpds.[40 CFR 141.61(a)]	Result	Qualifier	Monitored Cmpds.[40 CFR 141.40(j)]	Result	Qualifier
Benzene ¹	<0.5		1,2,4-Trimethylbenzene	<1.0	
Carbon tetrachloride ¹	<0.5		1,2,3-Trichlorobenzene	<1.0	
Monochlorobenzene ¹	<0.5		n-Propylbenzene	<1.0	
o-Dichlorobenzene ¹	<0.5		n-Butylbenzene	<1.0	
para-Dichlorobenzene ¹	<0.5		Naphthalene	<1.0	
1,2-Dichloroethane ¹	<0.5		Hexachlorobutadiene	<1.0	
1,1-Dichloroethylene ¹	<0.5		1,3,5-Trimethylbenzene	<1.0	
cis-1,2-Dichloroethylene ¹	<0.5		4-Isopropyltoluene	<1.0	
trans-1,2-Dichloroethylene ¹	<0.5		Isopropylbenzene	<1.0	
1,2-Dichloropropane ¹	<0.5		t-Butylbenzene	<1.0	
Dichloromethane ¹	<0.5		s-Butylbenzene	<1.0	
Ethylbenzene ¹	<0.5		Trichlorofluoromethane	<2.0	
Styrene ¹	<0.5		Dichlorodifluoromethane	<2.0	
Tetrachloroethylene ¹	<0.5		Bromochloromethane	<1.0	
Toluene ¹	<0.5		Other Compounds	Result	Qualifier
1,2,4-Trichlorobenzene ¹	<0.5		Acetone	<10	
1,1,1-Trichloroethane ¹	<0.5		Acrylonitrile	<10	
1,1,2-Trichloroethane ¹	<0.5		2-Butanone (MEK)	<10	
Trichloroethylene ¹	<0.5		Carbon disulfide	<1.0	
Vinyl chloride ¹	<0.5		Ethyl methacrylate	<1.0	
Xylenes (total) ¹	<0.5		2-Hexanone	<1.0	
Monitored Cmpds.[40 CFR 141.40(e)]	Result	Qualifier	Iodomethane	<5.0	
Chloroform	1.5	} 144	Methyl methacrylate	<1.0	
Bromodichloromethane	3.5		4-Methyl-2-pentanone (MIBK)	<2.0	
Dibromochloromethane	6.3		Methyl-t-butyl ether (MTBE)	<0.5	
Bromoform	3.1		Tetrahydrofuran	<5.0	
Dibromomethane	<1.0		Comments:		
1,3-Dichlorobenzene	<1.0				
1,1-Dichloropropene	<1.0				
1,1-Dichloroethane	<1.0				
1,1,2,2-Tetrachloroethane	<1.0				
1,3-Dichloropropane	<1.0				
Chloromethane	<2.0				
Bromomethane	<2.0				
1,2,3-Trichloropropane	<1.0				
1,1,1,2-Tetrachloroethane	<1.0				
Chloroethane	<2.0				
2,2-Dichloropropane	<1.0				
2-Chlorotoluene	<1.0				
4-Chlorotoluene	<1.0				
Bromobenzene	<1.0				
cis-1,3-Dichloropropene	<1.0				
trans-1,3-Dichloropropene	<1.0				

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead KFREE on 01/18/2017



Texas Department of State Health Services

PO BOX 149347
 AUSTIN, TEXAS 78714-9347
 1-888-963-7111
 www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
 1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

**Volatile Organic Compounds by GC/MS
 Analysis Report**

Submitter Identification Number: 0110020

JAN 27 2017

BASTROP COUNTY WCID 2
 CREAMER, JOHN
 PO BOX 708
 BASTROP, TX 78602-0708

BCWCID #2

Date Reported : 01/19/2017

Report ID#: 20170119125041AD63980

Lab Sample ID# : AD63980 Water Source :
 Sample Priority : NORMAL Entry Point(s) : EP004
 TCEQ ID#(s) : 1705803

Date Collected : 01/10/2017 09:35 Conc. Units : µg/L
 Date Received : 01/11/2017 Method : EPA 524.2
 Date Analyzed : 01/12/2017 Analyst : JL
 Sample Cond. : Acceptable

Regulated Cmpds.[40 CFR 141.61(a)]	Result	Qualifier	Monitored Cmpds.[40 CFR 141.40(j)]	Result	Qualifier
Benzene ¹	<0.5		1,2,4-Trimethylbenzene	<1.0	
Carbon tetrachloride ¹	<0.5		1,2,3-Trichlorobenzene	<1.0	
Monochlorobenzene ¹	<0.5		n-Propylbenzene	<1.0	
o-Dichlorobenzene ¹	<0.5		n-Butylbenzene	<1.0	
para-Dichlorobenzene ¹	<0.5		Naphthalene	<1.0	
1,2-Dichloroethane ¹	<0.5		Hexachlorobutadiene	<1.0	
1,1-Dichloroethylene ¹	<0.5		1,3,5-Trimethylbenzene	<1.0	
cis-1,2-Dichloroethylene ¹	<0.5		4-Isopropyltoluene	<1.0	
trans-1,2-Dichloroethylene ¹	<0.5		Isopropylbenzene	<1.0	
1,2-Dichloropropane ¹	<0.5		t-Butylbenzene	<1.0	
Dichloromethane ¹	<0.5		s-Butylbenzene	<1.0	
Ethylbenzene ¹	<0.5		Trichlorofluoromethane	<2.0	
Styrene ¹	<0.5		Dichlorodifluoromethane	<2.0	
Tetrachloroethylene ¹	<0.5		Bromochloromethane	<1.0	
Toluene ¹	<0.5		Other Compounds	Result	Qualifier
1,2,4-Trichlorobenzene ¹	<0.5		Acetone	<10	
1,1,1-Trichloroethane ¹	<0.5		Acrylonitrile	<10	
1,1,2-Trichloroethane ¹	<0.5		2-Butanone (MEK)	<10	
Trichloroethylene ¹	<0.5		Carbon disulfide	<1.0	
Vinyl chloride ¹	<0.5		Ethyl methacrylate	<1.0	
Xylenes (total) ¹	<0.5		2-Hexanone	<1.0	
Monitored Cmpds.[40 CFR 141.40(e)]	Result	Qualifier	Iodomethane	<5.0	
Chloroform	13	} 29.9	Methyl methacrylate	<1.0	
Bromodichloromethane	10		4-Methyl-2-pentanone (MIBK)	<2.0	
Dibromochloromethane	6.9		Methyl-t-butyl ether (MTBE)	<0.5	
Bromoform	<1.0		Tetrahydrofuran	<5.0	
Dibromomethane	<1.0		Comments:		
1,3-Dichlorobenzene	<1.0		The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.		
1,1-Dichloropropene	<1.0		Authorized by Team Lead KFREE on 01/18/2017		
1,1-Dichloroethane	<1.0				
1,1,2,2-Tetrachloroethane	<1.0				
1,3-Dichloropropane	<1.0				
Chloromethane	<2.0				
Bromomethane	<2.0				
1,2,3-Trichloropropane	<1.0				
1,1,1,2-Tetrachloroethane	<1.0				
Chloroethane	<2.0				
2,2-Dichloropropane	<1.0				
2-Chlorotoluene	<1.0				
4-Chlorotoluene	<1.0				
Bromobenzene	<1.0				
cis-1,3-Dichloropropene	<1.0				
trans-1,3-Dichloropropene	<1.0				



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Trihalomethanes by GC/MS
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Riverside Plant 2

Date Reported : 07/20/2017
Report ID# : 20170720091735AD88873

Lab Sample ID# : AD88873
Sample Priority : NORMAL
TCEQ ID#(s) : 1754756
Water Source :
Entry Point(s) : DBP2-01

Date Collected : 07/11/2017 08:41
Date Received : 07/12/2017
Date Analyzed : 07/17/2017
Conc. Units : µg/L
Method : EPA 524.2
Analyst : JL
Sample Cond. : Acceptable

Table with 3 columns: Trihalomethanes, Result, Qualifier. Rows include Chloroform (1.9), Bromodichloromethane (5.4), Dibromochloromethane (20.4), Bromoform (34.2), and Total Trihalomethanes (61.9).

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead HHAJIPOUR on 07/18/2017

RECEIVED
JUL 28 2017
BOWOID #2



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Haloacetic Acids
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 07/20/2017
Report ID# : 20170720091735AD88873

Lab Sample ID# : AD88873 Water Source : Date Collected : 07/11/2017 08:41 Conc. Units : µg/L
Sample Priority : NORMAL Entry Point(s) : DBP2-01 Date Received : 07/12/2017 Method : 552.2 Rev 1.0
TCEQ ID#(s) : 1754756 Date Analyzed : 07/18/2017 Analyst : MA
Extraction Date : 07/13/2017 Sample Cond. : Acceptable

Table with 3 columns: Regulated Compounds, Result, Qualifier. Rows include Monochloroacetic acid (<2.0), Dichloroacetic acid (1.1), Trichloroacetic acid (<1.0), Monobromoacetic acid (<1.0), Dibromoacetic acid (10.3), Total HAA5 (11.4).

Table with 3 columns: Monitored Compounds, Result, Qualifier. Rows include Bromochloroacetic acid (3.2), Dalapon (<1.0).

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead HHAJPOUR on 07/18/2017

RECEIVED
JUL 28 2017
LAWRENCE



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Trihalomethanes by GC/MS
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Lamaboa
2013 combined

Date Reported : 07/20/2017
Report ID# : 20170720091735AD88874

Lab Sample ID# : AD88874 Water Source : Date Collected : 07/11/2017 09:04 Conc. Units : µg/L
Sample Priority : NORMAL Entry Point(s) : DBP2-02 Date Received : 07/12/2017 Method : EPA 524.2
TCEQ ID#(s) : 1754757 Date Analyzed : 07/17/2017 Analyst : JL
Sample Cond. : Acceptable

Table with 3 columns: Trihalomethanes, Result, Qualifier. Rows include Chloroform (16.0), Bromodichloromethane (11.4), Dibromochloromethane (7.4), Bromoform (1.1), and Total Trihalomethanes 1 (35.9).

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead HHAJIPOUR on 07/18/2017

RECEIVED
JUL 28 2017
BOWCID #2



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Haloacetic Acids
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

plat 253

Date Reported : 07/20/2017

Report ID# : 20170720091735AD88874

Lab Sample ID# : AD88874
Sample Priority : NORMAL
TCEQ ID#(s) : 1754757

Water Source :
Entry Point(s) : DBP2-02

Date Collected : 07/11/2017 09:04
Date Received : 07/12/2017
Date Analyzed : 07/15/2017
Extraction Date : 07/13/2017

Conc. Units : µg/L
Method : 552.2 Rev 1.0
Analyst : MA
Sample Cond. : Acceptable

Table with 3 columns: Regulated/Monitored Compounds, Result, Qualifier. Rows include Monochloroacetic acid, Dichloroacetic acid, Trichloroacetic acid, Monobromoacetic acid, Dibromoacetic acid, Total HAA5, Bromochloroacetic acid, Dalapon.

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead HHAJIPOUR on 07/18/2017

RECEIVED
JUL 28 2017
BCWCID #2



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Haloacetic Acids
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Plat 203

Date Reported : 04/18/2017
Report ID# : 20170418130259AD78811

Lab Sample ID# : AD78811 Water Source : Date Collected : 04/07/2017 09:30 Conc. Units : µg/L
Sample Priority : NORMAL Entry Point(s) : DBP2-02 Date Received : 04/07/2017 Method : 552.2 Rev 1.0
TCEQ ID#(s) : 1749568 Date Analyzed : 04/12/2017 Analyst : CL
Extraction Date : 04/11/2017 Sample Cond. : Acceptable

Table with 3 columns: Compound Name, Result, Qualifier. Rows include Regulated Compounds (Monochloroacetic acid, Dichloroacetic acid, Trichloroacetic acid, Monobromoacetic acid, Dibromoacetic acid, Total HAA5) and Monitored Compounds (Bromochloroacetic acid, Dalapon).

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.

Authorized by Chemist III BFLAMMANG on 04/17/2017

ENTERED
APR 24 2017
BCWCID #2



Texas Department of State Health Services

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

Haloacetic Acids Analysis Report


Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

*Revised
Plat 2*

Date Reported : 04/18/2017
Report ID# : 20170418130259AD78810

Lab Sample ID# : AD78810
Sample Priority : NORMAL
TCEQ ID#(s) : 1749567

Water Source : 
Entry Point(s) : DBP2-01

Date Collected : 04/07/2017 09:07
Date Received : 04/07/2017
Date Analyzed : 04/13/2017
Extraction Date : 04/11/2017
Conc. Units : µg/L
Method : 552.2 Rev 1.0
Analyst : CL
Sample Cond. : Acceptable

Regulated Compounds	Result	Qualifier
Monochloroacetic acid	<2.0	
Dichloroacetic acid	1.3	
Trichloroacetic acid	<1.0	
Monobromoacetic acid	<1.0	
Dibromoacetic acid	10.4	
Total HAA5 ¹	11.7	
Monitored Compounds	Result	Qualifier
Bromochloroacetic acid	4.5	
Dalapon	<1.0	

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.

Authorized by Chemist III BFLAMMANG on 04/17/2017

ENTERED
APR 24 2017
BCWCID #2



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Trihalomethanes by GC/MS
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 04/18/2017
Report ID# : 20170418130259AD78811

Lanahan - Plant 2 C 3

Lab Sample ID# : AD78811 Water Source : Date Collected : 04/07/2017 09:30 Conc. Units : µg/L
Sample Priority : NORMAL Entry Point(s) : DBP2-02 Date Received : 04/07/2017 Method : EPA 524.2
TCEQ ID#(s) : 1749568 Date Analyzed : 04/12/2017 Analyst : JL
Sample Cond. : Acceptable

Table with 3 columns: Trihalomethanes, Result, Qualifier. Rows include Chloroform (18.6), Bromodichloromethane (13.9), Dibromochloromethane (8.3), Bromoform (<1.0), and Total Trihalomethanes 1 (40.8).

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2009 Standard) requirements.

Authorized by Chemist III BFLAMMANG on 04/17/2017

ENTERED
APR 24 2017
BCWCID #2



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Trihalomethanes by GC/MS
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 04/18/2017
Report ID# : 20170418130259AD78810

Handwritten note: Riverside - Plat 2

Lab Sample ID# : AD78810
Sample Priority : NORMAL
TCEQ ID#(s) : 1749567

Water Source :
Entry Point(s) : DBP2-01

Date Collected : 04/07/2017 09:07
Date Received : 04/07/2017
Date Analyzed : 04/12/2017

Conc. Units : µg/L
Method : EPA 524.2
Analyst : JL
Sample Cond. : Acceptable

Table with 3 columns: Trihalomethanes, Result, Qualifier. Rows include Chloroform (3.1), Bromodichloromethane (10.1), Dibromochloromethane (31.7), Bromoform (40.8), and Total Trihalomethanes 1 (85.7).

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2009 Standard) requirements.

Authorized by Chemist III BFLAMMANG on 04/17/2017

ENTERED

APR 24 2017

BCWCID #2



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

*SINGLE MINERAL
Analysis Report

RECEIVED
FEB 06 2017
BCWCID #2

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 01/31/2017
Report ID# : 20170131153338AD63856

3

Lab Sample ID# : AD63856
Sample Priority : NORMAL
TCEQ ID#(s) : 1731409

Water Source :
Entry Point(s) : EP004

Date Collected : 01/10/2017 09:42
Date Received : 01/11/2017

Sample Cond. : Acceptable

Table with 7 columns: Analyte, Result, Unit, Method, Date/Time Analyzed, Analyst. Row 1: Total Cyanide 1, < 0.01, mg/L, 10-204-00-1-X, 01/23/2017 11:51, MD

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead HNGO on 01/30/2017



Texas Department of State Health Services

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

*SINGLE MINERAL Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 01/31/2017
Report ID# : 20170131153338AD63835

Lab Sample ID# : AD63835 Water Source : Date Collected : 01/10/2017 08:29
Sample Priority : NORMAL Entry Point(s) : EP001 Date Received : 01/11/2017
TCEQ ID#(s) : 1727290

Sample Cond. : Acceptable

Analyte	Result	Unit	Method	Date/Time Analyzed	Analyst
Total Cyanide ¹	< 0.01	mg/L	10-204-00-1-X	01/17/2017 12:55	MD

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead HNGO on 01/30/2017



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

*SINGLE MINERAL
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

2

Date Reported : 01/31/2017
Report ID# : 20170131153338AD63834

Lab Sample ID# : AD63834 Water Source : Date Collected : 01/10/2017 09:03
Sample Priority : NORMAL Entry Point(s) : EP002 Date Received : 01/11/2017
TCEQ ID#(s) : 1730008

Sample Cond. : Acceptable

Table with 6 columns: Analyte, Result, Unit, Method, Date/Time Analyzed, Analyst. Row 1: Total Cyanide 1, < 0.01, mg/L, 10-204-00-1-X, 01/17/2017 12:54, MD

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead HNGO on 01/30/2017



Texas Department of State Health Services

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

Herbicides in Drinking Water
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 02/09/2017
Report ID# : 20170209101159AD64096

Lab Sample ID# : AD64096 Water Source : Date Collected : 01/10/2017 08:29 Conc. Units : µg/L
Sample Priority : NORMAL Entry Point(s) : EP001 Date Received : 01/11/2017 Method : 515.4 Rev. 1.0
TCEQ ID#(s) : 1720968 Date Analyzed : 01/25/2017 Analyst : MA
Extraction Date : 01/23/2017 Sample Cond. : Acceptable

Table with 3 columns: Compound Name, Result, Qualifier. Rows include Regulated Compounds (2,4-D, 2,4,5-TP, Pentachlorophenol, Dalapon, Dinoseb, Picloram) and Non Regulated Compounds (Acifluorfen, Bentazon, Chloramben, 2,4-DB, Dicamba, 3,5-Dichlorobenzoic acid, Dichlorprop, Quinclorac, 2,4,5-T).

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.

Authorized by Group Manager TDUNN on 02/08/2017

RECEIVED
FEB 17 2017
BCWCID #2



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Herbicides in Drinking Water
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

2

Date Reported : 02/09/2017
Report ID#: 20170209101159AD64095

Lab Sample ID# : AD64095 Water Source : Date Collected : 01/10/2017 08:59 Conc. Units : µg/L
Sample Priority : NORMAL Entry Point(s) : EP002 Date Received : 01/11/2017 Method : 515.4 Rev. 1.0
TCEQ ID#(s) : 1721757 Date Analyzed : 01/25/2017 Analyst : MA
Extraction Date : 01/23/2017 Sample Cond. : Acceptable

Table with 3 columns: Regulated/Non Regulated Compounds, Result, Qualifier. Lists herbicides like 2,4-D, Dalapon, etc. with results <0.1.

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.

Authorized by Group Manager TDUNN on 02/08/2017

RECEIVED
FEB 17 2017
BCWCID #2



Texas Department of State Health Services

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

Herbicides in Drinking Water
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

3

Date Reported : 02/09/2017
Report ID# : 20170209101159AD64094

Lab Sample ID# : AD64094 Water Source : Date Collected : 01/10/2017 09:38 Conc. Units : µg/L
Sample Priority : NORMAL Entry Point(s) : EP004 Date Received : 01/11/2017 Method : 515.4 Rev. 1.0
TCEQ ID#(s) : 1722544 Date Analyzed : 01/25/2017 Analyst : MA
Extraction Date : 01/23/2017 Sample Cond. : Acceptable

Table with 3 columns: Compound Name, Result, Qualifier. Rows include Regulated Compounds (2,4-D, 2,4,5-TP, Pentachlorophenol, Dalapon, Dinoseb, Picloram) and Non Regulated Compounds (Acifluorfen, Bentazon, Chloramben, 2,4-DB, Dicamba, 3,5-Dichlorobenzoic acid, Dichlorprop, Quinclorac, 2,4,5-T).

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2009 Standard) requirements.

Authorized by Group Manager TDUNN on 02/08/2017

RECEIVED
FEB 17 2017
BCWCID #2



Texas Department of State Health Services

PO BOX 149347
 AUSTIN, TEXAS 78714-9347
 1-888-963-7111
 www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
 1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

***ALL METALS
 Analysis Report**

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
 CREAMER, JOHN
 PO BOX 708
 BASTROP, TX 78602-0708

Plant I

Date Reported : 01/26/2017
 Report ID#: 20170126181753AD63887

Lab Sample ID# : AD63887 Water Source : Date Collected : 01/10/2017 08:19
 Sample Priority : NORMAL Entry Point(s) : EP001 Date Received : 01/11/2017
 TCEQ ID#(s) : 1712928

Sample Cond. : Acceptable

Analyte	Result	Unit	Method	Date/Time Analyzed	Analyst
Acidification	Completed		EPA 200.2	01/11/2017	KH
pH Check	Completed		EPA 200.2	01/12/2017	KH
Turbidity Screen	Completed		SM 2130B	01/12/2017	KH
Visible Particles	Completed			01/12/2017	KH
Total Hardness as CaCO3 by Calculation	49.6	mg/L	SM 2340B	01/12/2017	KH
Aluminum ¹	< 0.0200	mg/L	EPA 200.8	01/13/2017	IU
Antimony ¹	< 0.0010	mg/L	EPA 200.8	01/13/2017	IU
Arsenic ¹	< 0.0020	mg/L	EPA 200.8	01/13/2017	IU
Barium ¹	0.0279	mg/L	EPA 200.8	01/13/2017	IU
Beryllium ¹	< 0.00080	mg/L	EPA 200.8	01/13/2017	IU
Cadmium ¹	< 0.0010	mg/L	EPA 200.8	01/13/2017	IU
Calcium	12.8	mg/L	EPA 200.7	01/12/2017	KH
Chromium ¹	< 0.0100	mg/L	EPA 200.8	01/13/2017	IU
Copper ¹	0.0027	mg/L	EPA 200.8	01/13/2017	IU
Iron ¹	0.073	mg/L	EPA 200.7	01/12/2017	KH
Lead ¹	< 0.0010	mg/L	EPA 200.8	01/13/2017	IU
Magnesium ¹	4.29	mg/L	EPA 200.7	01/12/2017	KH
Manganese ¹	0.0124	mg/L	EPA 200.8	01/13/2017	IU
Mercury ¹	< 0.00040	mg/L	EPA 245.1	01/23/2017	BF
Nickel ¹	< 0.0010	mg/L	EPA 200.8	01/13/2017	IU
Potassium ¹	3.01	mg/L	EPA 200.7	01/12/2017	KH
Selenium ¹	< 0.0030	mg/L	EPA 200.8	01/13/2017	IU
Silver ¹	< 0.0100	mg/L	EPA 200.8	01/13/2017	IU
Sodium ¹	181	mg/L	EPA 200.7	01/12/2017	KH
Thallium ¹	< 0.00040	mg/L	EPA 200.8	01/13/2017	IU
Zinc ¹	0.0309	mg/L	EPA 200.8	01/13/2017	IU

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(¹) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead EBOYER on 01/25/2017



Texas Department of State Health Services

PO BOX 149347
 AUSTIN, TEXAS 78714-9347
 1-888-963-7111
 www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
 1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

***ALL METALS
 Analysis Report**

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
 CREAMER, JOHN
 PO BOX 708
 BASTROP, TX 78602-0708

Plant 3

RECEIVED

FEB 03 2017

Date Reported : 01/26/2017

BCWCID #2

Report ID# : 20170126181753AD63886

Lab Sample ID# : AD63886
 Sample Priority : NORMAL
 TCEQ ID#(s) : 1713531

Water Source :
 Entry Point(s) : EP004

Date Collected : 01/10/2017 09:36
 Date Received : 01/11/2017

Sample Cond. : Acceptable

Analyte	Result	Unit	Method	Date/Time Analyzed	Analyst
Acidification	Completed		EPA 200.2	01/11/2017	KH
pH Check	Completed		EPA 200.2	01/12/2017	KH
Turbidity Screen	Completed		SM 2130B	01/12/2017	KH
Visible Particles	Completed			01/12/2017	KH
Total Hardness as CaCO3 by Calculation	3.52	mg/L	SM 2340B	01/12/2017	KH
Aluminum ¹	< 0.0200	mg/L	EPA 200.8	01/13/2017	IU
Antimony ¹	< 0.0010	mg/L	EPA 200.8	01/13/2017	IU
Arsenic ¹	< 0.0020	mg/L	EPA 200.8	01/13/2017	IU
Barium ¹	0.0244	mg/L	EPA 200.8	01/13/2017	IU
Beryllium ¹	< 0.00080	mg/L	EPA 200.8	01/13/2017	IU
Cadmium ¹	< 0.0010	mg/L	EPA 200.8	01/13/2017	IU
Calcium	1.41	mg/L	EPA 200.7	01/12/2017	KH
Chromium ¹	< 0.0100	mg/L	EPA 200.8	01/13/2017	IU
Copper ¹	0.0031	mg/L	EPA 200.8	01/13/2017	IU
Iron ¹	< 0.010	mg/L	EPA 200.7	01/12/2017	KH
Lead ¹	< 0.0010	mg/L	EPA 200.8	01/13/2017	IU
Magnesium ¹	< 1.00	mg/L	EPA 200.7	01/12/2017	KH
Manganese ¹	0.0040	mg/L	EPA 200.8	01/13/2017	IU
Mercury ¹	< 0.00040	mg/L	EPA 245.1	01/23/2017	BF
Nickel ¹	< 0.0010	mg/L	EPA 200.8	01/13/2017	IU
Potassium ¹	1.44	mg/L	EPA 200.7	01/12/2017	KH
Selenium ¹	< 0.0030	mg/L	EPA 200.8	01/13/2017	IU
Silver ¹	< 0.0100	mg/L	EPA 200.8	01/13/2017	IU
Sodium ¹	227	mg/L	EPA 200.7	01/12/2017	KH
Thallium ¹	< 0.00040	mg/L	EPA 200.8	01/13/2017	IU
Zinc ¹	0.0110	mg/L	EPA 200.8	01/13/2017	IU

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(¹) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead EBOYER on 01/25/2017



Texas Department of State Health Services

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

*ALL MINERALS
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Plant 3

Date Reported : 01/26/2017

Report ID# : 20170126181753AD63831

Lab Sample ID# : AD63831
Sample Priority : NORMAL
TCEQ ID#(s) : 1715670

Water Source :
Entry Point(s) : EP001

Date Collected : 01/10/2017 08:19
Date Received : 01/11/2017

Sample Cond. : Acceptable

Table with 6 columns: Analyte, Result, Unit, Method, Date/Time Analyzed, Analyst. Rows include Field pH Result, Diluted Conductance @ 25.0 °C, Phenolphthalein Alkalinity as CaCO3, Total Alkalinity as CaCO3, Bicarbonate, Carbonate, Fluoride, Chloride, Sulfate, Total Dissolved Solids, Nitrate as N.

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead LARCHER on 01/24/2017



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

*ALL MINERALS
Analysis Report

Plat 2

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 01/26/2017
Report ID#: 20170126181753AD63830

Lab Sample ID#: AD63830 Water Source : Date Collected : 01/10/2017 08:55
Sample Priority : NORMAL Entry Point(s) : EP002 Date Received : 01/11/2017
TCEQ ID#(s) : 1716400

Sample Cond. : Acceptable

Table with 6 columns: Analyte, Result, Unit, Method, Date/Time Analyzed, Analyst. Rows include Field pH Result, Diluted Conductance @ 25.0 °C, Phenolphthalein Alkalinity as CaCO3, Total Alkalinity as CaCO3, Bicarbonate, Carbonate, Fluoride, Chloride, Sulfate, Total Dissolved Solids, Nitrate as N.

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead LARCHER on 01/24/2017



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

*ALL MINERALS
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Plant 3

Date Reported : 01/26/2017
Report ID# : 20170126181753AD63828

Lab Sample ID# : AD63828 Water Source : Date Collected : 01/10/2017 09:36
Sample Priority : NORMAL Entry Point(s) : EP004 Date Received : 01/11/2017
TCEQ ID#(s) : 1717115

Sample Cond. : Acceptable

Table with 6 columns: Analyte, Result, Unit, Method, Date/Time Analyzed, Analyst. Rows include Field pH Result, Diluted Conductance @ 25.0 °C, Phenolphthalein Alkalinity as CaCO3, Total Alkalinity as CaCO3, Bicarbonate, Carbonate, Fluoride, Chloride, Sulfate, Total Dissolved Solids, Nitrate as N.

Comments:

This final laboratory report replaces the previous facsimile/email for Fluoride analysis MCL exceedance to TCEQ on 01/26/2017. The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead LARCHER on 01/26/2017



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

EDB and DBCP
Analysis Report

RECEIVED

FEB 03 2017

BCWCID #2

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 01/26/2017

Report ID# : 20170126181753AD64042

Lab Sample ID# : AD64042
Sample Priority : NORMAL
TCEQ ID#(s) : 1723069

Water Source :
Entry Point(s) : EP001

Date Collected : 01/10/2017 08:29
Date Received : 01/11/2017
Date Analyzed : 01/18/2017
Extraction Date : 01/17/2017

Conc. Units : µg/L
Method : 504.1 Rev. 1.1
Analyst : CL
Sample Cond. : Acceptable

Table with 3 columns: Compound Name, Result, Qualifier. Rows include Ethylene dibromide, Dibromochloropropane, and 1,2,3-Trichloropropane.

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.

Authorized by Chemist III BFLAMMANG on 01/25/2017



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Haloacetic Acids
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 01/26/2017
Report ID# : 20170126181753AD63964

Lab Sample ID# : AD63964 Water Source : Date Collected : 01/10/2017 10:22 Conc. Units : µg/L
Sample Priority : NORMAL Entry Point(s) : DBP2-01 Date Received : 01/11/2017 Method : 552.2 Rev 1.0
TCEQ ID#(s) : 1746457 Date Analyzed : 01/19/2017 Analyst : MA
Extraction Date : 01/17/2017 Sample Cond. : Acceptable

Table with 3 columns: Regulated Compounds, Result, Qualifier. Rows include Monochloroacetic acid (<2.0), Dichloroacetic acid (1.1), Trichloroacetic acid (1.2), Monobromoacetic acid (<1.0), Dibromoacetic acid (10.9), Total HAA5 (13.2). Also includes Monitored Compounds: Bromochloroacetic acid (4.4), Dalapon (<1.0).

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2009 Standard) requirements.

Authorized by Chemist III BFLAMMANG on 01/24/2017



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Trihalomethanes by GC/MS
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

680 Riverside Dr

Date Reported : 01/26/2017
Report ID# : 20170126181753AD63964

Lab Sample ID# : AD63964 Water Source : Date Collected : 01/10/2017 10:22 Conc. Units : µg/L
Sample Priority : NORMAL Entry Point(s) : DBP2-01 Date Received : 01/11/2017 Method : EPA 524.2
TCEQ ID#(s) : 1746457 Date Analyzed : 01/11/2017 Analyst : DM
Sample Cond. : Acceptable

Table with 3 columns: Trihalomethanes, Result, Qualifier. Rows include Chloroform (2.3), Bromodichloromethane (8.1), Dibromochloromethane (25.7), Bromoform (39.3), and Total Trihalomethanes 1 (75.4).

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2009 Standard) requirements.

Authorized by Chemist III BFLAMMANG on 01/24/2017



Texas Department of State Health Services

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

EDB and DBCP
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 01/26/2017
Report ID# : 20170126181753AD64050

Lab Sample ID# : AD64050 Water Source : Date Collected : 01/10/2017 09:42 Conc. Units : µg/L
Sample Priority : NORMAL Entry Point(s) : EP004 Date Received : 01/11/2017 Method : 504.1 Rev. 1.1
TCEQ ID#(s) : 1725372 Date Analyzed : 01/18/2017 Analyst : CL
Extraction Date : 01/17/2017 Sample Cond. : Acceptable

Table with 3 columns: Compound Name, Result, Qualifier. Rows include Ethylene dibromide and Dibromochloropropane (Regulated) and 1,2,3-Trichloropropane (Non Regulated).

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2009 Standard) requirements.

Authorized by Chemist III BFLAMMANG on 01/25/2017



Texas Department of State Health Services

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

EDB and DBCP
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 01/26/2017
Report ID#: 20170126181753AD64064

Lab Sample ID# : AD64064 Water Source : Date Collected : 01/10/2017 09:03 Conc. Units : µg/L
Sample Priority : NORMAL Entry Point(s) : EP002 Date Received : 01/11/2017 Method : 504.1 Rev. 1.1
TCEQ ID#(s) : 1724545 Date Analyzed : 01/18/2017 Analyst : DP
Extraction Date : 01/17/2017 Sample Cond. : Acceptable

Table with 3 columns: Regulated Compounds, Result, Qualifier. Rows include Ethylene dibromide and Dibromochloropropane.

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.

Authorized by Chemist III BFLAMMANG on 01/25/2017



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Carbamates by HPLC
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Plat 3

Date Reported : 01/26/2017
Report ID# : 20170126181753AD64113

Lab Sample ID# : AD64113 Water Source : Date Collected : 01/10/2017 09:38 Conc. Units : µg/L
Sample Priority : NORMAL Entry Point(s) : EP004 Date Received : 01/11/2017 Method : EPA Method 531.1
TCEQ ID#(s) : 1719923 Date Analyzed : 01/24/2017 Analyst : KI
Sample Cond. : Acceptable

Table with 3 columns: Compound Name, Result, Qualifier. Rows include Regulated Compounds (Aldicarb, Aldicarb sulfone, Aldicarb Sulfoxide, Carbofuran, Oxamyl) and Monitored Compounds (Baygon, Carbaryl, 3-Hydroxycarbofuran, Methiocarb, Methomyl).

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(!) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead HHAJIPOUR on 01/25/2017



Texas Department of State Health Services

PO BOX 149347
 AUSTIN, TEXAS 78714-9347
 1-888-963-7111
 www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
 1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Semivolatiles Organic
 Analysis Report

RECEIVED

FEB 03 2017

BCWCID #2

Date Reported : 01/26/2017

Report ID# : 20170126181753AD64134

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
 CREAMER, JOHN
 PO BOX 708
 BASTROP, TX 78602-0708

Lab Sample ID# : AD64134 Water Source :
 Sample Priority : NORMAL Entry Point(s) : EP002
 TCEQ ID#(s) : 1710100

Date Collected : 01/10/2017 08:55 Conc. Units µg/L
 Date Received : 01/11/2017 Method : EPA 525.2
 Date Analyzed : 01/20/2017 Analyst : JO
 Extraction Date : 01/13/2017 Sample Cond. : Acceptable

Regulated Compounds	Result	Qualifier	Monitored Compounds continued	Result	Qualifier
Alachlor ¹	<0.2		Dimethylphthalate	<2.0	
Atrazine ¹	<0.1		Fluorene	<0.20	
Benzo[a]pyrene ¹	<0.02		2,2',3,3',4,4',6-Heptachlorobiphenyl	<0.51	
alpha-Chlordane	<0.2		2,2',4,4',5,6'-Hexachlorobiphenyl	<0.20	
gamma-Chlordane	<0.2		Indeno[1,2,3-cd]pyrene	<0.20	
trans-Nonachlor	<0.2		Metolachlor	<0.20	
Di(2-ethylhexyl) adipate ¹	<0.6		Metribuzin	<0.20	
Di(2-ethylhexyl) phthalate ¹	0.74	N	Naphthalene	<0.20	
Heptachlor ¹	<0.04		2,2',3,3',4,5',6,6'-Octachlorobiphenyl	<0.51	
Hexachlorobenzene ¹	<0.1		2,2',3',4,6-Pentachlorobiphenyl	<0.20	
Hexachlorocyclopentadiene ¹	<0.1	*	Phenanthrene	<0.20	
Lindane ¹	<0.02		Propachlor	<0.20	
Methoxychlor ¹	<0.1		Pyrene	<0.20	
Simazine ¹	<0.07		2,2',4,4'-Tetrachlorobiphenyl	<0.20	
			2,4,5-Trichlorobiphenyl	<0.20	
Monitored Compounds	Result	Qualifier	Trifluralin	<0.20	
Acenaphthene	<0.20		Tentatively Identified Compounds	Result	Qualifier
Acenaphthylene	<0.20		Butyl citrate	2.7	
Aldrin	<0.20		Tentative identification of the largest non-target peaks is provided by comparison with the EPA/NIH mass spectral library. Approximate quantitation is performed using internal standards and an assumed response factor of one.		
Anthracene	<0.20		Comments:		
Benzo(a)anthracene	<0.20		N - See sample comments.		
Benzo[b]fluoranthene	<0.20		* - This analyte has known instability and/or method performance issues and quantitation should be considered approximate.		
Benzo[g,h,i]perylene	<0.20		Insufficient sample received for method 525.2 and 508.1 QC requirements. M525.2- bis(2-Ethylhexyl)phthalate result confirmed by reanalysis of extract. The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.		
Benzo[k]fluoranthene	<0.20		Authorized by Team Lead KFREE on 01/26/2017		
Bromacil	<0.20				
Butachlor	<0.20				
Butylbenzylphthalate	<2.0				
2-Chlorobiphenyl	<0.20				
Chrysene	<0.20				
Dibenz[a,h]anthracene	<0.20				
Di-n-butylphthalate	<2.0				
2,3-Dichlorobiphenyl	<0.20				
Dieldrin	<0.20				
Diethylphthalate	<2.0				



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Haloacetic Acids
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 01/24/2017
Report ID# : 20170124114539AD63942

Lab Sample ID# : AD63942 Water Source : Date Collected : 01/10/2017 10:02 Conc. Units : µg/L
Sample Priority : NORMAL Entry Point(s) : DBP2-02 Date Received : 01/11/2017 Method : 552.2 Rev 1.0
TCEQ ID#(s) : 1746458 Date Analyzed : 01/18/2017 Analyst : MA
Extraction Date : 01/13/2017 Sample Cond. : Acceptable

Table with 3 columns: Regulated Compounds, Result, Qualifier. Rows include Monochloroacetic acid (<2.0), Dichloroacetic acid (6.4), Trichloroacetic acid (6.0), Monobromoacetic acid (<1.0), Dibromoacetic acid (1.6), Total HAA5 1 (14.0).

Table with 3 columns: Monitored Compounds, Result, Qualifier. Rows include Bromochloroacetic acid (3.6), Dalapon (<1.0).

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.

Authorized by Chemist III AVINYARD on 01/19/2017



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Trihalomethanes by GC/MS
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Handwritten note: 226 Lamalwa

Date Reported : 01/24/2017
Report ID# : 20170124114539AD63942

Lab Sample ID# : AD63942 Water Source : Date Collected : 01/10/2017 10:02 Conc. Units : µg/L
Sample Priority : NORMAL Entry Point(s) : DBP2-02 Date Received : 01/11/2017 Method : EPA 524.2
TCEQ ID#(s) : 1746458 Date Analyzed : 01/12/2017 Analyst : LZ
Sample Cond. : Acceptable

Table with 3 columns: Trihalomethanes, Result, Qualifier. Rows include Chloroform (23.3), Bromodichloromethane (11.5), Dibromochloromethane (6.9), Bromoform (<1.0), and Total Trihalomethanes 1 (41.7).

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2009 Standard) requirements.

Authorized by Chemist III AVINYARD on 01/19/2017



Texas Department of State Health Services

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

Carbamates by HPLC
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 01/24/2017
Report ID# : 20170124114539AD64114

Lab Sample ID# : AD64114 Water Source : Date Collected : 01/10/2017 08:58 Conc. Units : µg/L
Sample Priority : NORMAL Entry Point(s) : EP002 Date Received : 01/11/2017 Method : EPA Method 531.1
TCEQ ID#(s) : 1719162 Date Analyzed : 01/19/2017 Analyst : JL
Sample Cond. : Acceptable

Table with 3 columns: Compound Name, Result, Qualifier. Rows include Regulated Compounds (Aldicarb, Aldicarb sulfone, Aldicarb Sulfoxide, Carbofuran, Oxamyl) and Monitored Compounds (Baygon, Carbaryl, 3-Hydroxycarbofuran, Methiocarb, Methomyl).

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead HHAJIPOUR on 01/23/2017



Texas Department of State Health Services

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Carbamates by HPLC
Analysis Report

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 01/24/2017
Report ID# : 20170124114539AD64115

Lab Sample ID#: AD64115 Water Source : Date Collected : 01/10/2017 08:22 Conc. Units : µg/L
Sample Priority : NORMAL Entry Point(s) : EP001 Date Received : 01/11/2017 Method : EPA Method 531.1
TCEQ ID#(s) : 1718364 Date Analyzed : 01/19/2017 Analyst : JL
Sample Cond. : Acceptable

Table with 3 columns: Compound Name, Result, Qualifier. Rows include Regulated Compounds (Aldicarb, Aldicarb sulfone, Aldicarb Sulfoxide, Carbofuran, Oxamyl) and Monitored Compounds (Baygon, Carbaryl, 3-Hydroxycarbofuran, Methiocarb, Methomyl).

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead HHAJIPOUR on 01/23/2017



Texas Department of State Health Services

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

Pesticides by Method 508.1 RECEIVED

Analysis Report

FEB 03 2017

BCWCID #2

Submitter Identification Number: 0110020

BASTROP COUNTY WCID 2
CREAMER, JOHN
PO BOX 708
BASTROP, TX 78602-0708

Date Reported : 01/26/2017
Report ID# : 20170126181753AD64134

Lab Sample ID# : AD64134 Water Source : Date Collected : 01/10/2017 08:55 Conc. Units : ug/L
Sample Priority : NORMAL Entry Point(s) : EP002 Date Received : 01/11/2017 Method : 508.1 Rev. 2.0
TCEQ ID#(s) : 1710100 Date Analyzed : 01/17/2017 Analyst : AM
Sample Cond. : Acceptable

Table with 3 columns: Regulated Compounds, Result, Qualifier. Rows include Chlordane, Endrin, Heptachlor epoxide, and Toxaphene.

Comments:

Insufficient sample received for method 525.2 and 508.1 QC requirements. M525.2- bis(2-Ethylhexyl)phthalate result confirmed by reanalysis of extract. The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead KFREE on 01/26/2017