

2022
Village of Liberty
Annual Drinking Water Quality Report
Fed ID # NY5203329

We are pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the water quality and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process, provide protection of our water resources and inform you on completed system upgrades. We are committed to ensuring the quality of your water. Our water source during 2022 has been the Lily Pond Water Filtration Plant and the Elm Street Well. The New York State Department of Health has conducted a "Source Water Assessment". Enclosed is a copy of the summary. For any questions regarding this assessment, please feel free to contact our office or the Department of Health. We have an aquifer protection ordinance available from our office that provides more information, such as potential sources of contamination, and describes restricted uses.

This report shows our water quality and what that means. If you have any questions about this report or concerning your water utility, please contact The Village of Liberty Water Department at 845-292-6420. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1ST AND 3RD Thursdays of each month at 7:00 PM in the Boardroom at the Village Municipal Building, 167 North Main Street, Liberty, New York 12754.

One improvement that continues to take place in our distribution system is the ongoing upgrade of our water meters. We have been changing out old meters and installing new remote read meters to streamline our reading of meters, as well as billing.

During the year 2022 the Village water system's daily requirements were an average of 552,000 gallons, of which the Lily Pond Filtration Plant provided 65% of the total system demand. The Elm Street Well provided 35% of the total system demand. The water usage is based on meter sales, calculated leaks, fire use, and flushing. We currently have 1,645 service connections and are serving 3,900 people in and around the Village and Parksville. In 2022 the average home's water bill was \$184.56 per quarter.

While we are working steadily toward supplying all of our system needs from the Lily Pond Filtration Plant, it is worth noting that the Elm Street Well has **not** had a positive MTBE reading since December 4th 1998. The Village of Liberty System routinely monitors for contaminants in your drinking water according to Federal and State laws. The table below shows the results of our monitoring for the past five years, as required by law. All drinking water, including bottled drinking water, may be expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

During 2022 we did not conduct lead and copper sampling because we are not required to until the year 2023. Listed in this report are the results from the year 2022. Testing showed the 90th percentile results were below the current action levels (Copper = 0.425 mg/l and Lead = <0.001 mg). Please see the table below. The level presented represents the 90th percentile of the 20 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected in the water system. The lowest and highest sample results are also listed.

For additional information related to compliance with the Lead and Copper Rule please visit the following:

<http://www.health.ny.gov/environmental/water/drinking/regulations/>

<https://www.epa.gov/dwreginfo/lead-and-copper-rule>

If present, elevated levels of lead can cause serious health problems, especially for pregnant women, infants, and young children. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. Village of Liberty Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

In the following table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Variations & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Action Level - the concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a

Maximum Contaminant Level - (mandatory language) The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - (mandatory language) The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Table of Detected Contaminants

Contaminant	Date of Sampling	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
(1) Total Coliform Bacteria	2022	N	ND	Per 100 ML	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment.
(2) Fecal coliform and <i>E.coli</i>	2022	N	ND	Per 100 ML	0	Any positive	Human and animal fecal waste
(3) Turbidity	2022 Done daily	N	Highest Run Ave 8/23/22 .058 Lowest Run Ave 10/25/22 .014 Average .033	NTU	N/A	.300	Soil runoff
(13) Total Organic Carbon	2022	N	Avg Raw 4.8 Avg Finish 1.6	Mg/L	N/A	50% average removal from Raw to Finish	Naturally Occurring
(4) MTBE (ELM ST. WELL)	2022	N	ND	Ug/l	0	.01	Octane boosting additive of gasoline
(7) Nitrate (as Nitrogen)	7/12/22	N	Elm ST 0.863	Mg/L	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
(8) Nitrite		N		Mg/L	0	1	
(7) Nitrate	7/12/22	N	PLANT 0.192	Mg/L	10	10	
(8) Nitrite		N	<0.025	Mg/L	0	1	
(9) TTHM (total trihalomehtanes)	3/10/22 6/8/22 9/15/22 12/8/22	N	Highest Running Annual Average 43.0 Max level 74.8 Min level 24.3	Ug/L		80	By product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains large amounts of organic matter.
(8) THAA (total haloacetic acids)	3/10/22 6/8/22 9/15/22 12/8/22	N	Highest Running Annual Average: 51.0 Max level: 57.8 Min level: 31.0	Ug/L	0	60	By product of drinking water disinfect ion needed to kill harmful organisms.
BARIUM	7/12/22 7/12/22	N	Elm St 0.27 Lily Pond 0.0226	MG/L	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
NICKEL	7/12/22 7/12/22	N	Lily Pond <0.0005 Elm ST <0.0005	MG/L	N/A	N/A	Erosion of natural deposits.
ARSENIC	7/12/22 7/12/22	N	Lily Pond <0.001 Elm ST <0.001	Mg/L		0.010	Naturally Occurring
(10) SODIUM	7/14/20 10/5/17	N	Elm ST Well 56 Lily Pond 7.8	MG/L		See Notes	Naturally occurring; Road salt; Water softeners; Animal waste.
(6)(12) LEAD	7/28/20	N	90 th % =0 Range: 0 – 0.0047 Action level exceeded at 0 sites	MG/L	.001	0.015	Corrosion of household plumbing

(5)(12) COPPER	7/28/20	N	90 th % = 0.301 Range: 0.0182 – 0.619	Mg/L	.301	1.3	Corrosion of plumbing
PFOS	6/14/22 9/14/22 11/12/20	N	PLANT <1.9 <0.893 WELL 2.9	ng/L		10 ng/L	MAN MADE CHEMICALS
PFOA	6/14/22 9/14/22 11/12/20	N	PLANT < 1.9 <0.893 WELL 2.1	ng/L		10ng/L	MAN MADE CHEMICALS
CHROMIUM	WELL 7/12/22 PLANT 7/12/22	N	WELL <0.007	Mg/L		0.1	Naturally Occurring
		N	PLANT <0.007			0.1	
FLUORIDE	WELL 7/12/22 PLANT 7/12/22	N	WELL <0.10	Mg/L		2	
		N	PLANT <0.10			2	
SELENIUM	WELL 7/12/22 PLANT 7/12/22	N	WELL <0.002	Mg/L		0.05	Naturally Occurring
		N	PLANT <0.002			0.05	
GROSS ALPHA	8/25/2016	N	WELL 0 +/-1.13	pCi L		15	Naturally Occurring
TOTAL URANIUM	3/9/16	N	Well 0.117+/-0.003	ug/L		30	Naturally Occurring
COMBINED RADIUM 226&228	3/19/16	N	Well 0.637+/-0.374	pCi		5	Naturally Occurring
GROSS BETA ALPHA PARTICLE ACTIVITY	3/19/16	N	1.11+/-0.859	millire ms		4	Naturally Occurring
DALAPON	7/14/20	N	1.3 LILY POND	ug/l		EP	

SAMPLING VIOLATION

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether your drinking water meets health standards. During 2022 we had no bacteriological sample that was in violation in the Village of Liberty.

- (1) **Total Coliform.** Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially – harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.
- (2) **Fecal coliform/E.Coli.** Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, and people with severely compromised immune systems.
- (3) **Turbidity.** constant monitoring annual avg. Turbidity has no health effects. However, turbidity can interfere with disinfections and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.
- (4) Even though we currently do not exceed MTBE levels, the Village still continually monitors for MTBE and any of its associated compounds. At present we show no presence of MTBE.
- (5) **Copper.** Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's disease should consult their personal

doctor.

(6) **Lead.** Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

(7) **Nitrate.** Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue-baby syndrome.

(8) **HAA's [Haloacetic Acids]** Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

(9) **TTHMs [Total Trihalomethanes].** Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

(10) **SODIUM** Water containing more than 20mg/l of sodium should not be used for drinking by people on severely restricted sodium diets.

(11) Running annual average above exceedance of the MCL for two quarters

(12) The level presented represents the 90th percentile of the 20 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper or lead values detected in the water system.

(13) Total organic carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes (THMs) and haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.

What Does This Information Mean?

Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites, which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

We constantly monitor the water supply for various constituents. We have **NOT** detected cryptosporidium in the water from the Lily Pond Water Filtration Plant. We have **NOT** detected this constituent in any of our samples tested. We believe it is important for you to know that cryptosporidium may cause serious illness in immuno-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS, or other immune system disorders. These people should seek advice from their health care providers.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals, and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Total Coliform: The Total Coliform Rule requires water systems to meet a stricter limit for coliform bacteria. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public by newspaper, television or radio. To comply with the stricter regulation, we have increased the average amount of chlorine in the distribution system.

Nitrates: As a precaution, we always notify physicians and health care providers in this area if there is ever a higher than normal level of nitrates in the water supply.

Lead: Lead in drinking water is rarely the sole cause of lead poisoning, but it can add to a person's total lead exposure. All potential sources of lead in the household should be identified and removed, replaced or reduced.

Our non-English speaking customers should contact the Village office for assistance in reading this report. This report contains important information about your drinking water. Translate it, or speak with someone who understands it.

<p>Spanish Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.</p>	<p>French Ce rapport contient des informations importantes sur votre eau potable. Traduisez-le ou parlez en avec quelqu'un qui le comprend bien.</p>
<p>Korean 아래의 보고는 귀사에서 드시는 식수에 대한 중요한 정보가 포함되어 있습니다. 번역을 하시든 아니든 이 보고를 읽은 이래 리는 분나 말씀하시기를 바랍니다.</p>	<p>Chinese 這份報告含有非常重要有關您喝的水的資料。請找懂得這份報告的人翻譯或解釋給您聽。</p>

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer, undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

In closing we would like to take the opportunity to thank you for allowing us to provide your family with clean, quality water during the last year. We take pride in the water we produce and deliver to your homes and look forward to the improvements that will take place during 2023.

Please call our office if you have questions. You can also locate this information via internet at www.libertyvillageny.org
VILLAGE DEPARTMENTS/WATER DEPARTMENT

Village of Liberty Water Department