

HOT WORK PERMIT

THIS HOT WORK PERMIT IS REQUIRED FOR ALL OPERATIONS WHICH CREATE HEAT, SPARKS OR OPEN FLAME.

PROJECT: _____ CONTRACTOR: _____ DATE: _____

CONTRACTOR COMPETENT PERSON RESPONSIBLE FOR OPERATION: _____

(CONTRACTOR - PRINT NAME)

I understand the expectations of this Hot Work Permit and the responsibility to implement the requirements.

X

(CONTRACTOR - SIGNATURE)

The location identified below has been reviewed and the required pre-cautions have been taken. The fire watch requirement has been established.

X

(APP - SIGNATURE)

FIRE WATCH REQUIREMENT AS DETERMINED BY APP (INITIAL ONE):

<input type="checkbox"/>	INDEPENDENT FIRE WATCH DURING WORK AND AREA MONITORED 60 MIN. AFTER
--------------------------	---

<input type="checkbox"/>	AREA MONITORED 60 MINUTES AFTER ONLY
--------------------------	--------------------------------------

<input type="checkbox"/>	FIRE WATCH NOT REQUIRED
--------------------------	-------------------------

NAME OF FIRE WATCH (IF REQUIRED): _____

TYPE AND LOCATION OF WORK PERFORMED

LOCATION OF WORK: _____

TYPE OF WORK: _____

START TIME: _____

FINISH TIME: _____

REQUIRED PRECAUTIONS

- YES Work area inspected for hazards above, below & adjacent to work area.
- YES Fire extinguisher present, charged & within 20' of work area
- YES Flammables and combustibles removed or protected and area swept
- YES N/A Smoke / heat detectors protected or taken out of service
- YES N/A Sprinkler heads in area identified and protected

FIRE WATCH CRITERIA

IF ANY OF THE FOLLOWING EXISTS, AN INDEPENDENT FIRE WATCH IS REQUIRED DURING AND FOR 60 MINUTES AFTER HOT WORK

- YES NO Does the facility owner require an independent fire watch during and after hot work?
- YES NO Is active fire protection in proximity (within 10') of the hot work and not shut down?
- YES NO Is the hot work adjacent to unsealed shafts, roofs, or floor penetrations where sparks or byproduct can drop to area below?
- YES NO Are flammable and combustibles near or below the hot work?

IF THE FOLLOWING CONDITION EXISTS, AREA MUST BE MONITORED FOR 60 MINUTES AFTER COMPLETION OF HOT WORK ONLY

- YES NO Is the hot work being performed in a cavity or enclosure that is not completely visible?

IF NONE OF THE CONDITIONS LISTED ABOVE EXIST, NO INDEPENDENT OR POST-WORK FIRE WATCH IS REQUIRED

PERMIT CLOSURE

I verify the above location has been examined and the required procedures have been followed. Fire watch requirement was met and no hot work hazards exist.

X

(COMPETENT PERSON - SIGNATURE)

AUSTIN POWER REPRESENTATIVE

REVIEWED AREA: _____

X

(APP - SIGNATURE)

PERMIT CLOSURE: DATE: _____ TIME: _____