

FRONT EXTERIOR

- 1. SEE CROSS SECTION FOR METHOD OF ROOF VENTILATION
- FOUNDATION ENCLOSURE (WHEN PROVIDED) MUST HAVE ONE SQUARE FOOT NET VENT AREA PER 1/150TH OF THE FLOOR AREA.
- A 22"X36" MINIMUM CRAWL SPACE ACCESS AND A 6 MIL POLY GROUND COVER, SITE INSTALLED BY OTHERS AND SUBJECT TO LOCAL JURISDICTION.
- 4. STEPS, RAILS, & DECKS TO BE DESIGNED AND BUILT BY OTHERS ON SITE, IN ACCORDANCE WILL LOCAL CODES REQUIREMENTS AND INSPECTIONS.

ATTIC VENTILATION: CEILING INLET: (42/51)X144 = 308448 SQ.IN. REQUIRED INLET AREA: (,5X154224)/300 = 514.08 SQ.IN. PROVIDED INLET AREA: (52/2)\$ = 520 SQ.IN SQ.IN. 520 SQ.IN. > 514.08 SQ.IN. THEREFORE OK

REQUIRED OUTLET AREA: (.5x154224)/300 = 514.08 SQ.IN. RIDGE VENT = 15 SQ.IN. PER FOOT OF AIR FLOW SOFFIT = 5 SQ. IN PER FOOT OF AIR FLOW 34.27 FT OF RIDGE VENT REQUIRED 102.81 FT OF SOFFIT VENT REQUIRED THE FBC CODE REQUIRES THAT ALL BUILDINGS LOCATED IN AREAS WITH WIND SPEEDS EQUAL TO DR GREATER THAN 140 MEH AND ALL BUILDINGS LOCATED IN AREAS WITH WIND SPEEDS EQUAL TO OR GREATER THAN 130 MEH WINCH ARE WITHIN ONE MILE OF A HURRICANE PROME COAST LINE BE PROVIDED WITH ETIMER OF THE FOLLOWING.

(1) IMPACT RESISTANT GLAZING COMPLYING WITH THE SSTD12, ASTM E 1886 AND/OR ASTM E 1996.

(2) STORM PROTECTION WOOD PANLES (I.E. WIN. 7/16" OSB OR PLYWOOD) PRECUIT TO FIT THE GLADING OPDINING WITH THE ATTACHMENT HANDMINE PROVIDED. THE PROTECTINE PANELS MUST BE INSTALLED IN ACCORDANCE WITH THE FASTENING SCHEDULE PROVIDED IN TABLE 301.2.1.2 FOR WINDSPEEDS EXCEEDING 130 MPH OR THE ATTACHMENTS MUST BE DESIGNED TO RESST THE COMPONENT AND CURDINING DOORS SPECIFIED FOR 7301.2.2 AND FOR HEIGHTS NOT TO EXCEED 30FT MEAN ROOF

NOTE: THE STORM PROTECTIVE PANELS MAY BE PROVIDED BY THE LOCAL CONTRACTOR OR INSTALLER PATHER THAN THE BUILDING MANUFACTURER.

IN ADDITION, EXTERIOR WINDOWS AND DOORS MUST BE DESIGNED TO RESIST THE DESIGN WIND LOVE SPECIFIED IN TABLE R301.2.2 OF THE FBC CODE ADJUSTED FOR HEIGHT & EXPOSURE PER TABLE R301.2.3 OF THE FBC CODE.

ALL EXTERIOR WINDOWS AND GLASS DOORS MUST BE TESTED AND APPROVED BY AN APPROVED NOEPENDANT LABORATORY AND BEAR A LABEL NOICATING COMPLIANCE WITH ANALYNWINDA 101/LS.2.



FINER LINES DESIGN & CONSTRUCTION INC.

DATE:	11/30/2016	3RD PARTY INSPECTION AGENCY NTA INC 305 NORTH OAKLAND AVE	
CODES:	2014 FBC		
LABELS:	FLORIDA	NAPPANEE N 46550	
SCALE:	NTS	NAPPANEE, N 46550 Contact: Dave Borts (574-773-2732)	
MODEL:			DRAWN BY:
METO/37_MES15_658_108			

EXTERIOR ELEVATION

SHEET 2

NK MYERS PE, PLI 805 28TH STREET KERBURG, WV 26