

**West Virginia Department of Health &
Human Resources
Berkeley County Health Department**

No image found with name:
Berkeley.png. Image files
needed to be generated.

GENERAL SANITATION INSPECTION REPORT

<i>Establishment Information</i>		
Facility Name Rosemont Elementary	Facility Type School	
Licensee Name Berkeley Co. Board of Education	Facility Telephone # 304	
Facility Address 301 S Alabama Ave Martinsburg , WV	Licensee Address ,	
<i>Inspection Information</i>		
Inspection Type Routine	Inspection Date 06/11/2018	Total Time Spent 2.08

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

<i>Observed Violations</i>
<p>Total # 4 Repeated # 3</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose. REPEAT OBSERVATION Ceiling tile in the cafeteria needs replaced, stained from water</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose. REPEAT OBSERVATION New door sweeps needed at doors 6,9,16,18,</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose. REPEAT OBSERVATION Water fountain in the cafeteria needs repaired, running slowly, no pressure</p> <p>64-18-22.2 - The premises shall be kept in such condition as to prevent the harborage or feeding of insects, rodents, and other vermin. OBSERVATION: Hole in wall in room 4 needs repaired possible entry point for pests.</p>

<i>Inspection Outcome</i>

<i>Comments</i>

Disclaimer

Person in Charge

Sanitarian

Glenn GCO Ondick