



Eastern Interconnection Planning Collaborative

EIPC 2014

Result of Activities and Work Plan (Non-Grant)

EIPC Webinar
November 21, 2014

Outline

- Background
- Scenario A
 - Updates to 2023 Roll-Up Case
 - Summary of Transfer Results
- Scenario B
 - Heat Wave & Drought Scenario
- 2014 EIPC Report

Background

EIPC 2013 Effort:

- 2018 and 2023 summer peak models created
 - Model assembled utilizing most up to date information
- Steady-state load-flow model analysis performed
 - Transmission “Gap” Analysis
 - Linear Transfer Analysis
- Report assembled and posted to EIPC website
 - http://www.eipconline.com/Non-DOE_Documents.html

Background

EIPC 2014 Effort:

- Stakeholder input requested for potential scenarios
 - 2 sample scenarios created by EIPC
 - 5 scenarios submitted by stakeholders
- Two of Stakeholder suggested scenarios selected
 - Updated 2023 Roll-Up Base Case
 - Heat Wave and Drought Scenario
- Purpose of Today's Webinar
 - Inform Stakeholders of completion of updated base case
 - Inform Stakeholders of Heat Wave and Drought Results
 - Inform Stakeholders of 2014 Report

Scenario A – Update of 2023 Roll-Up Case

- 2023 Summer Peak Roll-Up Utilized as Starting Point
 - Updated with any available generation, transmission, and load modifications determined significant by individual PA's
- Interregional “Gap” Analysis Performed
 - N-1 contingency analysis
 - Purpose was to identify effect of changes between neighboring Planning Authorities systems
- Linear Transfer Analysis
 - Purpose was to demonstrate the effect of model updates on the ability to transfer power between large areas above long term commitments

Scenario A - Summary of Transfer Results

- Objective was to demonstrate the effect case updates had on the Eastern Interconnection's ability to reliably move large amounts of power between areas
 - Analyzed 5,000 MW transfers between selected areas
- Monitored the following (100 kV and above):
 - N-0 branch overloads
 - N-1 branch overloads
 - Also included NYISO specific regional contingencies
- Updates to 2023 Roll-up did not have significant impact on the Eastern Interconnection transfer capability

Scenario A - Summary of Transfer Results

				Previous		New	
Source		Sink		FCITC (MW)	Lim. PA	FCITC (MW)	Lim. PA
A	FRCC	E	SERC	1600	DEF	1700	DEF
B	MISO	C	NPCC	3400	PENELEC-PJM	3100	PENELEC-PJM
B	MISO	D	PJM	>5000	N/A	>5000	N/A
B	MISO	E	SERC	>5000	N/A	>5000	N/A
B	MISO	F	SPP	650	EES	650	EES
C	NPCC	B	MISO	1800	NYISO	1750	NYISO
C	NPCC	D	PJM	1500	NYISO	1200	NYISO
D	PJM	B	MISO	1600	ALTW-MISO	1650	ALTW-MISO
D	PJM	C	NPCC	2100	PENELEC-PJM	2750	NYISO
D	PJM	E	SERC	>5000	N/A	>5000	N/A
E	SERC	A	FRCC	1900	SBA/FRCC	1900	SBA/FRCC
E	SERC	B	MISO	>5000	N/A	>5000	N/A
E	SERC	D	PJM	1900	BREC-MISO	4800	DVP-PJM
E	SERC	F	SPP	550	SWPA-SPP	500	SWPA-SPP
F	SPP	B	MISO	850	WERE-SPP	800	WERE-SPP
F	SPP	E	SERC	950	WERE-SPP	950	WERE-SPP

Scenario B

Heat Wave and Drought Scenario Assumptions

- Submitted by: Eastern Interconnection States' Planning Council (EISPC)
- Study Case: Updated 2023 Summer Peak
- Premise: Model a severe and pervasive heat wave and drought condition in study year 2023
- Questions to be answered by analysis:
 - “What constraints arise when large amounts of power are transferred to areas of need during times of extremely high temperatures and drought conditions”

Scenario B

Heat Wave and Drought Scenario Assumptions

Modeling Parameters and Resource Modifications:

- Utilized updated 2023 summer peak roll-up model
- Modeled effect of heat wave condition on sink
 - Scale sink load up by 5% (~15,000 MW)
- Modeled effect of drought condition on sink
 - Scale sink generation down by 5% while assuming all unused capacity is unavailable (~15,000 MW)
- Modeled effect of power transfer from source
 - Scale available generation up while not violating generator limits (~30,000 MW)

Scenario B


Heat Wave and Drought Scenario Assumptions

- Utilizing revised Heat Wave & Drought Scenario Model:
 - Perform N-1 contingency analysis on 200 kV and above
 - Except for areas where lower voltage levels are required
 - Monitor all lines 161 kV and above
 - Utilizing MUST transfers analysis to identify facilities with > 3% TDF
 - Transfer Source:
 - ISO-NE, NYISO, IESO, PJM, MISO North, ATC, MAPP
 - Transfer Sink:
 - TVA, MISO South, SPP, SOCO, DEC, DUKE, SCEG, SC, PS, Alcoa, EEI, LGE/KU, FPL, DEF, JEA
 - Assembling results into report to be presented to Stakeholders December 2014

Scenario B

Heat Wave and Drought Scenario Results

Table illustrates the impacted facilities by KV range



2014 EIPC Amended Report

- Report for 2014 EIPC effort intended to be amendment of 2013 effort report
- Draft report is nearing completion
 - Expected to be posted for Stakeholder comments in early December
- Overview of report upcoming is subject to change

2014 EIPC Amended Report Assembly

Scenario A – Update to 2023 Summer Peak Roll-Up Case:

Section 2.1: Roll-Up Case Updates

- Description of PA Updates Provided

Section 2.2: Interregional Transmission Analysis

- Summary of Thermal Results

Section 2.3: Potential Enhancements to Section 2.2 Analysis

- Issues List and Conceptual Upgrades

Section 2.4: Linear Transfer Analysis

- Linear Transfer Result Comparison Between 2013 and 2014 Efforts

2014 EIPC Amended Report Assembly

Scenario B – Heat Wave and Drought Scenario:

Section 3.1: Scenario Inputs and Process

- Description of Case Creation

Section 3.2: Scenario Results

- Summary of Linear Transfer Results

Section 3.3: Discussion of Results

- Discussion of Meaning of Results

2014 EIPC Amended Report Assembly

Appendix F

- Update to New/Upgraded Transmission Projects Included in Cases

Appendix G

- Update to Generation Included in Cases

Appendix H

- Linear Transfer Analysis Results

Appendix I

- Heat Wave and Drought Scenario Case Modifications

Appendix J

- Heat Wave and Drought Scenario Linear Transfer Analysis Results

Appendix K

- Eastern Interconnection Wide Map Highlighting Impacted Facilities

Questions and Discussion

