

## Ampacity Rating For Emery Thompson Batch Freezers

Only For Machines Built After May 1, 2018

Cooling	Machine Model	Voltage	Phase	Hertz	Minimum Circuit Amperage	Maximum Fuse
Air	CB-100	115	1	60	11.0	20
Air	CB-200	115	1	60	13.75	20
	CB-200	208-230	1	60	9.0	20
	CB-200	240	1	50	8.2	20
Air	CB-350	208-230	1	60	14.7	20
	CB-350	240	1	50	15.5	20
Air	12LA-1	208-230	1	60	31.6	40
	12LA-3	208-230	3	60	26.2	30
	12LA-3	380	3	50	15.2	20
	12LA-3	460	3	60	13.5	20
	12LA-IOC-1	208-230	1	60	36.0	40
	12LA-IOC-3	208-230	3	60	26.2	30
	12LA-IOC-3	380	3	50	15.2	20
	12LA-IOC-3	460	3	60	13.5	20
Water	12NW-1	208-230	1	60	36.0	40
	12NW-3	208-230	3	60	23.7	30
	12NW-3	380	3	50	14.5	20
	12NW-3	460	3	60	12.7	20
	12NW-IOC-1	208-230	1	60	36.0	40
	12NW-IOC-3	208-230	3	60	23.7	30
	12NW-IOC-3	380	3	50	14.5	20
	12NW-IOC-3	460	3	60	12.7	20
Air	24LA-1	208-230	1	60	36.0	40
	24LA-3	208-230	3	60	26.2	30
	24LA-3	380	3	50	15.2	20
	24LA-3	460	3	60	13.5	20
	24LA-IOC-1	208-230	1	60	31.6	40
	24LA-IOC-3	208-230	3	60	26.2	30
	24LA-IOC-3	380	3	50	15.2	20
	24LA-IOC-3	460	3	60	13.5	20
Water	24NW-1	208-230	1	60	36.0	40
	24NW-3	208-230	3	60	23.7	30
	24NW-3	380	3	50	14.5	20
	24NW-3	460	3	60	12.7	20
	24NW-IOC-1	208-230	1	60	36.0	40
	24NW-IOC-3	208-230	3	60	23.7	30
	24NW-IOC-3	380	3	50	14.5	20
	24NW-IOC-3	460	3	60	12.7	20
Water	44BLT-3	208-230	3	60	42.3	50
	44BLT-IOC-3	208-230	3	60	42.3	50
	44BLT-IOC-3	380	3	50	21.8	30
	44BLT-IOC-3	460	3	60	18.3	20
Air	44BLT-LC-1	208-230	1	60	27.5	30
	REMOTE UNIT	208-230	1	60	34.1	40
	44BLT-LC-3	208-230	3	60	14.5	20
	REMOTE UNIT	208-230	3	60	21.4	30
	44BLT-IOC-LC-1	208-230	1	60	28.5	30
	REMOTE UNIT	208-230	1	60	34.1	40
	44BLT-IOC-LC-3	208-230	3	60	14.5	20
	REMOTE UNIT	208-230	3	60	21.4	30