

Contaminant	Violation Yes/No	Level Found	Range of Detections	Date of Sample	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria	No	0		2013		0	<2 positive samples	Naturally present in the environment
Turbidity ¹	No	0.88		2013	NTU	n/a	TT	Soil runoff
Copper ²	No	0.034 90 th %		2012	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead ²	No	1.9 90 th %		2012	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate (as Nitrogen)	No	2.1		2013	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium	No	23		2013	ppm	N/A	N/A	Erosion of natural deposits; used in water treatment
TTHM ³ [Total trihalomethanes]	No	25.5		2013	ppb	n/a	80	By-product of drinking water chlorination
Haloacetic Acids ³ (HAA5)	No	30.6		2013	ppb	N/A	60	By-product of drinking water disinfection.
Total Organic Carbon ⁴	No			2013	ppm	TT	TT	Naturally present in the environment.
Chlorine	No	1.47 AVG.	1.0-1.7	2013	ppm	MRDLG4	MRDL 4	Water additive used to control microbes.