

**West Virginia Department of Health &
Human Resources
Berkeley County Health Department**

No image found with name:
Berkeley.png. Image files
needed to be generated.

FOOD ESTABLISHMENT INSPECTION REPORT

Establishment Information		
Facility Name Hedgesville Middle School	Facility Type Food Service Establishment	
Licensee Name Berkeley Co. Board of Education	Facility Telephone # 304 754-3313	
Facility Address 334 School House Drive Hedgesville , WV	Licensee Address ,	
Inspection Information		
Inspection Type Routine	Inspection Date 04/30/2018	Total Time Spent 1.42

Equipment Temperatures	
Description	Temperature (Fahrenheit)
Walk in cooler	40
Victory cooler	38
Milk cooler 2-right	40
Juice cooler	38
Hot box 1-HM 2000	137
Hot box 2-CresCor	147
Hoshizaki refrig(grab-n-go)	38
milk center	40

Warewashing Info					
Machine Name	Sanitization Method	Thermo Label	PPM	Sanitizer Name	Sanitizer Type
bucketDishmachine	chemHeat	160	100	ChlorineHeat	

OPERATOR - Violations cited in this report shall be corrected within the time frames specified below, but within a period not to exceed 10 calendar days for critical items (§ 8-405.11) or 90 days for non-critical items (§ 8-406.11).

Observed Critical Violations
Total # 0
Repeated # 2

ObservedNon-CriticalViolations

Total # 5

Repeated # 2

4-501.11 - GOOD REPAIR, PROPER ADJUSTMENT, AND OPERATION

OBSERVATION: Roller carts in poor repair (bent/wheels won't work)

6-501.11 - PHYSICAL FACILITIES - GOOD REPAIR

REPEAT OBSERVATION Cracked floor tiles need replaced.

6-501.12 - CLEANING, FREQUENCY AND RESTRICTIONS

OBSERVATION: Ceiling vent in mop room needs cleaned

6-501.12 - CLEANING, FREQUENCY AND RESTRICTIONS

OBSERVATION: Wall behind dryer and vent above needs cleaned

6-501.14 - CLEANING VENTILATION SYSTEMS, NUISANCE, AND DISCHARGE PROHIBITION

REPEAT OBSERVATION Hood vents need cleaned .


Inspection Outcome

Comments

Disclaimer

Person in Charge

Sanitarian



Crystal Markely



Keith Allison