# A-CONTROL REMOTE CONTROLLER

#### MA DELUXE REMOTE CONTROLLER PAR-21MAA


## Dot liquid-crystal display is applied


Symbols, Japanese, Chinese, English, Germany, Spanish, Russian, Italian, French display can be selected freely.



#### Dot Liquid Crystal Display

Acknowledging the operation and control status at a glance. The large size display upgrades visual acknowledgement capability. The operation and control status can be understood promptly.





#### Multi-language Display



8 languages can be displayed.

Display can be switched over for 8 kinds of language.



#### **Operation Control Function**

Limiting the set temperature range

Air conditioning operation always within a limited temperature range

Auto Off timer

Automatic turning off of air conditioning operation

Operation locking

Preventing the random modification of setting

#### Weekly Timer

The function of the weekly timer equipped can change the set temperature in addition to the ON/OFF control. Up to 8 patterns can be set for each calendar day.

### **■** Functions Item

ON/OFF

Operation mode

 $\triangle$ 

₩ TEMP.

 $\overline{ }$ 

Temperature

Fan speed setting

Air flow

direction

Permit / Prohibit

local operation

Weekly scheduler

switching

|  | ☐:Each unit ○:Each group  | X:Not a    | vailable   |
|--|---|------------|------------|
| Item   | Description   | Operations | Display    |
| Prohibition/<br>permission of<br>specified mode<br>(Cooling prohibited<br>/heating prohibited<br>/cooling-heating<br>prohibited) | By the setting from System Controller, the operation for the following modes is prohibited. At cooling prohibited : Cool, Dry, Auto, At heating prohibited : Heat, Auto, At cooling-heating prohibited : Cool, Heat, Dry, Auto                  | ×          | 0          |
| Indoor unit intake<br>temperature  | Measures the intake temperature of the indoor unit when the indoor unit is operating.   | ×          | $\circ$    |
| Error  | When an error is currently occurring on an air conditioner unit, the afflicted unit and the error code are displayed.   | ×          |            |
| Test run   | This operates air conditioner units in test run mode.   | 0          | 0          |
| Ventilation equipment  | Up to 16 indoor units can be connected to an interlocked system that has one LOSSNAY. LOSSNAY items that can be set are "Hi" "Low" "Stop". Ventilation mode switching is not available.   | 0          | $\bigcirc$ |
| Function to<br>limit the<br>setting range<br>of room<br>temperature<br>(Set temperature<br>range limit)                          | The range of room temperature setting can be limited by the initial setting. The lowest limit temperature can be made higher than the usual (19°C) at cooling/drying, while the upper limit temperature lower than the usual (28°C) at heating. | 0          | 0          |
| Easy-to-operate<br>simplified<br>locking function<br>(Auto lock function)  | Setting/releasing of simplified locking for remote control switch can be performed.  Locking of all switches Locking of all switches except Start/Stop switch   | 0          | 0          |

**■** External dimension Unit:mm

Operations Display

 $\bigcirc$ 

 $\bigcirc$ 

 $\bigcirc$ 

 $\bigcirc$ 

 $\bigcirc$ 

()

\*1

X

Description

Switches between Cool / Dry / Auto / Fan / Heat. Operation modes vary depending on the air

Cool/Dry: 19°C - 30°C (66°F - 86°F)

Models with 4 air flow speed settings: Hi/Mid-2/Mid-1/Low Models with 3 air flow speed settings: Hi/Mid/Low Models with 2 air flow speed settings: Hi/Low

Air flow direction angles 100% - 80% - 60% - 40% Swing , Louver ON/OFF Air flow direction settings vary depending

Individually prohibit operation of each local remote control function (Start/Stop, Change operation

\*1: When the local remote controller inactivation command is received from the master system controller, "

" is displayed.

ON/OFF/Temperature setting can be done up to 8 times one day in the week.

The time can be set by the minute.

mode, Set temperature, Reset filter)

:17°C - 28°C (63°F - 82°F)

: 19°C - 28°C (66°F - 82°F)

Run and stop operation for a single group

Sets the temperature for a single group

Range of temperature setting

conditioner unit.

Heat Auto

on the model.

