

ASTRO-CHEM LAB, INC.

4102 2nd Ave. West

Williston, North Dakota 58802-0972
P.O Box 972

Phone: (701) 572-7355

WATER ANALYSIS REPORT

Sample Number: W-17-0182

Date of Analysis: 01/17/2017

Company: Ridgeview Park

City: Tiburon

State: CA

Well Number: Dore Water Depot

Date Received: 01/16/2017

DST Number:

Sample Source: Water Depot

Location:

Section:

Township:

Range:

County:

Formation:

Depth:

Distribution: Distribution List

Resistivity @ 77 °F 7.810 Ohm-Meters pH 7.20


Specific Gravity @ 77 °F 1.000 H2S Negative

Total Dissolved Solids (Calculated) 1093 mg/L (1093 ppm)

Sodium Chloride (Calculated) 79 mg/L (79 ppm)

CATION	MEQ/L	mg/L	ANION	MEQ/L	mg/L
CALCIUM	10.2	204	CHLORIDE	1.4	48
MAGNESIUM	0.2	2	CARBONATE	0.0	0
SODIUM	4.6	106	BICARBONATE	8.2	500
IRON	0.0	0.0	SULFATE	4.3	209
CHROMIUM	0.0	0.0	NITRATE	0.3	18
BARIUM	0.0	0.0			
POTASSIUM	0.1	5			

WATER ANALYSIS PATTERN



Remarks: Sampled 1-16-17 by D. Fonua
Conductivity = 1281 μ mhos/cm

Analyzed By: C. Jungels