

**West Virginia Department of
Health & Human Resources
Berkeley County Health
Department**



GENERAL SANITATION INSPECTION REPORT

Establishment Information		
Facility Name North Middle School	Facility Type School	
Licensee Name Berkeley Co. Board of Education	Facility Telephone # 304 267-3540	
Facility Address 250 East Rd Martinsburg, WV	Licensee Address ,	
Inspection Information		
Inspection Type Routine	Inspection Date April 19, 2019	Total Time Spent 2.25

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 5 Repeated # 0</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose. OBSERVATION: Missing ceiling tiles in 6th grade boys bathroom</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose. OBSERVATION: leaking faucets in rooms 138, 102</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose. OBSERVATION: Cafeteria bathroom hand sinks need batteries changed on the faucets</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose. OBSERVATION: All metered faucets need to be set at 15 seconds in all faucets that use this type.</p> <p>64-18-10.1 - The entire premises and its contents shall be maintained in good repair and in a clean and sanitary condition. Facilities and equipment shall be provided for this purpose. OBSERVATION: Stained ceiling tiles 109,116,127a</p>

COPY